



1 **EU-TYPE EXAMINATION CERTIFICATE**

2 Equipment intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU

3 Certificate Number: **Sira 16ATEX2219X** Issue: **7**

4 Equipment: **Proline Promass 300/500, Proline Cubemass 300/500 and Proline Promag 300/500**

5 Applicant: **Endress+Hauser Flowtec AG**

6 Address: Endress+Hauser Flowtec AG Kaegenstrasse 7, CH-4153, Reinach BL, Switzerland  
Endress+Hauser Flowtec AG , Cernay, France  
Endress+Hauser Flowtec (India) Pvt. Ltd. Waluj, India  
Endress+Hauser Flowtec AG Div. U.S.A. Greenwood, USA  
Endress+Hauser Flowtec (China) Co. Ltd. Suzhou, P.R. China  
Endress + Hauser Flowtec (Brazil) Fluxômetros Ltda., Estrada Municipal Antônio Sesti, 600 A - Recreio Costa Verde – Itatiba / SP, CEP 13254 – 085 – Brazil  
Endress+Hauser Flowtec (China) Co. Ltd.,  
Site 1: China- Singapore Suzhou Industrial Park (SIP), Su-Hong-Zhong-Lu No. 465  
Site 2: Suzhou Industrial Park (SIP), Jiang-Tian-Li-Lu No. 31, 215021 Suzhou, P.R. China

7 This equipment and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

8 CSA Group Netherlands B.V., notified body number 2813 in accordance with Articles 17 and 21 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential reports listed in Section 14.2.

9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the schedule to this certificate, has been assured by compliance with the following documents:

EN IEC 60079-0:2018	EN 60079-1:2014	EN 60079-11:2012
EN 60079-26:2015	EN 60079-31:2014	EN 60079-7:2015

10 If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to Specific Conditions of Use identified in the schedule to this certificate.

11 This EU-Type Examination Certificate relates only to the design and construction of the specified equipment. If applicable, further requirements of this Directive apply to the manufacture and supply of this equipment.

12 The marking of the equipment shall be as defined in the Certificate Annexe.

Project Number 80036352

Signed: J A May

Title: Director of Operations

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
Utrechtseweg 310,  
6812 AR, Arnhem,  
Netherlands



## SCHEDULE

### EU-TYPE EXAMINATION CERTIFICATE

Sira 16ATEX2219X

Issue 7

#### 13 DESCRIPTION OF EQUIPMENT

The Proline 300 / 500 is a platform used for flowmeters of type Proline Promag 300, Proline Promag 500, Proline Promass 300, Proline Promass 500, Proline Cubemass 300, Proline Cubemass 500, Proline Prosonic Flow G 300, Proline Prosonic Flow G 500, Proline Prosonic Flow P 500, Proline t-mass 300 and Proline t-mass 500.

All flowmeters are available in two versions, a compact version (Proline 300) and a remote version (Proline 500). The remote Proline 500 version is also available as a version with ISEM integrated in transmitter where the sensor sends analog signals to the transmitter and a version with ISEM integrated in sensor where the sensor is connected by a digital circuit to the transmitter with additional electronics located at the sensor for assessment of the sensor signals. Proline Prosonic Flow G 500 and Proline t-mass 500 are not available as a version with ISEM integrated in transmitter.

For all versions of the Proline 300, an additional remote Display, e.g. DKX001 or ODKX001, may be connected to the electronics. The remote display is available in two options for the user. Either it is ordered as a separate product or by the product of the flowmeter.

Different electronics are used for the flowmeters where the sensor is installed in a Zone 1 location and where the transmitter can be installed in a safe area or Zone 1 or 2 locations. All versions of electronics are designed either with intrinsically safe IO's (Ex "ia" for Zone 1) or with non-intrinsically safe IO's. A mix of type of protections, Ex "i" in combination with non-Ex "i" IO's is not allowed.

All Proline Promag 300/500, Proline Promass 300/500, Proline Prosonic Flow G 300/500 and Proline t-mass 300/500 flowmeters are available for an ambient temperature of -40°C to +60°C and optional -50°C to +60°C.

In addition, the version of the sensor of Proline Promass F/X/Q 500 with ISEM electronic in transmitter is available also for -60°C to +60°C ambient. Proline Prosonic Flow P 500 sensors are available for an ambient temperature of -20/-40/-50°C to +80°C and Proline Prosonic Flow P 500 transmitters are available for an ambient temperature of -40°C to +60°C and optional -50°C to +60°C.

An antenna bushing at cable entry for transmitter enclosures in type of protection Ex "eb", and Ex "tb" is available for connection of an external antenna.

**Variation 1** - This variation introduced the following changes:

- i. Minor changes to product order codes of Promag W500.
- ii. Minor corrections to product markings.
- iii. Introduction of remote display as part of the flowmeter.
- iv. Minor corrections to the product drawings

**Variation 2** - This variation introduced the following changes:

- i. The addition of model code for replacement transmitter OEM version and new assignment table of replacement transmitter to product of flowmeter.
- ii. The addition of a new, certified sensor "Promass A" sensor with changes to model code.
- iii. Update in the ambient temperature reduced optionally to -60°C for sensors of Promass F/Q/X 500 with code for integrated ISEM electronic k = "B" as described in the technical description document
- iv. All the corresponding drawings were updated to recognise minor administrative amendments.
- v. The introduction of the Proline Promass 300/500 and Proline Cubemass 300/500 flowmeters. These devices were previously covered by certificate Sira 16ATEX2177X using EN 60079-26:2015 as an



## SCHEDULE

### EU-TYPE EXAMINATION CERTIFICATE

Sira 16ATEX2219X

Issue 7

assessment standard; therefore, this document needs to be recognised in the list of supporting documents.  
(Note: As a result of this change, Sira 16ATEX2177X is no longer required and will therefore be suspended.)

- Previously, EN 60079-15 was specified as a supporting document, this was an error and therefore this standard was removed.

**Variation 3** – This variation introduced the following changes:

- The recognition of minor drawings amendments, none of which affect compliance with the applicable standards.
- Minor correction of ATEX marking nameplate to separate the ATEX markings from IECEx.

**Variation 4** – This variation introduced the following changes:

- Introduction of new model version Proline Prosonic Flow G 300/500
- Introduction of new model version Proline t-mass 300/500
- Introduction of new Antenna bushing model H337 for external antenna connection with the Proline 300/500 transmitter
- Addition of new order codes for IO1 current output (active) with I/O code dd = "CC" and "CD"
- Addition of new order codes for IO2, IO3 and IO4 with I/O code "K" for pulse output Ex i (passive) and with I/O code "L" for pulse output non Ex i
- Addition of new product order codes to include for Promag W300 and Promag W500
- Revised standard IEC 60079-0, Edition 6 to IEC60079-0, Edition 7.0
- The recognition of drawings amendments, none of which affect compliance with the applicable standards

**Variation 5** – This variation introduced the following changes:

- Addition of product order code "ww = A2" for model Proline Promag 300/500, Proline Prosonic 300/500 and Proline t-mass 300/500. See Certificate Annexe for order code details
- Correction of entity parameter for IO1 order codes: CA, CB (Ci= 0, changed to Ci =6nF) in the applicable drawings
- The recognition of drawings amendments, none of which affect compliance with the applicable standards.

**Variation 6** – This variation introduced the following changes:

- Changes in nomenclature ("Digital" is now referred as ISEM integrated in sensor, "Analog" is now referred to as ISEM integrated in transmitter)
- Introduction of new flange sizes for Proline Promass 300/500 for High Temperature (HT) flowmeters.
- Update of related product documentation
- Following appropriate assessment to demonstrate compliance with the latest technical knowledge, EN 60079-0:2012/A11:2013 was replaced by EN IEC 60079-0:2018.
- The description was amended to reflect the above changes
- Addition of two manufacturing locations in China as shown on TÜV QAN, TÜV 98 ATEX 1348Q

## 14 DESCRIPTIVE DOCUMENTS

### 14.1 Drawings

**Issue 0:** See Cover Sheet of IECEx Test Report CA/CSA/ExTR16.0031/00 for a full list of drawings covered by this issue.

**Issue 1:** See Cover Sheet of IECEx Test Report CA/CSA/ExTR16.0031/01 for a full list of drawings covered by this issue.

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
Utrechtseweg 310,  
6812 AR, Arnhem Netherlands



## SCHEDULE

### EU-TYPE EXAMINATION CERTIFICATE

Sira 16ATEX2219X

Issue 7

**Issue 2:** See Cover Sheet of IECEx Test Report CA/CSA/ExTR16.0031/02 for a full list of drawings covered by this issue. These drawings were rationalised and supersede those detailed in Issues 0 and 1

**Issue 3:** See Cover Sheet of IECEx Test Report CA/CSA/ExTR16.0031/03 for a full list of drawings covered by this issue. These drawings were rationalised and supersede those detailed in Issue 2 and earlier.

**Issue 4:** See Cover Sheet of IECEx Test Report CA/CSA/ExTR16.0031/04 for a full list of drawings covered by this issue. These drawings were rationalised and supersede those detailed in Issue 3 and earlier.

**Issue 5:** See Cover Sheet of IECEx Test Report CA/CSA/ExTR16.0031/05 for a full list of drawings covered by this issue. These drawings were rationalised and supersede those detailed in Issue 4 and earlier.

**Issue 6:** No new drawings were introduced

**Issue 7:** See Cover Sheet of IECEx Test Report CA/CSA/ExTR16.0031/06 for a full list of drawings covered by this issue. These drawings were rationalised and supersede those detailed in Issue 5 and earlier.

#### 14.2 Associated Sira Reports and Certificate History

Issue	Date	Report no.	Comment
0	19 July 2016	R70084415A	The release of the prime certificate.
1	23 February 2017	R70110427A	The introduction of Variation 1.
2	26 September 2017	R70140398A	The introduction of Variation 2.
3	12 January 2018	R70162908A	The introduction of Variation 3.
4	25 March 2019	R70214610A	The introduction of Variation 4.
5	23 August 2019	R80012315A	The introduction of Variation 5
6	15 October 2019	0626	Transfer of certificate Sira 16ATEX2219X from Sira Certification Service to CSA Group Netherlands B.V.
7	11 August 2020	R80036352A	The introduction of Variation 6.

#### 15 SPECIFIC CONDITIONS OF USE (denoted by X after the certificate number)

15.1 All equipment of the measurement system shall be included in the equipotential bonding. Along the intrinsically safe circuits potential equalization must exist.

15.2 The sensors may only be used for those process media, for which the wetted parts are known to be suitable

15.3 Plastic transmitter enclosures for the order codes listed below shall be installed in an area of at least pollution degree 2.

Proline Promass 8\*5\*\*\*-(BI/BJ)\*\*\*\*\*A....,  
 Proline Promass 08\*5\*\*\*-(BI/BJ)\*\*\*\*\*A....,  
 Proline Promass 8X5\* XX -(BI/BJ) \*\*\*\*\*A....  
 Proline Promass 08X5\* XX -(BI/BJ) \*\*\*\*\*A....

Proline Promag 5\*5\*\*\*-(BJ)\*\*\*\*\*A....,  
 Proline Promag 05\*5\*\*\*-(BJ)\*\*\*\*\*A....,  
 Proline Promag 5X5\* XX -(BJ) \*\*\*\*\*A....  
 Proline Promag 05X5\* XX -(BJ) \*\*\*\*\*A....

Proline Prosonic Flow G 9\*5\*\*\*-(BJ)...,  
 Proline Prosonic Flow G 09\*5\*\*\*-(BJ) ...,  
 Proline Prosonic Flow G 9X5\*XX-(BJ)...,  
 Proline Prosonic Flow G 09X5\*XX-(BJ)...

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
Utrechtseweg 310,  
6812 AR, Arnhem Netherlands



SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

Sira 16ATEX2219X  
Issue 7

Proline t-mass 6\*5\*\*\*-(BJ)...,  
Proline t-mass O6\*5\*\*\*-(BJ) ...,  
Proline t-mass 6X5\*XX-(BJ)...,  
Proline t-mass O6X5\*XX-(BJ)...

15.4 Equipment with the following order codes for Proline Promass shall be installed using a transient protection not exceeding 140% of the peak rated voltage value at the supply terminals to the equipment.  
For order code 'dd' = BM, BN

15.5 If the flowmeter system is connected to remote display type DKX001, the approval codes 'dd' for the flowmeter shall be paired to the approval code "bb" of the remote display as follows:

Approval code 'dd' of Proline Promass 300	Approval code 'bb' of remote display DKX001/ODKX001 as covered by DEKRA15ATEX0044
BA, BB, BC or BD	BE, BF or BG

15.6 Equipment with the following order codes for Proline Promag, Proline Prosonic Flow G and Proline t-mass shall be installed using a transient protection not exceeding 140% of the peak rated voltage value at the supply terminals to the equipment.  
For order code 'dd' = BN

15.7 For remote versions of Promag flowmeters with a flat gasket within the sensor terminal box, the user shall ensure that flat cover seals are not bent into the seal surface before securing the cover. Seals that are not flat shall be replaced.

15.8 If the flowmeter system is connected to remote display type DKX001, the approval codes 'dd' for the flowmeter shall be paired to the approval code "bb" of the remote display as follows:

Approval code 'dd' of Proline Promag 300, Proline Prosonic Flow G 300 and Proline t-mass 300	Approval code 'bb' of remote display DKX001/ODKX001 as covered by DEKRA15ATEX0044
BB, BD, B7 or B8	BE, BF or BG

15.9 For remote versions of Promag flowmeters with a flat gasket within the sensor terminal box, the user shall ensure that flat cover seals are not bent into the seal surface before securing the cover. Seals that are not flat shall be replaced.

15.10 The equipment has non-conductive surfaces which are a potential electrostatic charging hazard - see instructions for guidance.

**Applicable to Antenna bushing H337 when used with Proline 300/500 transmitter enclosure:**

15.11 Antenna supplied by Endress+Hauser shall be used only. As an alternate, any passive omni-directional RF antenna with or without cable is permitted to be connected when meeting the following parameters:

- a) The antenna connected to the antenna bushing shall have an impedance of at least 50Ω
- b) The rated frequency range of the antenna shall not exceed 1710MHz ... 6000MHz
- c) The rated power of the antenna shall be at least 100mW



## SCHEDULE

### EU-TYPE EXAMINATION CERTIFICATE

Sira 16ATEX2219X

Issue 7

- 15.12 The antenna bushing type H337 shall be mounted wrench tight to the transmitter enclosure to maintain the ingress protection of the enclosure
- 15.13 The RF antenna or the RF antenna cable shall be fitted with a Series N (MIL-STD-348) plug connector. The coupling nut of the Series N plug connector shall be hand tightened only
- 15.14 The metal enclosure of the Antenna Bushing H337 shall be securely connected to local earth, typically via the enclosure to which it is connected

### 16 ESSENTIAL HEALTH AND SAFETY REQUIREMENTS OF ANNEX II (EHSRs)

The relevant EHSRs that are not addressed by the standards listed in this certificate have been identified and individually assessed in the reports listed in Section 14.2.

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
 Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

## 1 Proline Promass 300/500, Proline Cubemass 300/500

### 1.1 Marking

Proline Promass 500 analog, Proline Cubemass 500 with ISEM integrated in transmitter				
i. Model Code: 8*5*** – dd*ff****B*****+### 08*5*** – dd*ff****B*****+###				
dd = approval	ff = I/O	Device	ATEX marking	Marking of Ex protection
BA	CA, CB, CC, CD, HA, TA, BA, BB, GA, LA, NA, RA, SA, MA	Transmitter	⊕ II2(1)G ⊕ II2(1)D	Ex db eb ia [ia Ga] IIB T6...T5 Gb Ex tb [ia Da] IIIC T85°C Db
		Sensor	⊕ II1/2G ⊕ II2G ⊕ II2D	Ex ia IIB T6...T1 Ga/Gb <sup>1)</sup> Ex ia IIB T6...T1 Gb Ex ia tb IIIC T** °C Db
BB	CA, CB, CC, CD, HA, TA, BA, BB, GA, LA, NA, RA, SA, MA	Transmitter	⊕ II2(1)G ⊕ II2(1)D	Ex db eb ia [ia Ga] IIC T6... T5 Gb Ex tb [ia Da] IIIC T85°C Db
		Sensor	⊕ II1/2G ⊕ II2G ⊕ II2D	Ex ia IIC T6...T1 Ga/Gb <sup>1)</sup> Ex ia IIC T6...T1 Gb Ex ia tb IIIC T** °C Db
BC	CA, CB, CC, CD, HA, TA, BA, BB, GA, LA, NA, RA, SA, MA	Transmitter	⊕ II2(1)G ⊕ II2(1)D	Ex db ia [ia Ga] IIB T6... T5 Gb Ex tb [ia Da] IIIC T85°C Db
		Sensor	⊕ II1/2G ⊕ II2G ⊕ II2D	Ex ia IIB T6...T1 Ga/Gb <sup>1)</sup> Ex ia IIB T6...T1 Gb Ex ia tb IIIC T** °C Db
BD	CA, CB, CC, CD, HA, TA, BA, BB, GA, LA, NA, RA, SA, MA	Transmitter	⊕ II2(1)G ⊕ II2(1)D	Ex db ia [ia Ga] IIC T6... T5 Gb Ex tb [ia Da] IIIC T85°C Db
		Sensor	⊕ II1/2G ⊕ II2G ⊕ II2D	Ex ia IIC T6...T1 Ga/Gb <sup>1)</sup> Ex ia IIC T6...T1 Gb Ex ia tb IIIC T** °C Db

1) The following sensors are marked for EPL Gb: Promass A DN1, Promass H DN8...50, Promass I DN 8...80

Proline Promass 500 analog, Proline Cubemass 500 analog				
Model Code: 8*5*** – dd*ff****B*****+### 08*5*** – dd*ff****B*****+###				
dd = approval	ff = I/O	Device	ATEX marking	Marking of Ex protection transmitter
BA	CA, CB, CC, CD, HA, TA, BA, BB, GA, LA, NA, RA, SA, MA	Transmitter	⊕ II2(1)G ⊕ II2(1)D	Ex db eb ia [ia Ga] IIB T6...T5 Gb Ex tb [ia Da] IIIC T85°C Db
		Sensor	⊕ II1/2G ⊕ II2G ⊕ II2D	Ex ia IIB T6...T1 Ga/Gb <sup>1)</sup> Ex ia IIB T6...T1 Gb Ex ia tb IIIC T** °C Db
BB	CA, CB, CC, CD, HA, TA, BA, BB, GA, LA, NA, RA, SA, MA	Transmitter	⊕ II2(1)G ⊕ II2(1)D	Ex db eb ia [ia Ga] IIC T6... T5 Gb Ex tb [ia Da] IIIC T85°C Db
		Sensor	⊕ II1/2G ⊕ II2G ⊕ II2D	Ex ia IIC T6...T1 Ga/Gb <sup>1)</sup> Ex ia IIC T6...T1 Gb Ex ia tb IIIC T** °C Db
BC	CA, CB, CC, CD, HA, TA, BA, BB,	Transmitter	⊕ II2(1)G ⊕ II2(1)D	Ex db ia [ia Ga] IIB T6... T5 Gb Ex tb [ia Da] IIIC T85°C Db

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X

Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

Proline Promass 500 analog, Proline Cubemass 500 analog				
Model Code: 8*5*** – dd*ff****B*****+##*# O8*5*** – dd*ff****B*****+##*#				
	GA, LA, NA, RA, SA, MA	Sensor	<input type="checkbox"/> II1/2G <input type="checkbox"/> II2G <input type="checkbox"/> II2D	Ex ia IIB T6...T1 Ga/Gb <sup>1)</sup> Ex ia IIB T6...T1 Gb Ex ia tb IIIC T** °C Db
BD	CA, CB, CC, CD, HA, TA, BA, BB, GA, LA, NA, RA, SA, MA	Transmitter	<input type="checkbox"/> II2(1)G <input type="checkbox"/> II2(1)D	Ex db ia [ia Ga] IIC T6... T5 Gb Ex tb [ia Da] IIIC T85°C Db
		Sensor	<input type="checkbox"/> II1/2G <input type="checkbox"/> II2G <input type="checkbox"/> II2D	Ex ia IIC T6...T1 Ga/Gb <sup>1)</sup> Ex ia IIC T6...T1 Gb Ex ia tb IIIC T** °C Db

1) The following sensors are marked for EPL Gb: Promass A DN1, Promass H DN8...50, Promass I DN 8...80

Proline Promass 500 digital, Proline Cubemass 500 with ISEM integrated in sensor				
Model Code: 8*5*** – dd*ff****A*****+##*# O8*5*** – dd*ff****A*****+##*#				
dd = Approval	ff = I/O	Device	ATEX marking	Marking of Ex protection transmitter
BI	BA, BB, GA, LA, NA, RA, SA, MA	Transmitter	<input type="checkbox"/> II(1)G <input type="checkbox"/> II(1)D	[Ex ia] IIC [Ex ia] IIIC
		Sensor	<input type="checkbox"/> II1/2G <input type="checkbox"/> II2G <input type="checkbox"/> II2D	Ex ia IIB T6...T1 Ga/Gb <sup>1)</sup> Ex ia IIB T6...T1 Gb Ex ia tb IIIC T** °C Db
BJ	BA, BB, GA, LA, NA, RA, SA, MA	Transmitter	<input type="checkbox"/> II(1)G <input type="checkbox"/> II(1)D	[Ex ia] IIC [Ex ia] IIIC
		Sensor	<input type="checkbox"/> II1/2G <input type="checkbox"/> II2G <input type="checkbox"/> II2D	Ex ia IIC T6...T1 Ga/Gb <sup>1)</sup> Ex ia IIC T6...T1 Gb Ex ia tb IIIC T** °C Db
BM	HA, TA, CA, CB, CC, CD	Transmitter	<input type="checkbox"/> II(1)G <input type="checkbox"/> II(1)D	[Ex ia] IIC [Ex ia] IIIC
		Sensor	<input type="checkbox"/> II1/2G <input type="checkbox"/> II2G <input type="checkbox"/> II2D	Ex ia IIB T6...T1 Ga/Gb <sup>1)</sup> Ex ia IIB T6...T1 Gb Ex ia tb IIIC T** °C Db
	BA, BB, GA, NA, RA, SA, MA	Transmitter	<input type="checkbox"/> II(1)G <input type="checkbox"/> II(1)D	[Ex ia] IIC [Ex ia] IIIC
		Sensor	<input type="checkbox"/> II1/2G <input type="checkbox"/> II2G <input type="checkbox"/> II2D	Ex ia IIB T6...T1 Ga/Gb <sup>1)</sup> Ex ia IIB T6...T1 Gb Ex ia tb IIIC T** °C Db
BN	HA, TA, CA, CB, CC, CD	Transmitter	<input type="checkbox"/> II(1)G <input type="checkbox"/> II(1)D	[Ex ia] IIC [Ex ia] IIIC
		Sensor	<input type="checkbox"/> II1/2G <input type="checkbox"/> II2G <input type="checkbox"/> II2D	Ex ia IIC T6...T1 Ga/Gb <sup>1)</sup> Ex ia IIC T6...T1 Gb Ex ia tb IIIC T** °C Db
	BA, BB, GA, NA, RA, SA, MA	Transmitter	<input type="checkbox"/> II(1)G <input type="checkbox"/> II(1)D	[Ex ia] IIC [Ex ia] IIIC
		Sensor	<input type="checkbox"/> II1/2G <input type="checkbox"/> II2G <input type="checkbox"/> II2D	Ex ia IIC T6...T1 Ga/Gb <sup>1)</sup> Ex ia IIC T6...T1 Gb Ex ia tb IIIC T** °C Db

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands



# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500  
Applicant: Endress+Hauser Flowtec AG

---



1) The following sensors are marked for EPL Gb: Promass A DN1, Promass H DN8...50, Promass I DN 8...80

## 1.2 Order Code

Extended order code Proline Promass 300 and Cubemass 300:

8a3bcc – ddeffghjlpstttvww + #\*\*#

**O8a3bcc – ddeffghjlpstttvwwyy + #\*\*#**

8x3bxx – ddeffghjlprrssww + #\*\*#

**O8x3bxx – ddeffghjlprrsswwyy + #\*\*#**

for OEM-version

for replacement transmitter

for replacement transmitter OEM

Extended order code Proline Promass 500 and Cubemass 500:

8a5bcc – ddeffghjkmnopsstttvww + #\*\*#

**O8a5bcc – ddeffghjkmnopsstttvwwyy + #\*\*#**

8x5bxx – ddeffghjkmopqrrssww + #\*\*#

**O8x5bxx – ddeffghjkmopqrrsswwyy + #\*\*#**

for OEM-version

for replacement transmitter

for replacement transmitter OEM

- a = Type of sensor**  
A = Promass A; C = Cubemass C; E = Promass E; F = Promass F; H = Promass H;  
I = Promass I; O = Promass O; P = Promass P; Q = Promass Q; S = Promass S;  
X = Promass X
- b = Generation**  
B = Promass A (type 8A\*B\*\*, O8A\*B\*\*); Cubemass C; Promass E;  
Promass F; Promass H; Promass I; Promass O;  
Promass P; Promass Q; Promass S; Promass X  
C = Promass A (type 8A\*C\*\*, O8A\*C\*\*)
- cc = Size**  
any double digits with combination of number or letter

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
Utrechtseweg 310,  
6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

dd	=	<b>Approval</b>	
		<u>Proline Promass 300:</u>	
		BA =Ex db eb [ia] IIB T6...T1 Gb	
		Ex tb IIIC T** Db	
		BB =Ex db eb [ia] IIC T6...T1 Gb	
		Ex tb IIIC T** Db	
		BC =Ex db [ia] IIB T6...T1 Gb	
		Ex tb IIIC T** Db	
		BD =Ex db [ia] IIC T6...T1 Gb	
		Ex tb IIIC T** Db	
		<u>Proline Promass 500:</u>	
		BA =Ex db eb [ia] IIB T6...T4 Gb	(transmitter)
		Ex ia IIB T6...T1 Gb	(sensor)
		Ex tb IIIC T** Db	(transmitter + sensor)
		BB =Ex db eb [ia] IIC T6...T4 Gb	(transmitter)
		Ex ia IIC T6...T1 Gb	(sensor)
		Ex tb IIIC T** Db	(transmitter + sensor)
		BC =Ex db [ia] IIB T6...T4 Gb	(transmitter)
		Ex ia IIB T6...T1 Gb	(sensor)
		Ex tb IIIC T** Db	(transmitter + sensor)
		BD =Ex db [ia] IIC T6...T4 Gb	(transmitter)
		Ex ia IIC T6...T1 Gb	(sensor)
		Ex tb IIIC T** Db	(transmitter + sensor)
		BI =[Ex ia] IIC	(transmitter)
		Ex ia IIB T6...T1 Gb	(sensor)
		Ex tb IIIC T** Db	(sensor)
		BJ =[Ex ia] IIC	(transmitter)
		Ex ia IIC T6...T1 Gb	(sensor)
		Ex tb IIIC T** Db	(sensor)
		BM =[Ex ia] IIC	(transmitter)
		Ex ia IIB T6...T1 Gb	(sensor)
		Ex tb IIIC T** Db	(sensor)
		BN =[Ex ia] IIC	(transmitter)
		Ex ia IIC T6...T1 Gb	(sensor)
		Ex tb IIIC T** Db	(sensor)
e	=	<b>Power Supply</b>	
		D = 24Vdc	
		E = 100-230Vac	
		I = 100-230Vac / 24Vdc	
		X = sensor only	

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
Utrechtseweg 310,  
6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

---

- ff = Input / Output 1**  
BA = 4-20mA HART  
BB = 4-20mA WHART  
CA = 4-20mA HART Ex i (passive)  
CB = 4-20mA WHART Ex i (passive)  
CC = 4-20mA HART Ex i (active)  
CD = 4-20mA WHART Ex i (active)  
GA = Profibus PA  
HA = Profibus PA Ex i  
LA = Profibus DP  
NA = EtherNet/IP  
RA = Profinet IO  
SA = Foundation Fieldbus  
TA = Foundation Fieldbus Ex i  
MA = Modbus RS485  
X = sensor only
- g = Input / Output 2**  
A = without Input/Output 2  
B = 4-20mA  
C = 4-20mA Ex i (passive)  
D = Configurable IO  
E = Pulse/Frequency/Switch output  
F = Pulse output phase-shifted  
G = Pulse/Frequency/Switch output Ex i  
H = Relay  
I = 4-20mA input  
J = Status input  
L = Pulse output Ex i  
K = Pulse output  
X = sensor only
- h = Input / Output 3**  
A = without Input/Output 3  
B = 4-20mA  
C = 4-20mA Ex i (passive)  
D = Configurable IO  
E = Pulse/Frequency/Switch output  
F = Pulse output phase-shifted  
G = Pulse/Frequency/Switch output Ex i  
H = Relay  
I = 4-20mA input  
J = Status input  
L = Pulse output Ex i  
K = Pulse output  
X = sensor only

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
Utrechtseweg 310,  
6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

---

- i** = **Input / Output 4** (Proline 500 only)
  - A = without Input/Output 4
  - B = 4-20mA
  - C = 4-20mA Ex i (passive)
  - D = Configurable IO
  - E = Pulse/Frequency/Switch output
  - F = Pulse output phase-shifted
  - G = Pulse/Frequency/Switch output Ex i
  - H = Relay
  - I = 4-20mA input
  - J = Status input
  - L = Pulse output Ex i
  - K = Pulse output
  - X = sensor only
- j** = **Display / Operation**
  - with remote Display : O
  - without remote Display : any single number or letter except O
- k** = **Integrated ISEM electronic** (Proline 500 only)
  - A = Sensor
  - B = Transmitter
- l** = **Housing** (Proline 300 only)
  - any single number or letter
- m** = **Transmitter Housing** (Proline 500 only)
  - any single number or letter
- n** = **Sensor Housing** (Proline 500 only)
  - any single number or letter
- o** = **Cable Sensor Connection** (Proline 500 only)
  - any single number or letter
- p** = **Cable Entry**
  - any single number or letter
- qq** = **Upgrade Kid**
  - any double digits with combination of number or letter
- rr** = **Existing Product** (refer to section 1.3 for assignment table of flowmeter to replacement transmitter)
  - any double digits with combination of number or letter
- ss** = **Measuring tube material**
  - any double digits with combination of number or letter
- ttt** = **Process connection**
  - any triple digits with combination of number or letter
- v** = **Calibration**
  - any single number or letter
- ww** = **Device model (two digit)** (refer to section 1.3 for assignment table of flowmeter to replacement transmitter)
  - A1 = product version 1
  - A2 = product version 2
- yy** = **Customer version (two digit)**
  - any double digits with combination of number or letter

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
Utrechtseweg 310,  
6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
 Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

- \*\* = Option in two digits (none, two or multiple of two digits)  
any combination of number and/or letter
- #, + = Signs used as indicator for optional abbreviation of extended order code

## 1.3 Assignment of Flowmeter to Replacement Transmitter

The replacement transmitters are assigned to the flowmeter Proline Promass 300/500 as follows:

Product flowmeters			Replacement transmitter type			
model code	Generation code b =	device model code ww =	model code	Generation code b =	existing product rr =	device model code ww =
8A*b**-...ww, O8A*b**-...ww	B	A1	8x*bxx-...rr...ww, O8x*bxx-...rr...ww	B	AA	A1
8C*b**-...ww, O8C*b**-...ww	B	A1	8x*bxx-...rr...ww, O8x*bxx-...rr...ww	B	C*	A1
8E*b**-...ww, O8E*b**-...ww	B	A1	8x*bxx-...rr...ww, O8x*bxx-...rr...ww	B	E*	A1
8F*b**-...ww, O8F*b**-...ww	B	A1	8x*bxx-...rr...ww, O8x*bxx-...rr...ww	B	F*	A1
8H*b**-...ww, O8H*b**-...ww	B	A1	8x*bxx-...rr...ww, O8x*bxx-...rr...ww	B	H*	A1
8I*b**-...ww, O8I*b**-...ww	B	A1	8x*bxx-...rr...ww, O8x*bxx-...rr...ww	B	I*	A1
8O*b**-...ww, O8O*b**-...ww	B	A1	8x*bxx-...rr...ww, O8x*bxx-...rr...ww	B	O*	A1
8P*b**-...ww, O8P*b**-...ww	B	A1	8x*bxx-...rr...ww, O8x*bxx-...rr...ww	B	P*	A1
8Q*b**-...ww, O8Q*b**-...ww	B	A1	8x*bxx-...rr...ww, O8x*bxx-...rr...ww	B	Q*	A1
8S*b**-...ww, O8S*b**-...ww	B	A1	8x*bxx-...rr...ww, O8x*bxx-...rr...ww	B	S*	A1
8X*b**-...ww, O8X*b**-...ww	B	A1	8x*bxx-...rr...ww, O8x*bxx-...rr...ww	B	X*	A1
8A*b**-...ww, O8A*b**-...ww	C	A1	8x*bxx-...rr...ww, O8x*bxx-...rr...ww	B	AB	A1

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X

Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

## 1.4 Sensor Groups

In the following tables, the Promass 300/500 sensors are assigned to different sensor groups depending on their sensor size and electronics version.

Assignment of Promass sensors and Cubemass sensors installed in Zone 1:

Sensor Group	Type of sensor	Size of sensor	Group	T <sub>Med,min</sub>
A1	A (type 8A*B**)	01, 02, 04	IIC	-50°C
	C	01, 02, 04, 06	IIC	-50°C
	E	25, 40, 50	IIC	-50°C
	F	08, 15, 25, 40, 50	IIC	-50°C /-60°C *)
	F(HT)	15, 25, 50	IIC	-50°C
	H, S, P	08, 15, 25, 40	IIC	-50°C
	I	08, 15, 16, 25, 26, 40	IIC	-50°C
	Q	25, 50	IIC	-50°C /-60°C *)
B1	A (type 8A*C**)	01, 02, 04	IIC	-50°C
	E	08, 15, 80	IIC	-50°C
	F	08, 15	IIC	-50°C /-60°C *)
	F, F(HT), O	80, 100, 150, 250	IIC	-50°C /-60°C *)
	I	41, 50, 51, 80	IIC	-50°C
	H, S, P	50	IIC	-50°C
	Q	80, 100	IIC	-50°C /-60°C *)
	X	350	IIC	-50°C /-60°C *)
C1	F	15, 25, 40, 50	IIC	-200°C
	H	8, 15, 25, 40, 50	IIC	-200°C
D1	Q	25, 50	IIC	-200°C
	F	08, 15, 80, 100, 150, 250	IIC	-200°C
E1	H	50	IIC	-200°C
	Q	80, 100	IIC	-200°C
	E	80	IIB	-50°C
	F, F(HT), O	80, 100, 150, 250	IIB	-50°C /-60°C *)
	H, S, P	50	IIB	-50°C
	I	41, 50, 51, 80	IIB	-50°C
	Q	80, 100	IIB	-50°C /-60°C *)
	X	350	IIB	-50°C /-60°C *)
H1	F, F(HT)	80, 100, 150, 250	IIB	-200°C
	H	50	IIB	-200°C
	Q	80, 100	IIB	-200°C

\*) T<sub>med,min</sub> = -60°C only applicable for sensor of Promass F 500, Promass Q 500 and Promass X 500 versions with ISEM integrated in transmitter.

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
Utrechtseweg 310,  
6812 AR, Arnhem Netherlands

## Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
Equipment: Proline Promag 300/500, Proline Promass  
300/500, Proline Cubemass 300/500,  
Proline Prosonic Flow 300/500, Proline  
t-mass 300/500  
Applicant: Endress+Hauser Flowtec AG

---



**Note:** All sensors of Promass 300 and Promass 500 versions are available for EPL Ga/Gb except the versions "A" (size DN1), "H" (all sizes) and "I" (all sizes) which are only available for EPL Gb. For sensors with EPL Ga, Zone 0, the protection is only applicable for the interior of the measuring tube.

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
Utrechtseweg 310,  
6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
 Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

## 1.5 Parameters

### 1.5.1 Electrical Parameters

Power Supply		
Order Code e =	terminal no.	values
D <sup>1)</sup>	No. 1(L+/L), 2(L-/N)	U <sub>N</sub> = 19.2...28.8V <sub>DC</sub> U <sub>M</sub> = 250Vac
E <sup>1)</sup>	No. 1(L+/L), 2(L-/N)	U <sub>N</sub> = 85...264V <sub>AC</sub> U <sub>M</sub> = 250Vac
I <sup>2)</sup>	No. 1(L+/L), 2(L-/N)	U <sub>N</sub> = 19.2...28.8V <sub>DC</sub> / 85...264V <sub>AC</sub> U <sub>M</sub> = 250 V

1) applicable for products with approval code dd = BA, BB, BC, BD

2) applicable for products with approval code dd = BI, BJ, BM, BN

Input/Output 1																								
Order Code ff =	terminal no.	values																						
BA, BB, MA	No. 26, 27	U <sub>N</sub> = 30V <sub>DC</sub> U <sub>M</sub> = 250Vac																						
LA, GA, SA	No. 26, 27	U <sub>N</sub> = 32V <sub>DC</sub> U <sub>M</sub> = 250Vac																						
CA, CB	No. 26, 27	U <sub>i</sub> = 30V I <sub>i</sub> = 100mA P <sub>i</sub> = 1.25W L <sub>i</sub> = 0 C <sub>i</sub> = 0																						
CC, CD	No. 26, 27	<table border="0"> <tr> <td>1)</td> <td>2)</td> </tr> <tr> <td>U<sub>o</sub> = 21.8V</td> <td>U<sub>o</sub> = 21.8V</td> </tr> <tr> <td>I<sub>o</sub> = 90mA</td> <td>I<sub>o</sub> = 90mA</td> </tr> <tr> <td>P<sub>o</sub> = 491mW</td> <td>P<sub>o</sub> = 491mW</td> </tr> <tr> <td>L<sub>o</sub> = 4.1mH (IIC) / 15mH (IIB)</td> <td>L<sub>o</sub> = 9mH (IIC) / 39mH (IIB)</td> </tr> <tr> <td>C<sub>o</sub> = 160nF (IIC) / 1160nF (IIB)</td> <td>C<sub>o</sub> = 600nF (IIC) / 4000nF (IIB)</td> </tr> <tr> <td>U<sub>i</sub> = 30V</td> <td>U<sub>i</sub> = 30V</td> </tr> <tr> <td>I<sub>i</sub> = 10mA</td> <td>I<sub>i</sub> = 10mA</td> </tr> <tr> <td>P<sub>i</sub> = 0.3W</td> <td>P<sub>i</sub> = 0.3W</td> </tr> <tr> <td>C<sub>i</sub> = 6nF</td> <td>C<sub>i</sub> = 6nF</td> </tr> <tr> <td>L<sub>i</sub> = 4.1mH</td> <td>L<sub>i</sub> = 4.1mH</td> </tr> </table>	1)	2)	U <sub>o</sub> = 21.8V	U <sub>o</sub> = 21.8V	I <sub>o</sub> = 90mA	I <sub>o</sub> = 90mA	P <sub>o</sub> = 491mW	P <sub>o</sub> = 491mW	L <sub>o</sub> = 4.1mH (IIC) / 15mH (IIB)	L <sub>o</sub> = 9mH (IIC) / 39mH (IIB)	C <sub>o</sub> = 160nF (IIC) / 1160nF (IIB)	C <sub>o</sub> = 600nF (IIC) / 4000nF (IIB)	U <sub>i</sub> = 30V	U <sub>i</sub> = 30V	I <sub>i</sub> = 10mA	I <sub>i</sub> = 10mA	P <sub>i</sub> = 0.3W	P <sub>i</sub> = 0.3W	C <sub>i</sub> = 6nF	C <sub>i</sub> = 6nF	L <sub>i</sub> = 4.1mH	L <sub>i</sub> = 4.1mH
1)	2)																							
U <sub>o</sub> = 21.8V	U <sub>o</sub> = 21.8V																							
I <sub>o</sub> = 90mA	I <sub>o</sub> = 90mA																							
P <sub>o</sub> = 491mW	P <sub>o</sub> = 491mW																							
L <sub>o</sub> = 4.1mH (IIC) / 15mH (IIB)	L <sub>o</sub> = 9mH (IIC) / 39mH (IIB)																							
C <sub>o</sub> = 160nF (IIC) / 1160nF (IIB)	C <sub>o</sub> = 600nF (IIC) / 4000nF (IIB)																							
U <sub>i</sub> = 30V	U <sub>i</sub> = 30V																							
I <sub>i</sub> = 10mA	I <sub>i</sub> = 10mA																							
P <sub>i</sub> = 0.3W	P <sub>i</sub> = 0.3W																							
C <sub>i</sub> = 6nF	C <sub>i</sub> = 6nF																							
L <sub>i</sub> = 4.1mH	L <sub>i</sub> = 4.1mH																							
HA, TA	No. 26, 27	<table border="0"> <tr> <td>1)</td> <td>2)</td> </tr> <tr> <td><u>Profibus PA (Fisco Field Device) / Foundation Fieldbus</u></td> <td><u>Profibus PA (Fisco Field Device) / Foundation Fieldbus</u></td> </tr> <tr> <td>U<sub>i</sub> = 30V</td> <td>U<sub>i</sub> = 32V</td> </tr> <tr> <td>I<sub>i</sub> = 570mA</td> <td>I<sub>i</sub> = 570mA</td> </tr> <tr> <td>P<sub>i</sub> = 8.5W</td> <td>P<sub>i</sub> = 8.5W</td> </tr> <tr> <td>L<sub>i</sub> = 10μH</td> <td>L<sub>i</sub> = 10μH</td> </tr> <tr> <td>C<sub>i</sub> = 5nF</td> <td>C<sub>i</sub> = 5nF</td> </tr> </table>	1)	2)	<u>Profibus PA (Fisco Field Device) / Foundation Fieldbus</u>	<u>Profibus PA (Fisco Field Device) / Foundation Fieldbus</u>	U <sub>i</sub> = 30V	U <sub>i</sub> = 32V	I <sub>i</sub> = 570mA	I <sub>i</sub> = 570mA	P <sub>i</sub> = 8.5W	P <sub>i</sub> = 8.5W	L <sub>i</sub> = 10μH	L <sub>i</sub> = 10μH	C <sub>i</sub> = 5nF	C <sub>i</sub> = 5nF								
1)	2)																							
<u>Profibus PA (Fisco Field Device) / Foundation Fieldbus</u>	<u>Profibus PA (Fisco Field Device) / Foundation Fieldbus</u>																							
U <sub>i</sub> = 30V	U <sub>i</sub> = 32V																							
I <sub>i</sub> = 570mA	I <sub>i</sub> = 570mA																							
P <sub>i</sub> = 8.5W	P <sub>i</sub> = 8.5W																							
L <sub>i</sub> = 10μH	L <sub>i</sub> = 10μH																							
C <sub>i</sub> = 5nF	C <sub>i</sub> = 5nF																							
NA, RA	IO1 / RJ45	U <sub>N</sub> = 30V <sub>DC</sub> U <sub>M</sub> = 250Vac																						

1) applicable for products with approval code dd = BA, BB, BC, BD

2) applicable for products with approval code dd = BM, BN

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands



# Certificate Annexe

Certificate Number: Sira 16ATEX2219X

Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

Input/Output 2		
Order Code g =	terminal no.	values
C, G, K	No. 24, 25	U <sub>i</sub> = 30V I <sub>i</sub> = 100mA P <sub>i</sub> = 1.25W L <sub>i</sub> = 0 C <sub>i</sub> = 0
B, D, E, F, I, J, L	No. 24, 25	U <sub>N</sub> = 30V <sub>DC</sub> U <sub>M</sub> = 250V <sub>ac</sub>
H	No. 24, 25	U <sub>N</sub> = 30V <sub>DC</sub> I <sub>N</sub> = 100mA <sub>DC</sub> / 500mA <sub>AC</sub> U <sub>M</sub> = 250V <sub>ac</sub>
Input/Output 3		
Order Code h =	terminal no.	values
C, G, K	No. 22, 23	U <sub>i</sub> = 30V I <sub>i</sub> = 100mA P <sub>i</sub> = 1.25W L <sub>i</sub> = 0 C <sub>i</sub> = 0
B, D, E, F, I, J, L	No. 22, 23	U <sub>N</sub> = 30V <sub>DC</sub> U <sub>M</sub> = 250V <sub>ac</sub>
H	No. 22, 23	U <sub>N</sub> = 30V <sub>DC</sub> I <sub>N</sub> = 100mA <sub>DC</sub> / 500mA <sub>AC</sub> U <sub>M</sub> = 250V <sub>ac</sub>
Input/Output 4		
Order Code i =	terminal no.	values
C, G, K	No. 20, 21	U <sub>i</sub> = 30V I <sub>i</sub> = 100mA P <sub>i</sub> = 1.25W L <sub>i</sub> = 0 C <sub>i</sub> = 0
B, D, E, F, I, J, L	No. 20, 21	U <sub>N</sub> = 30V <sub>DC</sub> U <sub>M</sub> = 250V <sub>ac</sub>
H	No. 20, 21	U <sub>N</sub> = 30V <sub>DC</sub> I <sub>N</sub> = 100mA <sub>DC</sub> / 500mA <sub>AC</sub> U <sub>M</sub> = 250V <sub>ac</sub>
Service Interface		
Order Code dd =	terminal no.	values
BA, BB, BC, BD	Service Interface	Service Interface shall only be installed in areas which are known to be non hazardous
not for: BA, BB, BC, BD	Service Interface	U <sub>N</sub> = 3.3V

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
Utrechtseweg 310,  
6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
 Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

Antenna bushing		
Order Code dd =	terminal no.	values
BA, BB, BI, BJ, BM, BN	N connector	See conditions of safe use

Display remote		
Order Code dd =	terminal no.	values
BA, BB, BC, BD	No. 81, 82, 83, 84	U <sub>o</sub> = 3.9V I <sub>o</sub> = 1.5A (spark) 200mA (power) P <sub>o</sub> = 600mW R <sub>i</sub> = 2.6Ω C <sub>o</sub> = 670μF L <sub>o</sub> = 0
not for: BA, BB, BC, BD	No. 81, 82, 83, 84	U <sub>N</sub> = 3.3V I <sub>N</sub> = 150mA

For Transmitter with approval code dd = BA, BB, BC, BD connected to the Remote Display of Endress+Hauser, Type DKX001 or ODKX001, the cable parameter with ration L/R = ≤ 0.024 mH/Ω applies.

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500  
Applicant: Endress+Hauser Flowtec AG



## Proline Promass and Proline Cubemass Remote Transmitter and Remote Sensor:

8\*\*\*\*\*-... and O8\*\*\*\*\*-... with order code dd = BA, BB, BC, BD in combination with k = B:

Transmitter:

Terminals 41, 42

-> exciter coil circuit:

$U_o = 15V, I_o = 129mA, P_o = 484mW$

(sensor group A1/C1/E1)

$U_o = 15V, I_o = 46mA, P_o = 173mW$

(sensor group B1/D1/H1)

Terminals 9, 10, 11, 12, X3, X4

-> temperature circuit:

$U_o = 15V, I_o = 18.2mA, P_o = 68.3mW$

Terminals 4, 5, 6, 7

-> sensor coil circuit:

$U_o = 15V, I_o = 15.2mA, P_o = 57mW$

Sensor:

Terminals 41, 42

-> exciter coil circuit:

$U_i = 15V, I_i = 132mA, P_i = 494mW$

(sensor group A1/C1/E1)

$U_i = 15V, I_i = 48mA, P_i = 180mW$

(sensor group B1/D1/H1)

Terminals 9, 10, 11, 12, X3, X4

-> temperature circuit:

$U_i = 15V, I_i = 60.6mA, P_i = 227.3mW$

Terminals 4, 5, 6, 7

-> sensor coil circuit:

$U_i = 15V, I_i = 15.2mA, P_i = 57mW$

For interconnection using a cable with a maximum length of 120m is allowed when using a cable which has the following parameters:

Cable inductance  $\leq 0.5$  mH/km

Cable capacitance  $\leq 0.5$   $\mu$ F/km

8\*\*\*\*\*-... and O8\*\*\*\*\*-... with order code dd = BI, BJ, BM, BN in combination with k = A:

Transmitter:

terminals 61, 62, 63, 64 ->

$U_o = 13.8V, I_o = 1.156A, P_o = 3.3W$

Sensor:

terminals 61, 62, 63, 64 ->

$U_i = 14V, I_i = 1.2A, P_i = 3.4W$

For interconnection of transmitter to sensor any cable may be used with the following requirements:

- $L/R \leq 0.0089$  mH/ $\Omega$  and  $C_{cable} \leq 760nF$  for group IIC,  $L/R \leq 0.0356$  mH/ $\Omega$  and  $C_{cable} \leq 4.2\mu F$  for group IIB

Or

- $L_{cable} \leq 26\mu H$  and  $C_{cable} \leq 760nF$  for group IIC,  $L_{cable} \leq 104\mu H$  and  $C_{cable} \leq 4.2\mu F$  for group IIB

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
Utrechtseweg 310,  
6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X

Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500

Applicant: Endress+Hauser Flowtec AG



## 1.5.2 Thermal Parameters (Zone 1)

**Proline Promass A/E/H/I/O/P/Q/S/X 300**      **Proline Cubemass C 300**      **Proline Promass C 300**

Notes: Pages 1 and 2 apply to versions with extended order code covering: 8798\*\*\*-dd... 8938\*\*\*-dd... 08798\*\*\*-dd... 08938\*\*\*-dd...

with approval option CCSAS / CSA: dd = CC, CD, CE, CI, CZ, C3, C4      CCASAS / CSA: dd = CC, CD, CE, CI, CZ, C3, C4      ICCEX / ATEX: dd = BA, BB, BC, BD

Sensor	Size / DN	T <sub>max</sub> (°C)									
		T1	T2	T3	T4	T5	T6	T7	T8	T9	T10
A	01...04	150	150	150	150	150	150	150	150	150	150
	05...06	150	150	150	150	150	150	150	150	150	150
	08...50	150	150	150	150	150	150	150	150	150	150
C	01...06	150	150	150	150	150	150	150	150	150	150
	08...50	150	150	150	150	150	150	150	150	150	150
E	01...04	150	150	150	150	150	150	150	150	150	150
	05...06	150	150	150	150	150	150	150	150	150	150
	08...50	150	150	150	150	150	150	150	150	150	150
F	01...04	150	150	150	150	150	150	150	150	150	150
	05...06	150	150	150	150	150	150	150	150	150	150
	08...50	150	150	150	150	150	150	150	150	150	150
H	01...04	150	150	150	150	150	150	150	150	150	150
	05...06	150	150	150	150	150	150	150	150	150	150
	08...50	150	150	150	150	150	150	150	150	150	150
I	01...04	150	150	150	150	150	150	150	150	150	150
	05...06	150	150	150	150	150	150	150	150	150	150
	08...50	150	150	150	150	150	150	150	150	150	150
M	01...04	150	150	150	150	150	150	150	150	150	150
	05...06	150	150	150	150	150	150	150	150	150	150
	08...50	150	150	150	150	150	150	150	150	150	150
P	01...04	150	150	150	150	150	150	150	150	150	150
	05...06	150	150	150	150	150	150	150	150	150	150
	08...50	150	150	150	150	150	150	150	150	150	150
Q	01...04	150	150	150	150	150	150	150	150	150	150
	05...06	150	150	150	150	150	150	150	150	150	150
	08...50	150	150	150	150	150	150	150	150	150	150
S, P	01...04	150	150	150	150	150	150	150	150	150	150
	05...06	150	150	150	150	150	150	150	150	150	150
	08...50	150	150	150	150	150	150	150	150	150	150

Sensor	Size / DN	T <sub>max</sub> (°C)									
		T1	T2	T3	T4	T5	T6	T7	T8	T9	T10
Proline A	8...15	150	150	150	150	150	150	150	150	150	150
	15...25	150	150	150	150	150	150	150	150	150	150
Proline C	40...60	150	150	150	150	150	150	150	150	150	150
	80...100	150	150	150	150	150	150	150	150	150	150
Proline E	8...15	150	150	150	150	150	150	150	150	150	150
	15...25	150	150	150	150	150	150	150	150	150	150
Proline F	40...60	150	150	150	150	150	150	150	150	150	150
	80...100	150	150	150	150	150	150	150	150	150	150
Proline H	8...15	150	150	150	150	150	150	150	150	150	150
	15...25	150	150	150	150	150	150	150	150	150	150
Proline I	40...60	150	150	150	150	150	150	150	150	150	150
	80...100	150	150	150	150	150	150	150	150	150	150
Proline M	8...15	150	150	150	150	150	150	150	150	150	150
	15...25	150	150	150	150	150	150	150	150	150	150
Proline P	40...60	150	150	150	150	150	150	150	150	150	150
	80...100	150	150	150	150	150	150	150	150	150	150
Proline Q	8...15	150	150	150	150	150	150	150	150	150	150
	15...25	150	150	150	150	150	150	150	150	150	150
Proline S, P	40...60	150	150	150	150	150	150	150	150	150	150
	80...100	150	150	150	150	150	150	150	150	150	150

(1) T1 (min) = 40°C; T2 (min) = 50°C; T3 (min) = 50°C; T4 (min) = 50°C; T5 (min) = 50°C; T6 (min) = 50°C; T7 (min) = 50°C; T8 (min) = 50°C; T9 (min) = 50°C; T10 (min) = 50°C  
 (2) values in brackets are applicable for installation where the transmitter is not installed above the medium  
 (3) for applicable version with maximum medium temperature and minimum medium temperature

Material	A	B	C	D	E	F	G	H	I	J	K
Temperature	100...200 / °C	100...200 / °C	100...200 / °C	100...200 / °C	100...200 / °C	100...200 / °C	100...200 / °C	100...200 / °C	100...200 / °C	100...200 / °C	100...200 / °C
Control Drawing	IECEX, ATEX, CSA, CCSAS										
Zone 1, Zone 21, CII Div. 1, CIII, CIII, CII Zone 1											
Thermal Parameter											
Proline Promass 300/500, Proline Cubemass 300/500											
Flowtec AG, Kappelerstrasse 7, CH-4153 Birmensdorf, Switzerland											

FES0263E	1/6	
----------	-----	--

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V. Utrechtseweg 310, 6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X

Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

Temperature table for versions with sensor insulated (for insulation refer to manual of Endress+Hauser Flowtec)												
Sensor	Size/DN	T <sub>min</sub> °C	T <sub>max</sub> °C	Temperatures [°C]								
				T <sub>6</sub> (85°C)	T <sub>5</sub> (100°C)	T <sub>4</sub> (130°C)	T <sub>3</sub> (200°C)	T <sub>2</sub> (300°C)	T <sub>1</sub> (450°C)			
Promag	01...04	-50	205	50	90	95	130	150	150	205	205	205
				55	95	95	130	150	150	205	205	205
A	01...06	-50	205	50	95	95	130	150	150	205	205	205
				55	95	95	130	150	150	205	205	205
C	08...50	-50	205	25	90	100	130	130	150	205	205	205
				25	90	100	130	130	150	205	205	205
E	80	-50	205	25	90	75	110	110	170	205	205	205
				25	90	75	110	110	170	205	205	205
Promass	09...15	-50	150	50	50	95	110	130	150	150	150	150
				50	50	95	110	130	150	150	150	150
F	25...50	-50/2	240	50	50	95	130	160	240	240	240	240
		-200		55	55	95	130	160	240	240	240	240
	80...250	-50/2	240	50	50	95	130	160	240	240	240	240
		-200		55	55	95	130	160	240	240	240	240
	15...25	-50/2	350	50	45	95	130	175	275	350	350	350
		-200		60	45	95	130	175	275	350	350	350
	25...50	-50	150	50	90	95	130	150	150	150	150	150
				60	90	95	130	150	150	150	150	150
Promag	B	-30/2	205	50	50	95	110	130	150	150	150	150
		-200		55	55	95	110	130	150	150	150	150
H	15...50	-30/2	205	50	50	95	110	130	150	150	150	150
		-200		55	55	95	110	130	150	150	150	150
Promag	B	-50	150	45	45	95	130	150	150	150	150	150
				50	45	95	130	150	150	150	150	150
S.P.		-50	205	45	45	95	130	150	150	150	150	150
				50	45	95	130	150	150	150	150	150
	15...50	-50	150	60	60	95	110	110	150	150	150	150
				60	60	95	110	110	150	150	150	150
Promag	15FB 25	-50	205	60	60	95	110	110	150	150	150	150
				60	60	95	110	110	150	150	150	150
	25FB 40	-50	150	50	50	95	120	150	150	150	150	150
				60	50	95	120	150	150	150	150	150
	40FB 50	-50	150	60	60	95	120	150	150	150	150	150
				60	60	95	120	150	150	150	150	150
	50FB 80	-50	150	60	60	95	120	150	150	150	150	150
				60	60	95	120	150	150	150	150	150

Continued of previous page

**Temperature table for versions with sensor insulated (for insulation refer to manual of Endress+Hauser Flowtec)**

Sensor	Size/DN	T <sub>min</sub> °C	T <sub>max</sub> °C	Temperatures [°C]								
				T <sub>6</sub> (85°C)	T <sub>5</sub> (100°C)	T <sub>4</sub> (130°C)	T <sub>3</sub> (200°C)	T <sub>2</sub> (300°C)	T <sub>1</sub> (450°C)			
Promag	80...250	-50	205	50	90	75	110	110	170	205	205	
				55	90	75	110	110	170	205	205	
Promass	300	-50	205	50	90	90	120	170	205	205	205	
				55	90	90	120	170	205	205	205	
C	25...100	-50/2	240	50	90	75	110	140	240	240	240	
		-200		55	90	75	110	140	240	240	240	

Notes: (1) T<sub>1</sub> min = 40°C, 50°C respectively (see manual)  
 (2) The sensor models are applicable for installation when the sensor is not installed alone  
 (3) for applicable version with maximum medium temperature and minimum medium temperature see manualetts

**Temperature table for versions with sensor insulated (for insulation refer to manual of Endress+Hauser Flowtec)**

Sensor	Size/DN	T <sub>min</sub> to be measured at reference point at								
		T <sub>6</sub> (85°C)	T <sub>5</sub> (100°C)	T <sub>4</sub> (130°C)	T <sub>3</sub> (200°C)	T <sub>2</sub> (300°C)	T <sub>1</sub> (450°C)			
S.P.		16	15	14	13	12	11			
		59	72	75	78	77	77			

Notes: (1) for tube use temperature shall not exceed all of the following  
 - temperature table for versions with sensor not insulated (refer to table above)  
 - temperature at reference point (as listed in the table)  
 - T<sub>1</sub> min = 40°C, 50°C respectively (see manual)  
 - for maximum medium temperature and minimum medium temperature see manualetts  
 (2) location of reference point

Reference point

Approved for installation:  
 1. 10/03/2016 / B1  
 2. 24/10/2016 / B1  
 3. 05/02/2017 / B1  
 4. 04/07/2018 / B1  
 5. 22/10/2019 / B1  
 Other reserved reservations:  
 - none  
 - no other reserved reservations

Control Drawing: IECEx ATEX, CSA, cCSAus  
 Zone 1, Zone 21, CII Div. 1, CII, CII.I, CII.III, CII.Zone 1  
 Thermal Parameter  
 Proline Promag 300/500, Proline Cubemass 300/500

**ES** Proline AG, Kohnstrasse 7, CH-4153 Raminen, BL 1, Postfach  
**FES0263E** 2/6

This certificate and its schedules may only be reproduced in its entirety and without change  
 CSA Group Netherlands B.V. Utrechtseweg 310, 6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X

Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500

Applicant: Endress+Hauser Flowtec AG



**Proline Promass A/E/H/M/O/P/Q/S/X 500**      **Proline Cubemass C 500**

**Notes:** This page applies to versions with extended order code covering: 85\*...-dd\*...E... cCSA/S / CSA; dd = C, CD, CE, C1, C2, C3, C4; IECEX / ATEX; dd = BA, BB, BC, BD

**Temperature table for versions with sensor not insulated**

Version	Size / DN	Min T <sub>meas</sub> (T <sub>ref</sub> )	Max T <sub>meas</sub> (T <sub>ref</sub> )	T <sub>meas</sub> (T <sub>ref</sub> )	T <sub>amb</sub> (T <sub>ref</sub> )	T <sub>15</sub> (100°C) (130°C)	T <sub>25</sub> (150°C) (200°C)	T <sub>30</sub> (200°C) (250°C)	T <sub>35</sub> (250°C) (300°C)	T <sub>40</sub> (300°C) (350°C)	T <sub>45</sub> (350°C) (400°C)
Promass A (Type 8A/5C)	01 ... 04	-50	205	60	60	95	130	150	205	205	205
	01 ... 04	-50	205	60	60	95	130	150	205	205	205
	01 ... 04	-50	205	60	60	95	130	150	205	205	205
Cubemass C	01 ... 06	-50	205	50	50	95	130	150	205	205	205
	08 ... 50	-50	205	50	50	100	130	150	205	205	205
	08 ... 50	-50	205	50	50	100	130	150	205	205	205
	08 ... 15	-50	205	60	60	75	110	170	205	205	205
	08 ... 15	-50	205	55	55	95	130	150	205	205	205
	08 ... 15	-50	205	60	60	95	130	150	205	205	205
	08 ... 15	-50	205	60	60	95	130	150	205	205	205
	08 ... 15	-50	205	60	60	95	130	150	205	205	205
	08 ... 15	-50	205	60	60	95	130	150	205	205	205
	08 ... 15	-50	205	60	60	95	130	150	205	205	205
	08 ... 15	-50	205	60	60	95	130	150	205	205	205
	08 ... 15	-50	205	60	60	95	130	150	205	205	205
Promag S, P	01 ... 04	-50	205	60	60	95	130	150	205	205	205
	01 ... 04	-50	205	60	60	95	130	150	205	205	205
	01 ... 04	-50	205	60	60	95	130	150	205	205	205
	01 ... 04	-50	205	60	60	95	130	150	205	205	205
	01 ... 04	-50	205	60	60	95	130	150	205	205	205

**Transmitter for all versions:**  
 T<sub>meas</sub> 15 (100°C)  
 T<sub>amb</sub> (T<sub>ref</sub>) 60  
 Model: (1) T<sub>amb</sub> = -50°C (for insulation see name label)

Control Drawing: IECEX, ATEX, CSA, cCSA/S

Zone 1, Zone 21, CII Div. 1, C.III, C.III, C.III, C.III Zone 1

Theoretical Parameter

Proline Promass 300/500, Proline Cubemass 300/500

Approved for:	10/03/2008	IE	Approved for:	10/03/2008	BH
Checked by:	08/03/2017	H	Checked by:	08/03/2017	H
Drawn by:	04/07/2018	J	Drawn by:	04/07/2018	J

Expire date:	
Printed:	10/03/2008
Printed by:	BH
Expiry date:	22/10/2009
Expire by:	BH

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands

FES0263E 3/6

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X

Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

Continued of previous page

Sensor	Size / DN	T <sub>max</sub>		T <sub>max</sub> class [°C]																
		min	max	T <sub>0</sub>	T <sub>1</sub>	T <sub>2</sub>	T <sub>3</sub>	T <sub>4</sub>	T <sub>5</sub>	T <sub>6</sub>	T <sub>7</sub>	T <sub>8</sub>	T <sub>9</sub>	T <sub>10</sub>	T <sub>11</sub>					
Promag A (0m...0.6m)	01 ... 04	-50	205	50	60	70	80	90	95	100	110	120	130	140	150	160	170	180	190	205
	05 ... 06	-50	205	50	60	70	80	90	95	100	110	120	130	140	150	160	170	180	190	205
Promag C (0m...0.6m)	01 ... 04	-50	205	50	60	70	80	90	95	100	110	120	130	140	150	160	170	180	190	205
	05 ... 06	-50	205	50	60	70	80	90	95	100	110	120	130	140	150	160	170	180	190	205
Promag E	08 ... 15	-50 / -60	205 / 240	50 / 60	60	70	80	90	95	100	110	120	130	140	150	160	170	180	190	205 / 240
	16 ... 25	-50 / -60	205 / 240	50 / 60	60	70	80	90	95	100	110	120	130	140	150	160	170	180	190	205 / 240
Promag F	26 ... 40	-50 / -60	205 / 240	50 / 60	60	70	80	90	95	100	110	120	130	140	150	160	170	180	190	205 / 240
	41 ... 50	-50 / -60	205 / 240	50 / 60	60	70	80	90	95	100	110	120	130	140	150	160	170	180	190	205 / 240
Promag S, P	8 ... 15	-50 / -60	205 / 240	50 / 60	60	70	80	90	95	100	110	120	130	140	150	160	170	180	190	205 / 240
	16 ... 25	-50 / -60	205 / 240	50 / 60	60	70	80	90	95	100	110	120	130	140	150	160	170	180	190	205 / 240
Promag I	26 ... 40	-50 / -60	205 / 240	50 / 60	60	70	80	90	95	100	110	120	130	140	150	160	170	180	190	205 / 240
	41 ... 50	-50 / -60	205 / 240	50 / 60	60	70	80	90	95	100	110	120	130	140	150	160	170	180	190	205 / 240
Promag O	80 ... 250	-50	205	60	70	80	90	95	100	110	120	130	140	150	160	170	180	190	205	
		-50	205	60	70	80	90	95	100	110	120	130	140	150	160	170	180	190	205	


Sensor	Size / DN	T <sub>max</sub>		T <sub>max</sub> class [°C]															
		min	max	T <sub>0</sub>	T <sub>1</sub>	T <sub>2</sub>	T <sub>3</sub>	T <sub>4</sub>	T <sub>5</sub>	T <sub>6</sub>	T <sub>7</sub>	T <sub>8</sub>	T <sub>9</sub>	T <sub>10</sub>	T <sub>11</sub>				
Promag X	350	-50 / -60	205 / 240	60	70	80	90	95	100	110	120	130	140	150	160	170	180	190	205
	25 ... 100	-50 / -60	205 / 240	60	70	80	90	95	100	110	120	130	140	150	160	170	180	190	205
Promag Q	25 ... 100	-50 / -60	205 / 240	60	70	80	90	95	100	110	120	130	140	150	160	170	180	190	205
	125 ... 200	-50 / -60	205 / 240	60	70	80	90	95	100	110	120	130	140	150	160	170	180	190	205

**Temperature table for versions with sensor insulated (for insulation refer to manual of Endress+Hauser Flowtec)**

Sensor	Size / DN	T <sub>max</sub>		T <sub>max</sub> class [°C]															
		min	max	T <sub>0</sub>	T <sub>1</sub>	T <sub>2</sub>	T <sub>3</sub>	T <sub>4</sub>	T <sub>5</sub>	T <sub>6</sub>	T <sub>7</sub>	T <sub>8</sub>	T <sub>9</sub>	T <sub>10</sub>	T <sub>11</sub>				
Promag I	80 ... 250	-50	205	60	70	80	90	95	100	110	120	130	140	150	160	170	180	190	205
		-50	205	60	70	80	90	95	100	110	120	130	140	150	160	170	180	190	205

**Temperature table for versions with sensor insulated (for insulation refer to manual of Endress+Hauser Flowtec)**

Note: (1) For safe use temperature shall not exceed at the following  
 - temperature scale for versions with sensor not insulated (refer to table above)  
 - Temperature for use point (reference temperature)  
 - For maximum/medium temperature and minimum/medium temperature see manual  
 (2) Location of reference point



(reference point)

**Transmitter for all versions:**

T <sub>max</sub> 18 (085°C)		
T <sub>max</sub> 15 (107°C)		
T <sub>max</sub> 60		

Note: (1) 12 m/s - 40°C for insulation and normal use

**Control Drawing IECEx, ATEX, CSA, CCSA/US**

Version	Part	Material	Material description	Material specification
E	01	06	Case	Aluminum die cast
F	02	03	Case	Aluminum die cast
G	04	05	Case	Aluminum die cast
H	06	07	Case	Aluminum die cast
I	08	09	Case	Aluminum die cast
J	10	11	Case	Aluminum die cast
K	12	13	Case	Aluminum die cast

**Thermal Parameter**

Zone 1, Zone 21, CII Div. 1, CIII, CIIII, CIIII, CIIIII

Proline Promag 300/500, Proline Cubemass 300/500

**EMC** Power AG, Kaldenburger 7, CH-4153 Reinach BL 1, Postfach

<b>FES0263E</b>	<b>4/6</b>
-----------------	------------

This certificate and its schedules may only be reproduced in its entirety and without change. CSA Group Netherlands B.V. Utrechtseweg 310, 6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
 Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

Temperature table for versions with sensor not insulated																								
Sensor	Size / DN	Temp. [°C]		T <sub>amb</sub> [°C]																				
		min	max	T6	T5	T4	T3	T2	T1	T0	T-1	T-2	T-3											
Promass A (type 8A/50)	01 ... 04	-50	205	35	60	85	110	135	160	185	210	235	260	285	310	335	360	385	410	435	460	485	510	
				35	60	85	110	135	160	185	210	235	260	285	310	335	360	385	410	435	460	485	510	535
Promass A (type 8A/50)	01 ... 04	-50	205	35	60	85	110	135	160	185	210	235	260	285	310	335	360	385	410	435	460	485	510	535
				35	60	85	110	135	160	185	210	235	260	285	310	335	360	385	410	435	460	485	510	535
Cubemass C	01 ... 06	-50	205	35	60	85	110	135	160	185	210	235	260	285	310	335	360	385	410	435	460	485	510	535
				35	60	85	110	135	160	185	210	235	260	285	310	335	360	385	410	435	460	485	510	535
Promass E	08 ... 50	-50	205	35	60	85	110	135	160	185	210	235	260	285	310	335	360	385	410	435	460	485	510	535
				35	60	85	110	135	160	185	210	235	260	285	310	335	360	385	410	435	460	485	510	535
Promass F	08 ... 50	-50	205	35	60	85	110	135	160	185	210	235	260	285	310	335	360	385	410	435	460	485	510	535
				35	60	85	110	135	160	185	210	235	260	285	310	335	360	385	410	435	460	485	510	535
Promass H	15 ... 50	-50 / -200	205	35	60	85	110	135	160	185	210	235	260	285	310	335	360	385	410	435	460	485	510	535
				35	60	85	110	135	160	185	210	235	260	285	310	335	360	385	410	435	460	485	510	535
Promass S/P	15 ... 50	-50	205	35	60	85	110	135	160	185	210	235	260	285	310	335	360	385	410	435	460	485	510	535
				35	60	85	110	135	160	185	210	235	260	285	310	335	360	385	410	435	460	485	510	535

Notes: This page applies to versions with extended order code covering: 8\*5...-dd...A... with approval option IECEx / ATEX. 8\*5...-dd...A... with approval option IECEx / ATEX. 8\*5...-dd...A... with approval option IECEx / ATEX.

Transmitter for all versions: Type of enclosure: Ordinary location (°C) 60, T6 (85°C), T5 (100°C), T4 (135°C), T3 (170°C), T2 (205°C), T1 (240°C), T0 (280°C), T-1 (320°C), T-2 (360°C), T-3 (400°C). Material: Aluminum enclosure. Note: (1) Aluminum enclosure T<sub>amb</sub> = -50°C (for installation see item 6.9.9.9). Note: (2) Values in brackets are applicable for installation where the transmitter is not insulated above for applicable version with maximum medium temperature and minimum medium temperature.

Control Drawing IECEx, ATEX, CSA, cCSAus. Zone 1, Zone 21, CII, Div. 1, CII, CIII, CII, Zone 1. Thermal Parameter: Proline Promass 300/500, Proline Cubemass 300/500. Endress+Hauser Flowtec AG, Kienaststrasse 7, CH-4113 Reinach, BL, Pakistan. FES0263E 5/6

CSA Group Netherlands B.V. Utrechtseweg 310, 6812 AR, Arnhem Netherlands



# Certificate Annexe

Certificate Number: Sira 16ATEX2219X

Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

Sensor	Size/DN	T <sub>amb</sub>		T <sub>amb</sub>		T <sub>amb</sub>		T <sub>amb</sub>		T <sub>amb</sub>		T <sub>amb</sub>		T <sub>amb</sub>	
		min	max	min	max	min	max	min	max	min	max	min	max	min	max
Promass	01 ... 04	-50	205	40	205	40	205	40	205	40	205	40	205	40	205
Promag	01 ... 04	-50	205	40	205	40	205	40	205	40	205	40	205	40	205
Cubemass	01 ... 08	-50	205	40	205	40	205	40	205	40	205	40	205	40	205
Promass	08 ... 50	-50	205	40	205	40	205	40	205	40	205	40	205	40	205
Promag	08 ... 50	-50	205	40	205	40	205	40	205	40	205	40	205	40	205
Promass	50 ... 250	-50	205	40	205	40	205	40	205	40	205	40	205	40	205
Promag	50 ... 250	-50	205	40	205	40	205	40	205	40	205	40	205	40	205
Promass	8 ... 90	-50	205	40	205	40	205	40	205	40	205	40	205	40	205
Promag	8 ... 90	-50	205	40	205	40	205	40	205	40	205	40	205	40	205
Promass	90 ... 250	-50	205	40	205	40	205	40	205	40	205	40	205	40	205
Promag	90 ... 250	-50	205	40	205	40	205	40	205	40	205	40	205	40	205
Promass	350	-50	205	40	205	40	205	40	205	40	205	40	205	40	205
Promag	350	-50	205	40	205	40	205	40	205	40	205	40	205	40	205

Sensor	Size/DN	T <sub>amb</sub>		T <sub>amb</sub>		T <sub>amb</sub>		T <sub>amb</sub>		T <sub>amb</sub>		T <sub>amb</sub>		T <sub>amb</sub>	
		min	max	min	max	min	max	min	max	min	max	min	max	min	max
Promass	25 ... 100	-50	240	40	240	40	240	40	240	40	240	40	240	40	240
Promag	25 ... 100	-50	240	40	240	40	240	40	240	40	240	40	240	40	240
Promass	100 ... 250	-50	240	40	240	40	240	40	240	40	240	40	240	40	240
Promag	100 ... 250	-50	240	40	240	40	240	40	240	40	240	40	240	40	240

**Temperature table for versions with sensor insulated**

T<sub>amb</sub> to be measured at reference point at

Sensor	Size/DN	T <sub>amb</sub>	T <sub>amb</sub>	T <sub>amb</sub>	T <sub>amb</sub>	T <sub>amb</sub>	T <sub>amb</sub>
all	all	78 (80°C)	15 (100°C)	54 (138°C)	82 (200°C)	85 (200°C)	85 (450°C)
		45	64	82	82	85	85

Notes: (1) for safe use temperatures shall not exceed all of the following:  
 - sensor case temperature shall not exceed 130°C (266°F)  
 - sensor case at reference point shall not exceed 150°C (302°F)  
 - ambient temperature shall not exceed 130°C (266°F)  
 - ambient temperature at reference point shall not exceed 150°C (302°F)  
 (2) location of reference point

Type of enclosure	Material	T <sub>amb</sub>	T <sub>amb</sub>	T <sub>amb</sub>	T <sub>amb</sub>
Control enclosure	aluminum	78 (80°C)	15 (100°C)	54 (138°C)	85 (200°C)
	plastic	60	60	45	60

Material	Temperature	Material	Temperature
aluminum enclosure	T <sub>amb</sub> = 50°C (for insulation see table above)	aluminum enclosure	T <sub>amb</sub> = 40°C
plastic enclosure	T <sub>amb</sub> = 40°C	plastic enclosure	T <sub>amb</sub> = 40°C

Material	Temperature	Material	Temperature
aluminum enclosure	T <sub>amb</sub> = 50°C (for insulation see table above)	aluminum enclosure	T <sub>amb</sub> = 40°C
plastic enclosure	T <sub>amb</sub> = 40°C	plastic enclosure	T <sub>amb</sub> = 40°C

Material	Temperature	Material	Temperature
aluminum enclosure	T <sub>amb</sub> = 50°C (for insulation see table above)	aluminum enclosure	T <sub>amb</sub> = 40°C
plastic enclosure	T <sub>amb</sub> = 40°C	plastic enclosure	T <sub>amb</sub> = 40°C

Material	Temperature	Material	Temperature
aluminum enclosure	T <sub>amb</sub> = 50°C (for insulation see table above)	aluminum enclosure	T <sub>amb</sub> = 40°C
plastic enclosure	T <sub>amb</sub> = 40°C	plastic enclosure	T <sub>amb</sub> = 40°C

Material	Temperature	Material	Temperature
aluminum enclosure	T <sub>amb</sub> = 50°C (for insulation see table above)	aluminum enclosure	T <sub>amb</sub> = 40°C
plastic enclosure	T <sub>amb</sub> = 40°C	plastic enclosure	T <sub>amb</sub> = 40°C

Material	Temperature	Material	Temperature
aluminum enclosure	T <sub>amb</sub> = 50°C (for insulation see table above)	aluminum enclosure	T <sub>amb</sub> = 40°C
plastic enclosure	T <sub>amb</sub> = 40°C	plastic enclosure	T <sub>amb</sub> = 40°C

Material	Temperature	Material	Temperature
aluminum enclosure	T <sub>amb</sub> = 50°C (for insulation see table above)	aluminum enclosure	T <sub>amb</sub> = 40°C
plastic enclosure	T <sub>amb</sub> = 40°C	plastic enclosure	T <sub>amb</sub> = 40°C

Material	Temperature	Material	Temperature
aluminum enclosure	T <sub>amb</sub> = 50°C (for insulation see table above)	aluminum enclosure	T <sub>amb</sub> = 40°C
plastic enclosure	T <sub>amb</sub> = 40°C	plastic enclosure	T <sub>amb</sub> = 40°C

Material	Temperature	Material	Temperature
aluminum enclosure	T <sub>amb</sub> = 50°C (for insulation see table above)	aluminum enclosure	T <sub>amb</sub> = 40°C
plastic enclosure	T <sub>amb</sub> = 40°C	plastic enclosure	T <sub>amb</sub> = 40°C

Material	Temperature	Material	Temperature
aluminum enclosure	T <sub>amb</sub> = 50°C (for insulation see table above)	aluminum enclosure	T <sub>amb</sub> = 40°C
plastic enclosure	T <sub>amb</sub> = 40°C	plastic enclosure	T <sub>amb</sub> = 40°C

Material	Temperature	Material	Temperature
aluminum enclosure	T <sub>amb</sub> = 50°C (for insulation see table above)	aluminum enclosure	T <sub>amb</sub> = 40°C
plastic enclosure	T <sub>amb</sub> = 40°C	plastic enclosure	T <sub>amb</sub> = 40°C

Material	Temperature	Material	Temperature
aluminum enclosure	T <sub>amb</sub> = 50°C (for insulation see table above)	aluminum enclosure	T <sub>amb</sub> = 40°C
plastic enclosure	T <sub>amb</sub> = 40°C	plastic enclosure	T <sub>amb</sub> = 40°C

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
 Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

## 2. Proline Promag 300/500

### 2.1 Marking

Proline Promag 300			
Model Code: 5*3*** – dd*ff*****+### O5*3*** – dd*ff*****+###			
dd = Approval:	ff = I/O:	ATEX Marking	Marking of Ex protection
BB	CA, CB, CC, CD, HA, TA	II2(1)G II2(1)D	Ex db eb ia [ia Ga] IIC T6...T1 Gb Ex tb [ia Da] IIIC T** °C Db
	BA, BB, GA, LA, NA, RA, SA, MA	II2G II2D	Ex db eb ia IIC T6...T1 Gb Ex tb IIIC T** °C Db
BD	CA, CB, CC, CD, HA, TA	II2(1)G II2(1)D	Ex db eb ia [ia Ga] IIC T6...T1 Gb Ex tb [ia Da] IIIC T** °C Db
	BA, BB, GA, LA, NA, RA, SA, MA	II2G II2D	Ex db eb ia IIC T6...T1 Gb Ex tb IIIC T** °C Db

Proline Promag 500 with ISEM integrated in transmitter				
Model Code: 5*5*** – dd*ff****B*****+### O5*5*** – dd*ff****B*****+###				
dd = Approval:	ff = I/O:	Device	ATEX Marking	Marking of Ex protection transmitter
BB	CA, CB, CC, CD, HA, TA, BA, BB, GA, LA, NA, RA, SA, MA	Transmitter	II2(1)G II2(1)D	Ex db eb [ia Ga] IIC T6...T5 Gb Ex tb [ia Da] IIIC T85°C Db
		Sensor	II2G II2D	Ex eb ia IIC T6...T1 Gb Ex ia tb IIIC T** °C Db
BD	CA, CB, CC, CD, HA, TA, BA, BB, GA, LA, NA, RA, SA, MA	Transmitter	II2(1)G II2(1)D	Ex db [ia Ga] IIC T6...T5 Gb Ex tb [ia Da] IIIC T85°C Db
		Sensor	II2G II2D	Ex eb ia IIC T6...T1 Gb Ex ia tb IIIC T** °C Db
B7	CA, CB, CC, CD, HA, TA, BA, BB, GA, LA, NA, RA, SA, MA	Transmitter	II2(1)G	Ex db eb [ia Ga] IIC T6... T5 Gb
		Sensor	II2G	Ex eb ia IIC T6...T1 Gb
B8	CA, CB, CC, CD, HA, TA, BA, BB, GA, LA, NA, RA, SA, MA	Transmitter	II2(1)G	Ex db [ia Ga] IIC T6... T5 Gb
		Sensor	II2G	Ex eb ia IIC T6...T1 Gb

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
 Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

Proline Promag 500 Digital				
Model Code: 5*5*** – dd*ff****B*****+###                      O5*5*** – dd*ff****B*****+###				
dd = Approval:	ff = I/O:	Device	ATEX Marking	Marking of Ex protection transmitter
BN and BJ	HA, TA, BA, BB, GA, LA, NA, RA, SA, MA, CA, CB, CC, CD	Sensor	II2G II2D	Ex db ia IIC T6...T1 Gb Ex ia tb IIIC T** °C Db

## 2.2 Order Code

Extended order code Proline Promag 300:

5a3bcc – ddzeffghjlpstttuvww + ###

O5a3bcc – ddzeffghjlpstttuvwwyy + ###

5x3bxx – ddeffghjlpww + ###

O5x3bxx – ddeffghjlpwwyy + ###

for OEM-version

for replacement transmitter only

for replacement transmitter OEM

Extended order code Proline Promag 500:

5a5bcc – ddzeffghijklmnopstttuvww + ###

O5a5bcc – ddzeffghijklmnopstttuvwwyy + ### for OEM-version

5x5bxx – ddeffghijklmopqqww + ###

O5x5bxx – ddeffghijklmopqqwwyy + ###

for replacement transmitter only

for replacement transmitter OEM

**a = Type of sensor**

H = Sensor Promag H

P = Sensor Promag P

W = Sensor Promag W

**b = Generation**

B = Generation of Flowmeter

**cc = Size**

any combination of number and/or letter up to size = DN3000

**dd = Approval**

Proline Promag 300:

BB = Ex db eb [ia] IIC T6...T1 Gb

Ex tb IIIC T\* Db

BD = Ex db [ia] IIC T6...T1 Gb

Ex tb IIIC T\* Db

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

---

## Proline Promag 500:

BB = Ex db eb [ia] IIC T6...T4 Gb (transmitter)  
Ex eb ia IIC T6...T1 Gb (sensor)  
Ex tb IIIC T\*\* Db (transmitter + sensor)  
BD = Ex db [ia] IIC T6...T1 Gb (transmitter)  
Ex eb ia IIC T6...T1 Gb (sensor)  
Ex tb IIIC T\*\* Db (transmitter + sensor)  
BJ = Ex db ia IIC T6...T1 Gb (sensor)  
Ex tb IIIC T\* Db (sensor)  
BN = Ex db ia IIC T6...T1 Gb (sensor)  
Ex tb IIIC T\* Db (sensor)  
B7 = Ex db eb [ia] IIC T6...T1 Gb (transmitter)  
Ex eb [ia] IIC T6...T1 Gb (sensor)  
B8 = Ex db [ia] IIC T6...T1 Gb (transmitter)  
Ex eb [ia] IIC T6...T1 Gb (sensor)

**z** = **Design** (Promag W 300 and Proline W 500 only)  
any single number or letter

**e** = **Power Supply**

D = 24Vdc  
E = 100-230Vac  
I = 100-230Vac / 24Vdc  
X = sensor only

**ff** = **Input / Output 1**

BA = 4-20mA HART  
BB = 4-20mA WHART  
CA = 4-20mA HART Ex i (passive)  
CB = 4-20mA WHART Ex i (passive)  
CC = 4-20mA HART Ex i (active)  
CD = 4-20mA WHART Ex i (active)

GA = Profibus PA  
HA = Profibus PA Ex i  
LA = Profibus DP  
MA = Modbus RS485  
NA = EtherNet/IP  
RA = Profinet IO  
SA = Foundation Fieldbus  
TA = Foundation Fieldbus Ex i  
XX = sensor only

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
Utrechtseweg 310,  
6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

---

- g = Input / Output 2**  
A = without Input/Output 2  
B = 4-20mA  
C = 4-20mA Ex i (passive)  
D = Configurable IO  
E = Pulse/Frequency/Switch output  
F = Pulse output phase-shifted  
G = Pulse/Frequency/Switch output Ex i  
H = Relay  
I = 4-20mA input  
J = Status input  
L = Pulse output Ex i  
K = Pulse output  
X = sensor only
- h = Input / Output 3**  
A = without Input/Output 3  
B = 4-20mA  
C = 4-20mA Ex i (passive)  
D = Configurable IO  
E = Pulse/Frequency/Switch output  
F = Pulse output phase-shifted  
G = Pulse/Frequency/Switch output Ex i  
H = Relay  
I = 4-20mA input  
J = Status input  
L = Pulse output Ex i  
K = Pulse output  
X = sensor only
- i = Input / Output 4 (Proline 500 only)**  
A = without Input/Output 4  
B = 4-20mA  
C = 4-20mA Ex i (passive)  
D = Configurable IO  
E = Pulse/Frequency/Switch output  
F = Pulse output phase-shifted  
G = Pulse/Frequency/Switch output Ex i  
H = Relay  
I = 4-20mA input  
J = Status input  
L = Pulse output Ex i  
K = Pulse output  
X = sensor only
- j = Display / Operation**  
with remote Display : O  
without remote Display : any single number or letter except O

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
Utrechtseweg 310,  
6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

---

- k = **Integrated ISEM electronic** (Proline 500 only)
  - A = Sensor
  - B = Transmitter
- l = **Housing** (Proline 300 only)  
any single number or letter
- m = **Transmitter Housing** (Proline 500 only)  
any single number or letter
- n = **Sensor Housing** (Proline 500 only)  
any single number or letter
- o = **Cable Sensor Connection** (Proline 500 only)  
any single number or letter
- p = **Cable Entry**  
any single number or letter
- qq = **Upgrade Kid**  
any double digits with combination of number or letter
- s = **Liner material**  
any single number or letter
- ttt = **Process connection**  
any triple digits with combination of number or letter
- u = **Electrode**  
any number or letter
- v = **Calibration**  
any single number or letter
- w = **Device Model (two digit)** (refer to section 2.3 for assignment table of flowmeter to replacement transmitter)  
w  
A1 = product version 1
- yy = **Customer version (two digit)**  
any double digits with combination of number or letter
- \*\* = **Option in two digits (none, two or multiple of two digits)**  
any combination of number and/or letter
- #, = **Signs used as indicator for optional abbreviation of extended order code**  
+

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
Utrechtseweg 310,  
6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
 Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500  
 Applicant: Endress+Hauser Flowtec AG



## 2.3 Assignment of Flowmeter to Replacement Transmitter

The replacement transmitters are assigned to the flowmeter Proline Promag 300/500 as follows:

Product flowmeters			Replacement transmitter type			
model code	Generation code b =	device model code ww =	model code	Generation code b =	device model code ww =	
5H*b**-...ww, 5P*b**-...ww, 5W*b**-...ww,	O5H*b**-...ww O5P*b**-...ww O5W*b**-...ww	B	A1	5x*bxx-...ww, O5x*bxx-...ww	B	A1

## 2.4 Parameters

### 2.4.1 Electrical Parameters

Power Supply	terminal no.	values
Order Code e =		
D <sup>1)</sup>	No. 1(L+/L), 2(L-/N)	U <sub>N</sub> = 19.2...28.8V <sub>DC</sub> U <sub>M</sub> = 250Vac
E <sup>1)</sup>	No. 1(L+/L), 2(L-/N)	U <sub>N</sub> = 85...264V <sub>AC</sub> U <sub>M</sub> = 250Vac
I <sup>2)</sup>	No. 1(L+/L), 2(L-/N)	U <sub>N</sub> = 19.2...28.8V <sub>DC</sub> / 85...264V <sub>AC</sub> U <sub>M</sub> = 250 V

3) applicable for products with approval code dd = BA, BB, BC, BD, B7, B8

4) applicable for products with approval code dd = BI, BJ, BM, BN

Input/Output 1	terminal no.	values
Order Code ff =		
BA, BB, MA	No. 26, 27	U <sub>N</sub> = 30V <sub>DC</sub> U <sub>M</sub> = 250Vac
LA, GA, SA	No. 26, 27	U <sub>N</sub> = 32V <sub>DC</sub> U <sub>M</sub> = 250Vac
CA, CB	No. 26, 27	U <sub>i</sub> = 30V I <sub>i</sub> = 100mA P <sub>i</sub> = 1.25W L <sub>i</sub> = 0 C <sub>i</sub> = 0
CC, CD	No. 26, 27	1) U <sub>O</sub> = 21.8V I <sub>O</sub> = 90mA P <sub>O</sub> = 491mW L <sub>O</sub> = 4.1mH (IIC) /
		2) U <sub>O</sub> = 21.8V I <sub>O</sub> = 90mA P <sub>O</sub> = 491mW L <sub>O</sub> = 9mH (IIC) /

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
 Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

		$C_o = 15\text{mH (IIB)}$ $C_o = 160\text{nF (IIC)} / 1160\text{nF (IIB)}$  $U_i = 30\text{V}$ $I_i = 10\text{mA}$ $P_i = 0.3\text{W}$ $C_i = 6\text{nF}$ $L_i = 4.1\text{mH}$	$C_o = 39\text{mH (IIB)}$ $C_o = 600\text{nF (IIC)} / 4000\text{nF (IIB)}$  $U_i = 30\text{V}$ $I_i = 10\text{mA}$ $P_i = 0.3\text{W}$ $C_i = 6\text{nF}$ $L_i = 4.1\text{mH}$
HA, TA	No. 26, 27	<sup>1)</sup> <u>Profibus PA (Fisco Field Device) / Foundation Fieldbus</u> $U_i = 30\text{V}$ $I_i = 570\text{mA}$ $P_i = 8.5\text{W}$ $L_i = 10\mu\text{H}$ $C_i = 5\text{nF}$	<sup>2)</sup> <u>Profibus PA (Fisco Field Device) / Foundation Fieldbus</u> $U_i = 32\text{V}$ $I_i = 570\text{mA}$ $P_i = 8.5\text{W}$ $L_i = 10\mu\text{H}$ $C_i = 5\text{nF}$
NA, RA	IO1 / RJ45	$U_N = 30\text{V}_{\text{DC}}$ $U_M = 250\text{V}_{\text{AC}}$	

<sup>1)</sup> applicable for products with approval code dd = BB, BD, B7, B8

<sup>2)</sup> applicable for products with approval code dd = BM, BN

Input/Output 2	terminal no.	values
Order Code g =		
C, G, K	No. 24, 25	$U_i = 30\text{V}$ $I_i = 100\text{mA}$ $P_i = 1.25\text{W}$ $L_i = 0$ $C_i = 0$
B, D, E, F, I, J, L	No. 24, 25	$U_N = 30\text{V}_{\text{DC}}$ $U_M = 250\text{V}_{\text{AC}}$
H	No. 24, 25	$U_N = 30\text{V}_{\text{DC}}$ $I_N = 100\text{mA}_{\text{DC}} / 500\text{mA}_{\text{AC}}$ $U_M = 250\text{V}_{\text{AC}}$

Input/Output 3	terminal no.	values
Order Code h =		
C, G, K	No. 22, 23	$U_i = 30\text{V}$ $I_i = 100\text{mA}$ $P_i = 1.25\text{W}$ $L_i = 0$ $C_i = 0$
B, D, E, F, I, J, L	No. 22, 23	$U_N = 30\text{V}_{\text{DC}}$

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands



# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
 Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

		$U_M = 250V_{ac}$
H	No. 22, 23	$U_N = 30V_{DC}$ $I_N = 100mA_{DC} / 500mA_{AC}$ $U_M = 250V_{ac}$

Input/Output 4		
Order Code i =	terminal no.	values
C, G, K	No. 20, 21	$U_i = 30V$ $I_i = 100mA$ $P_i = 1.25W$ $L_i = 0$ $C_i = 0$
B, D, E, F, I, J, L	No. 20, 21	$U_N = 30V_{DC}$ $U_M = 250V_{ac}$
H	No. 20, 21	$U_N = 30V_{DC}$ $I_N = 100mA_{DC} / 500mA_{AC}$ $U_M = 250V_{ac}$

Service Interface		
Order Code dd =	terminal no.	values
BB, BD, B7, B8	Service Interface	Service Interface shall only be installed in areas which are known to be non hazardous
not for: BB, BD, B7, B8	Service Interface	$U_N = 3.3V$

Antenna bushing		
Order Code dd =	terminal no.	values
BB, BJ, BN, B7	N connector	See conditions of safe use

Display remote		
Order Code dd =	terminal no.	values
BB, BD, B7, B8	No. 81, 82, 83, 84	$U_o = 3.9V$ $I_o = 1.5A$ (spark), 200mA (power) $P_o = 600mW$ $R_i = 2.6\Omega$ $C_o = 670\mu F$ $L_o = 0$
not for: BB, BD, B7, B8	No. 81, 82, 83, 84	$U_N = 3.3V$ $I_N = 150mA$

For Transmitter with approval code dd = BB, BD, B7 and B8 connected to the Remote Display of Endress+Hauser, Type DKX001 or ODKX001, the cable parameter with ration  $L/R = \leq 0.024$  mH/ $\Omega$  applies.

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500  
Applicant: Endress+Hauser Flowtec AG

---



## Proline Remote Transmitter and Remote Sensor:

5\*\*\*\*\*-... and O5\*\*\*\*\*-... with order code dd = BB, BD, B7, B8 in combination with k = B:

Transmitter :

terminals 4, 5, 6, 7, 8, 32, 33, 34, 35, 36, 37 ->  $U_o = 26.6V$ ,  $I_o = 19.2mA$ ,  $P_o = 128mW$ ,  
 $L_o = 20mH$ ,  $C_o = 94nF$

and

$U_o = 13.3V$ ,  $I_o = 39.2mA$ ,  $P_o = 131mW$ ,  
 $L_o = 20mH$ ,  $C_o = 94nF$

terminals 41, 42 ->  $U_N = 60V$ ,  $I_N = 90mA$

Sensor :

terminals 4, 5, 6, 7, 8, 32, 33, 34, 35, 36, 37 ->  $U_i = 26.6V$ ,  $I_i = n.a.$ ,  $P_i = n.a.$ ,  $L_i = 0$ ,  $C_i = 0$

terminals 41, 42 ->  $U_N = 60V$ ,  $I_N = 90mA$

Interconnection of circuit connected to terminals 4, 5, 6, 7, 8, 37, 36 for use of a cable with a maximum length of 200m is allowed when using a cable which has the following parameters:

Cable inductance  $\leq 1$  mH/km

Cable capacitance  $\leq 0.42\mu F/km$

5\*\*\*\*\*-... and O5\*\*\*\*\*-... with order code dd = BJ, BN in combination with k = A:

Transmitter:

terminals 61, 62 ->  $U_N = 35V$   
terminals 63, 64 ->  $U_N = 3.3V$

Sensor:

terminals 61, 62 ->  $U_N = 35V$   
terminals 63, 64 ->  $U_N = 3.3V$

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
 Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500  
 Applicant: Endress+Hauser Flowtec AG



## 2.4.2 Thermal Parameters (Zone 1)

**Proline Promag H/PW 300**

Notes: This page applies to versions with extended order code covering:  
 5/H/P/3B\*\* - dd...  
 5M/3B\*\* - dd...  
 with approval option  
 CCSAus / CSA: dd = CD, CE, C2, C4  
 IECEX / ATEX: dd = BB, BD

Standard version with sensor not insulated:  
 O5/H/P/3B\*\* - dd...  
 O5/M/3B\*\* - dd...  
 CCSAus / CSA: dd = CD, CE, C2, C4  
 IECEX / ATEX: dd = BB, BD

High temperature version with sensor insulated (for insulation refer to manual of E-H Flowtec):  
 5x2Bxx - dd...  
 5x3Bxx - dd...  
 O5x3Bxx - dd...

Sensor	Size / DN	Liner	T <sub>max</sub> [°C]	T <sub>max</sub> [°C]	T <sub>max</sub> [°C]							
					T6 (85°C)	T5 (100°C)	T4 (135°C)	T3 (200°C)	T2 (300°C)	T1 (450°C)	T1 (450°C)	
Promag P	15...600	PTFE	-40	45	60	90	130	130	130	130	130	130
				55	60	90	130	130	130	130	130	
				60	60	90	130	130	130	130	130	
Promag W	25...200	PFA	-40	45	60	95	130	150	150	150	150	
				50	60	95	130	150	150	150	150	
				60	60	95	130	150	150	150	150	
Promag H	25...1000	HG	-20	50	60	80	80	80	80	80	80	
				50	60	80	80	80	80	80	80	
				50	60	80	80	80	80	80	80	
Promag H	2...150	PFA	-40	55 (3)	65 (3)	80	130	150	150	150	150	
				60 (3)	65 (3)	80	130	150	150	150	150	
				60 (3)	65 (3)	80	130	150	150	150	150	

Notes: (1) T<sub>min</sub> = -40°C (for limitation see name plate)  
 (2) T<sub>max</sub> may be reduced by versions. For limitation of range for T<sub>max</sub> see name plate  
 (3) Promag H limited to T<sub>max</sub> = 50°C @ class 16 and T<sub>max</sub> = 30°C @ class 16 for optional versions available with medium temperature measurement

High temperature version with sensor not insulated:  
 Promag P all  
 PFA -40 60 130 130 130 130 130 130  
 HG -40 60 130 130 130 130 130 130  
 PU -20 60 90 90 90 90 90 90

Notes: (1) T<sub>min</sub> = -40°C (for limitation see name plate)  
 (2) T<sub>max</sub> may be reduced by versions. For limitation of range for T<sub>max</sub> see name plate  
 (3) Location of reference point

High temperature version with sensor insulated (insulation not in compliance to manual of E-H Flowtec):  
 Promag P all  
 PFA -40 60 130 130 130 130 130 130  
 HG -40 60 130 130 130 130 130 130  
 PU -20 60 90 90 90 90 90 90

Notes: (1) T<sub>min</sub> = -40°C (for limitation see name plate)  
 (2) T<sub>max</sub> to be measured at reference point at sensor neck [°C]

Sensor	Size / DN	Liner	T <sub>max</sub> [°C]	T <sub>max</sub> [°C]	T <sub>max</sub> [°C]						
					T6 (85°C)	T5 (100°C)	T4 (135°C)	T3 (200°C)	T2 (300°C)	T1 (450°C)	T1 (450°C)
Promag P	all	PTFE	-40	60	130	56.4	71.3	72.0	72.0	72.0	72.0
				60	130	56.4	71.3	72.0	72.0	72.0	72.0
				60	130	56.4	71.3	72.0	72.0	72.0	72.0
Promag W	all	PFA	-40	60	130	56.4	71.3	72.0	72.0	72.0	
				60	130	56.4	71.3	72.0	72.0	72.0	
				60	130	56.4	71.3	72.0	72.0	72.0	
Promag W	all	HG	-20	60	130	56.4	71.3	72.0	72.0	72.0	
				60	130	56.4	71.3	72.0	72.0	72.0	
				60	130	56.4	71.3	72.0	72.0	72.0	

Notes: (1) T<sub>min</sub> = -40°C (for limitation see name plate)  
 (2) T<sub>max</sub> to be measured at reference point at sensor neck [°C]

reference point  
reference point

Hersteller:	K	10.05.2016 / Bn	E	
Produkt:	P	24.10.2010 / Bn	S	
Version:	C	03.05.2015 / Bn	H	
Druck:	D	15.02.2015 / Bn	J	
Druck:	E		K	

Alle gezeigten Informationen, insbesondere Genehmigungen, sind ohne Gewährleistung der Richtigkeit zu verstehen. Die Verantwortung für die Korrektheit der Angaben liegt bei den Kunden.

Exakte date: 10.05.2016  
 Erteilt für: FES0260D / Bn  
 Genehmigt: 10.05.2016  
 Ergeben: 15.02.2015  
 Bn

Control Drawing IECEX, ATEX, CSA, cCSAus  
 Zone 1, Zone 21, Cl I Div 1, Cl II, Cl III, Cl I Zone 1  
 Thermal Parameter  
 Proline Promag 300/500

**FES0260D 1/3**

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands



# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
 Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500  
 Applicant: Endress+Hauser Flowtec AG



### Proline Promag H/PMW 500

Notes: This page applies to versions with extended order code covering:

5/H/PM5R\*\* - dd\*\*\*\*\*A...  
 5M/5R\*\* - dd\*\*\*\*\*A...  
 with approval option  
 CCSAUS / CSA: dd = CN, C6  
 IECEX / ATEX: dd = B1, BN

05/H/PM5R\*\* - dd\*\*\*\*\*A...  
 05M/5R\*\* - dd\*\*\*\*\*A...  
 5x5Bxx - dd\*\*\*\*\*A...  
 05x5Bxx - dd\*\*\*\*\*A...

#### Sensor of Standard version with sensor not insulated

Sensor	Size / DN	Liner	T <sub>max</sub> [°C]	T <sub>max</sub> [°C]													
				T6	T5	T4	T3	T2	T1	T6	T5	T4	T3	T2	T1		
Promag P	15...600	PTFE	-40	60	80	95	130	150	150	130	130	130	130	130	130	130	130
	25...200	PFA	-40	50	50	95	130	150	150	150	150	150	150	150	150	150	150
Promag W	50...3000	HG	-20	60	80	80	95	130	130	130	130	130	130	130	130	130	130
	25...1000	PU	-20	50	50	50	50	50	50	50	50	50	50	50	50	50	50
Promag H	2...150	PFA	-40	45	80	95	130	150	150	150	150	150	150	150	150	150	150
	60	PU	-20	45	80	95	135	135	135	135	135	135	135	135	135	135	135

Notes: (1) T<sub>min</sub> = -40°C (for limitation see name plate)  
 (2) T<sub>max</sub> may be reduced by versions. For limitation of range for T<sub>max</sub> see name plate  
 (3) Promag H limited to T<sub>max</sub> = 50°C @ class T6 and T<sub>max</sub> = 50°C @ class T5 for optional versions available with medium temperature measurement

#### Sensor of High temperature version with sensor not insulated:

Sensor	Size / DN	Liner	T <sub>max</sub> [°C]	T <sub>max</sub> [°C]													
				T6	T5	T4	T3	T2	T1	T6	T5	T4	T3	T2	T1		
Promag P	15...600	PTFE	-40	60	80	95	130	130	130	130	130	130	130	130	130	130	130
	25...200	PFA	-40	60	80	95	130	150	150	150	150	150	150	150	150	150	150
Promag W	50...3000	HG	-20	60	80	80	95	130	130	130	130	130	130	130	130	130	130
	25...1000	PU	-20	50	50	50	50	50	50	50	50	50	50	50	50	50	50

Notes: (1) T<sub>min</sub> = -40°C (for limitation see name plate)  
 (2) T<sub>max</sub> may be reduced by versions. For limitation of range for T<sub>max</sub> see name plate

#### Sensor of High temperature version with sensor insulated (for insulation refer to manual of E+H Flowtec)

Sensor	Size / DN	Liner	T <sub>max</sub> [°C]	T <sub>max</sub> [°C]													
				T6	T5	T4	T3	T2	T1	T6	T5	T4	T3	T2	T1		
Promag P	15...600	PTFE	-40	60	80	95	130	130	130	130	130	130	130	130	130	130	130
	25...200	PFA	-40	60	80	95	130	150	150	150	150	150	150	150	150	150	150
Promag W	50...3000	HG	-20	60	80	80	95	130	130	130	130	130	130	130	130	130	130
	25...1000	PU	-20	50	50	50	50	50	50	50	50	50	50	50	50	50	50

Notes: (1) T<sub>min</sub> = -40°C (for limitation see name plate)  
 (2) T<sub>max</sub> may be reduced by versions. For limitation of range for T<sub>max</sub> see name plate

#### Sensor of High temperature version with sensor insulated (insulation not in compliance to manual of E+H Flowtec):

Sensor	Size / DN	Liner	T <sub>max</sub> [°C]	T <sub>max</sub> [°C]													
				T6	T5	T4	T3	T2	T1	T6	T5	T4	T3	T2	T1		
Promag P	all	PTFE	-40	60	80	95	130	130	130	130	130	130	130	130	130	130	130
		PFA	-40	60	80	95	130	150	150	150	150	150	150	150	150	150	150
Promag W	all	HG	-20	60	80	80	95	130	130	130	130	130	130	130	130	130	130
		PU	-20	50	50	50	50	50	50	50	50	50	50	50	50	50	50

Notes: (1) T<sub>min</sub> = -40°C (for limitation see name plate)  
 (2) location of reference point



Transmitter for all versions:			
Type of enclosure	Ordinary location (°C)	T <sub>min</sub>	T <sub>max</sub>
aluminum	60	---	45
plastic	60	---	60

Notes: (1) aluminum enclosure: T<sub>min</sub> = -50°C (for limitation see name plate)  
 (2) plastic enclosure: T<sub>min</sub> = -40°C

Änderungen:	A: 11.02.2018 / Bn	E	Alle gesetzlichen und technischen Vorschriften	Erstellt durch:
	B: 24.10.2018 / Bn	S	Änderung Zeichnung und ohne weitere	
	C: 03.08.2017 / Bn	H	Genehmigung neuer veränderung werden von	Erstellt für:
	D: 15.02.2018 / Bn	J	dem Hersteller und Kundentechniker	Ersteller: FES / Bn
	E: 15.02.2018 / Bn	K	zugewiesener person	FILE: MZK009/FES020600/FES020600.doc

Control Drawing IECEX, ATEX, CSA, CCSAUS  
 Zone 1, Zone 21, CII, Div. 1, CIII, CIIII, CII Zone 1  
 Thermal Parameter  
 Proline Promag 300/500

Gezeichnet	10.02.2018	Bn
Geprüft		
Er-gedr-ht	10.02.2018	Bn
Gezeichnet		

**E+H** Flowtec AG, Käpenstrasse 7, CH-4153 Reinach, BL 1, Postfach

**FES0260D 3/3**

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
 Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

## 3 Proline Promag 300/500

### 3.1 Marking

Proline Promag 300			
Model Code: 5*3*** – dd*ff*****+### O5*3*** – dd*ff*****+###			
dd = Approval:	ff = I/O:	ATEX Marking	Marking of Ex protection
BB	CA, CB, CC, CD, HA, TA	II2(1)G II2(1)D	Ex db eb ia [ia Ga] IIC T6...T1 Gb Ex tb [ia Da] IIIC T** °C Db
	BA, BB, GA, LA, NA, RA, SA, MA	II2G II2D	Ex db eb ia IIC T6...T1 Gb Ex tb IIIC T** °C Db
BD	CA, CB, CC, CD, HA, TA	II2(1)G II2(1)D	Ex db eb ia [ia Ga] IIC T6...T1 Gb Ex tb [ia Da] IIIC T** °C Db
	BA, BB, GA, LA, NA, RA, SA, MA	II2G II2D	Ex db eb ia IIC T6...T1 Gb Ex tb IIIC T** °C Db

Proline Promag 500 with ISEM integrated in transmitter				
Model Code: 5*5*** – dd*ff****B*****+### O5*5*** – dd*ff****B*****+###				
dd = Approval:	ff = I/O:	Device	ATEX Marking	Marking of Ex protection transmitter
BB	CA, CB, CC, CD, HA, TA, BA, BB, GA, LA, NA, RA, SA, MA	Transmitter	II2(1)G II2(1)D	Ex db eb [ia Ga] IIC T6...T5 Gb Ex tb [ia Da] IIIC T85°C Db
		Sensor	II2G II2D	Ex eb ia IIC T6...T1 Gb Ex ia tb IIIC T** °C Db
BD	CA, CB, CC, CD, HA, TA, BA, BB, GA, LA, NA, RA, SA, MA	Transmitter	II2(1)G II2(1)D	Ex db [ia Ga] IIC T6...T5 Gb Ex tb [ia Da] IIIC T85°C Db
		Sensor	II2G II2D	Ex eb ia IIC T6...T1 Gb Ex ia tb IIIC T** °C Db
B7	CA, CB, CC, CD, HA, TA, BA, BB, GA, LA, NA, RA, SA, MA	Transmitter	II2(1)G	Ex db eb [ia Ga] IIC T6... T5 Gb
		Sensor	II2G	Ex eb ia IIC T6...T1 Gb
B8	CA, CB, CC, CD, HA, TA, BA, BB, GA, LA, NA, RA, SA, MA	Transmitter	II2(1)G	Ex db [ia Ga] IIC T6... T5 Gb
		Sensor	II2G	Ex eb ia IIC T6...T1 Gb

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
 Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

Proline Promag 500 Digital				
Model Code: 5*5*** – dd*ff****B*****+###                      O5*5*** – dd*ff****B*****+###				
dd = Approval:	ff = I/O:	Device	ATEX Marking	Marking of Ex protection transmitter
BN and BJ	HA, TA, BA, BB, GA, LA, NA, RA, SA, MA, CA, CB, CC, CD	Sensor	II2G II2D	Ex db ia IIC T6...T1 Gb Ex ia tb IIIC T** °C Db

## 3.2 Order Code

Extended order code Proline Promag 300:

5a3bcc – ddzeffghjlpstttuvww + ###

O5a3bcc – ddzeffghjlpstttuvwwyy + ###

5x3bxx – ddeffghjlpww + ###

O5x3bxx – ddeffghjlpwwyy + ###

for OEM-version

for replacement transmitter only

for replacement transmitter OEM

Extended order code Proline Promag 500:

5a5bcc – ddzeffghijklmnopstttuvww + ###

O5a5bcc – ddzeffghijklmnopstttuvwwyy + ### for OEM-version

5x5bxx – ddeffghijklmopqqww + ###

O5x5bxx – ddeffghijklmopqqwwyy + ###

for replacement transmitter only

for replacement transmitter OEM

**a = Type of sensor**

H = Sensor Promag H

P = Sensor Promag P

W = Sensor Promag W

**b = Generation**

B = Generation of Flowmeter

**cc = Size**

any combination of number and/or letter up to size = DN3000

**dd = Approval**

Proline Promag 300:

BB = Ex db eb [ia] IIC T6...T1 Gb

Ex tb IIIC T\* Db

BD = Ex db [ia] IIC T6...T1 Gb

Ex tb IIIC T\* Db

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

---

## Proline Promag 500:

BB = Ex db eb [ia] IIC T6...T4 Gb (transmitter)  
Ex eb ia IIC T6...T1 Gb (sensor)  
Ex tb IIIC T\*\* Db (transmitter + sensor)  
BD = Ex db [ia] IIC T6...T1 Gb (transmitter)  
Ex eb ia IIC T6...T1 Gb (sensor)  
Ex tb IIIC T\*\* Db (transmitter + sensor)  
BJ = Ex db ia IIC T6...T1 Gb (sensor)  
Ex tb IIIC T\* Db (sensor)  
BN = Ex db ia IIC T6...T1 Gb (sensor)  
Ex tb IIIC T\* Db (sensor)  
B7 = Ex db eb [ia] IIC T6...T1 Gb (transmitter)  
Ex eb [ia] IIC T6...T1 Gb (sensor)  
B8 = Ex db [ia] IIC T6...T1 Gb (transmitter)  
Ex eb [ia] IIC T6...T1 Gb (sensor)

**z** = **Design** (Promag W 300 and Proline W 500 only)  
any single number or letter

**e** = **Power Supply**

D = 24Vdc  
E = 100-230Vac  
I = 100-230Vac / 24Vdc  
X = sensor only

**ff** = **Input / Output 1**

BA = 4-20mA HART  
BB = 4-20mA WHART  
CA = 4-20mA HART Ex i (passive)  
CB = 4-20mA WHART Ex i (passive)  
CC = 4-20mA HART Ex i (active)  
CD = 4-20mA WHART Ex i (active)

GA = Profibus PA  
HA = Profibus PA Ex i  
LA = Profibus DP  
MA = Modbus RS485  
NA = EtherNet/IP  
RA = Profinet IO  
SA = Foundation Fieldbus  
TA = Foundation Fieldbus Ex i  
XX = sensor only

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
Utrechtseweg 310,  
6812 AR, Arnhem Netherlands



# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

---

- g = Input / Output 2**
  - A = without Input/Output 2
  - B = 4-20mA
  - C = 4-20mA Ex i (passive)
  - D = Configurable IO
  - E = Pulse/Frequency/Switch output
  - F = Pulse output phase-shifted
  - G = Pulse/Frequency/Switch output Ex i
  - H = Relay
  - I = 4-20mA input
  - J = Status input
  - L = Pulse output Ex i
  - K = Pulse output
  - X = sensor only
- h = Input / Output 3**
  - A = without Input/Output 3
  - B = 4-20mA
  - C = 4-20mA Ex i (passive)
  - D = Configurable IO
  - E = Pulse/Frequency/Switch output
  - F = Pulse output phase-shifted
  - G = Pulse/Frequency/Switch output Ex i
  - H = Relay
  - I = 4-20mA input
  - J = Status input
  - L = Pulse output Ex i
  - K = Pulse output
  - X = sensor only
- i = Input / Output 4 (Proline 500 only)**
  - A = without Input/Output 4
  - B = 4-20mA
  - C = 4-20mA Ex i (passive)
  - D = Configurable IO
  - E = Pulse/Frequency/Switch output
  - F = Pulse output phase-shifted
  - G = Pulse/Frequency/Switch output Ex i
  - H = Relay
  - I = 4-20mA input
  - J = Status input
  - L = Pulse output Ex i
  - K = Pulse output
  - X = sensor only
- j = Display / Operation**
  - with remote Display : O
  - without remote Display : any single number or letter except O

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
Utrechtseweg 310,  
6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

---

- k = **Integrated ISEM electronic** (Proline 500 only)
  - A = Sensor
  - B = Transmitter
- l = **Housing** (Proline 300 only)  
any single number or letter
- m = **Transmitter Housing** (Proline 500 only)  
any single number or letter
- n = **Sensor Housing** (Proline 500 only)  
any single number or letter
- o = **Cable Sensor Connection** (Proline 500 only)  
any single number or letter
- p = **Cable Entry**  
any single number or letter
- qq = **Upgrade Kid**  
any double digits with combination of number or letter
- s = **Liner material**  
any single number or letter
- ttt = **Process connection**  
any triple digits with combination of number or letter
- u = **Electrode**  
any number or letter
- v = **Calibration**  
any single number or letter
- w = **Device Model (two digit)** (refer to section 2.3 for assignment table of flowmeter to replacement transmitter)  
w  
A1 = product version 1
- yy = **Customer version (two digit)**  
any double digits with combination of number or letter
- \*\* = **Option in two digits (none, two or multiple of two digits)**  
any combination of number and/or letter
- #, = **Signs used as indicator for optional abbreviation of extended order code**  
+

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
Utrechtseweg 310,  
6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
 Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500  
 Applicant: Endress+Hauser Flowtec AG



### 3.3 Assignment of Flowmeter to Replacement Transmitter

The replacement transmitters are assigned to the flowmeter Proline Promag 300/500 as follows:

Product flowmeters			Replacement transmitter type			
model code	Generation code b =	device model code ww =	model code	Generation code b =	device model code ww =	
5H*b**-...ww, 5P*b**-...ww, 5W*b**-...ww,	O5H*b**-...ww O5P*b**-...ww O5W*b**-...ww	B	A1	5x*bxx-...ww, O5x*bxx-...ww	B	A1

### 3.4 Parameters

#### 3.4.1 Electrical Parameters

Power Supply	terminal no.	values
Order Code e =		
D <sup>1)</sup>	No. 1(L+/L), 2(L-/N)	U <sub>N</sub> = 19.2...28.8V <sub>DC</sub> U <sub>M</sub> = 250Vac
E <sup>1)</sup>	No. 1(L+/L), 2(L-/N)	U <sub>N</sub> = 85...264V <sub>AC</sub> U <sub>M</sub> = 250Vac
I <sup>2)</sup>	No. 1(L+/L), 2(L-/N)	U <sub>N</sub> = 19.2...28.8V <sub>DC</sub> / 85...264V <sub>AC</sub> U <sub>M</sub> = 250 V

5) applicable for products with approval code dd = BA, BB, BC, BD, B7, B8

6) applicable for products with approval code dd = BI, BJ, BM, BN

Input/Output 1	terminal no.	values
Order Code ff =		
BA, BB, MA	No. 26, 27	U <sub>N</sub> = 30V <sub>DC</sub> U <sub>M</sub> = 250Vac
LA, GA, SA	No. 26, 27	U <sub>N</sub> = 32V <sub>DC</sub> U <sub>M</sub> = 250Vac
CA, CB	No. 26, 27	U <sub>i</sub> = 30V I <sub>i</sub> = 100mA P <sub>i</sub> = 1.25W L <sub>i</sub> = 0 C <sub>i</sub> = 0
CC, CD	No. 26, 27	1) U <sub>O</sub> = 21.8V I <sub>O</sub> = 90mA P <sub>O</sub> = 491mW L <sub>O</sub> = 4.1mH (IIC) /
		2) U <sub>O</sub> = 21.8V I <sub>O</sub> = 90mA P <sub>O</sub> = 491mW L <sub>O</sub> = 9mH (IIC) /

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
 Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

		$C_o = 15\text{mH (IIB)}$ $C_o = 160\text{nF (IIC)} / 1160\text{nF (IIB)}$  $U_i = 30\text{V}$ $I_i = 10\text{mA}$ $P_i = 0.3\text{W}$ $C_i = 6\text{nF}$ $L_i = 4.1\text{mH}$	$C_o = 39\text{mH (IIB)}$ $C_o = 600\text{nF (IIC)} / 4000\text{nF (IIB)}$  $U_i = 30\text{V}$ $I_i = 10\text{mA}$ $P_i = 0.3\text{W}$ $C_i = 6\text{nF}$ $L_i = 4.1\text{mH}$
HA, TA	No. 26, 27	<sup>1)</sup> <u>Profibus PA (Fisco Field Device) / Foundation Fieldbus</u> $U_i = 30\text{V}$ $I_i = 570\text{mA}$ $P_i = 8.5\text{W}$ $L_i = 10\mu\text{H}$ $C_i = 5\text{nF}$	<sup>2)</sup> <u>Profibus PA (Fisco Field Device) / Foundation Fieldbus</u> $U_i = 32\text{V}$ $I_i = 570\text{mA}$ $P_i = 8.5\text{W}$ $L_i = 10\mu\text{H}$ $C_i = 5\text{nF}$
NA, RA	IO1 / RJ45	$U_N = 30\text{V}_{\text{DC}}$ $U_M = 250\text{V}_{\text{AC}}$	

<sup>1)</sup> applicable for products with approval code dd = BB, BD, B7, B8

<sup>2)</sup> applicable for products with approval code dd = BM, BN

Input/Output 2	terminal no.	values
Order Code g =		
C, G, K	No. 24, 25	$U_i = 30\text{V}$ $I_i = 100\text{mA}$ $P_i = 1.25\text{W}$ $L_i = 0$ $C_i = 0$
B, D, E, F, I, J, L	No. 24, 25	$U_N = 30\text{V}_{\text{DC}}$ $U_M = 250\text{V}_{\text{AC}}$
H	No. 24, 25	$U_N = 30\text{V}_{\text{DC}}$ $I_N = 100\text{mA}_{\text{DC}} / 500\text{mA}_{\text{AC}}$ $U_M = 250\text{V}_{\text{AC}}$

Input/Output 3	terminal no.	values
Order Code h =		
C, G, K	No. 22, 23	$U_i = 30\text{V}$ $I_i = 100\text{mA}$ $P_i = 1.25\text{W}$ $L_i = 0$ $C_i = 0$
B, D, E, F, I, J, L	No. 22, 23	$U_N = 30\text{V}_{\text{DC}}$

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
 Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

		$U_M = 250V_{ac}$
H	No. 22, 23	$U_N = 30V_{DC}$ $I_N = 100mA_{DC} / 500mA_{AC}$ $U_M = 250V_{ac}$

Input/Output 4		
Order Code i =	terminal no.	values
C, G, K	No. 20, 21	$U_i = 30V$ $I_i = 100mA$ $P_i = 1.25W$ $L_i = 0$ $C_i = 0$
B, D, E, F, I, J, L	No. 20, 21	$U_N = 30V_{DC}$ $U_M = 250V_{ac}$
H	No. 20, 21	$U_N = 30V_{DC}$ $I_N = 100mA_{DC} / 500mA_{AC}$ $U_M = 250V_{ac}$

Service Interface		
Order Code dd =	terminal no.	values
BB, BD, B7, B8	Service Interface	Service Interface shall only be installed in areas which are known to be non hazardous
not for: BB, BD, B7, B8	Service Interface	$U_N = 3.3V$

Antenna bushing		
Order Code dd =	terminal no.	values
BB, BJ, BN, B7	N connector	See conditions of safe use

Display remote		
Order Code dd =	terminal no.	values
BB, BD, B7, B8	No. 81, 82, 83, 84	$U_o = 3.9V$ $I_o = 1.5A$ (spark), 200mA (power) $P_o = 600mW$ $R_i = 2.6\Omega$ $C_o = 670\mu F$ $L_o = 0$
not for: BB, BD, B7, B8	No. 81, 82, 83, 84	$U_N = 3.3V$ $I_N = 150mA$

For Transmitter with approval code dd = BB, BD, B7 and B8 connected to the Remote Display of Endress+Hauser, Type DKX001 or ODKX001, the cable parameter with ration  $L/R = \leq 0.024$  mH/ $\Omega$  applies.

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500  
Applicant: Endress+Hauser Flowtec AG

---



## Proline Remote Transmitter and Remote Sensor:

5\*\*\*\*\*-... and O5\*\*\*\*\*-... with order code dd = BB, BD, B7, B8 in combination with k = B:

Transmitter :

terminals 4, 5, 6, 7, 8, 32, 33, 34, 35, 36, 37 ->  $U_o = 26.6V$ ,  $I_o = 19.2mA$ ,  $P_o = 128mW$ ,  
 $L_o = 20mH$ ,  $C_o = 94nF$

and

$U_o = 13.3V$ ,  $I_o = 39.2mA$ ,  $P_o = 131mW$ ,  
 $L_o = 20mH$ ,  $C_o = 94nF$

terminals 41, 42 ->  $U_N = 60V$ ,  $I_N = 90mA$

Sensor :

terminals 4, 5, 6, 7, 8, 32, 33, 34, 35, 36, 37 ->  $U_i = 26.6V$ ,  $I_i = n.a.$ ,  $P_i = n.a.$ ,  $L_i = 0$ ,  $C_i = 0$

terminals 41, 42 ->  $U_N = 60V$ ,  $I_N = 90mA$

Interconnection of circuit connected to terminals 4, 5, 6, 7, 8, 37, 36 for use of a cable with a maximum length of 200m is allowed when using a cable which has the following parameters:

Cable inductance  $\leq 1$  mH/km

Cable capacitance  $\leq 0.42\mu F/km$

5\*\*\*\*\*-... and O5\*\*\*\*\*-... with order code dd = BJ, BN in combination with k = A:

Transmitter:

terminals 61, 62 ->  $U_N = 35V$   
terminals 63, 64 ->  $U_N = 3.3V$

Sensor:

terminals 61, 62 ->  $U_N = 35V$   
terminals 63, 64 ->  $U_N = 3.3V$

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
 Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500  
 Applicant: Endress+Hauser Flowtec AG



### 3.4.2 Thermal Parameters (Zone 1)

**Proline Promag H/PUW 300**

Notes: This page applies to versions with extended order code covering: 5/HP/38\*\* - dd...  
 5W/38\*\* - dd...  
 with approval option  
 CCSAus / CSA: dd = CD, CE, C2, C4  
 ECEX / ATEX: dd = BB, BD

5x2Bxx - dd...  
 05x3Bxx - dd...

Sensor	Size / DN	Liner	T <sub>max</sub> [°C]	T <sub>min</sub> [°C]	T <sub>max</sub> [°C]						
					T8 (85°C)	T5 (100°C)	T4 (135°C)	T3 (200°C)	T2 (300°C)	T1 (450°C)	
Promag P	15...600	PTFE	-40	50	60	90	130	130	130	130	130
				55	60	90	130	130	130	130	
				60	60	90	130	130	130	130	
Promag W	25...200	PFA	-40	45	60	95	130	150	150	150	
				50	60	95	130	150	150	150	
				60	60	95	130	150	150	150	
Promag H	50...3000	HG	-20	50	60	80	80	80	80	80	
				50	60	80	80	80	80	80	
				50	60	80	80	80	80	80	
Promag P	15...600	PTFE	-40	50	60	90	130	130	130	130	
				55	60	90	130	130	130	130	
				60	60	90	130	130	130	130	
Promag W	25...200	PFA	-40	45	60	95	130	150	150	150	
				50	60	95	130	150	150	150	
				60	60	95	130	150	150	150	
Promag H	50...3000	HG	-20	50	60	80	80	80	80	80	
				50	60	80	80	80	80	80	
				50	60	80	80	80	80	80	

Notes: (1) T<sub>min</sub> = -40°C (for limitation see name plate)  
 (2) T<sub>max</sub> may be reduced by versions. For limitation of range for T<sub>max</sub> see name plate  
 (3) Promag H limited to T<sub>max</sub> = 50°C @ class 18 and T<sub>max</sub> = 50°C @ class 18 for optional versions available with medium temperature measurement

**High temperature version with sensor not insulated:**

Sensor	Size / DN	Liner	T <sub>max</sub> [°C]	T <sub>min</sub> [°C]	T <sub>max</sub> [°C]					
					T6 (85°C)	T5 (100°C)	T4 (135°C)	T3 (200°C)	T2 (300°C)	T1 (450°C)
Promag P	15...600	PTFE	-40	50	60	95	130	130	130	130
				55	60	95	130	130	130	130
				60	60	95	130	130	130	130
Promag W	25...200	PFA	-40	45	60	95	130	150	150	150
				50	60	95	130	150	150	150
				60	60	95	130	150	150	150
Promag H	50...3000	HG	-20	50	60	80	80	80	80	80
				50	60	80	80	80	80	80
				50	60	80	80	80	80	80

Notes: (1) T<sub>min</sub> = -40°C (for limitation see name plate)  
 (2) T<sub>max</sub> may be reduced by versions. For limitation of range for T<sub>max</sub> see name plate

**High temperature version with sensor insulated:**

Sensor	Size / DN	Liner	T <sub>max</sub> [°C]	T <sub>min</sub> [°C]	T <sub>max</sub> [°C]						
					T6 (85°C)	T5 (100°C)	T4 (135°C)	T3 (200°C)	T2 (300°C)	T1 (450°C)	
Promag P all	all	PTFE	-40	60	130	58.4	71.3	72.0	72.0	72.0	72.0
				60	130	58.4	71.3	72.0	72.0	72.0	72.0
				60	130	58.4	71.3	72.0	72.0	72.0	72.0
Promag W	all	PFA	-40	60	150	58.4	71.3	72.0	72.0	72.0	72.0
				60	150	58.4	71.3	72.0	72.0	72.0	72.0
				60	150	58.4	71.3	72.0	72.0	72.0	72.0
Promag H	all	PU	-20	60	80	58.4	71.3	72.0	72.0	72.0	72.0
				60	80	58.4	71.3	72.0	72.0	72.0	72.0
				60	80	58.4	71.3	72.0	72.0	72.0	72.0

Notes: (1) T<sub>min</sub> = -40°C (for limitation see name plate)  
 (2) T<sub>max</sub> may be reduced by versions. For limitation of range for T<sub>max</sub> see name plate  
 (3) Location of reference point.

reference point

Manufacturer	Model	Serial	Material	Size	Color	Version	Ordering	Installation	Accessories
E	10.05.2018	Bn	E	34.10.2018	Bn	S			
C	03.05.2018	Bn	H	03.05.2018	Bn	J			
D	15.02.2018	Bn	J			K			
E									

Control Drawing: ECEX, ATEX, CSA, cCSAus  
 Zone 1, Zone 21, CII Div 1, CIII, CIII, CII Zone 1  
 Thermal Parameter  
 Proline Promag 300/500

Flowtec AG, Käpenstrasse 7, CH-4153 Reinach, BL1, Postfach

FES0260D 1/3

This certificate and its schedules may only be reproduced in its entirety and without change

**CSA Group Netherlands B.V.**  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands

# Certificate Annexe

**Certificate Number:** Sira 16ATEX2219X  
**Equipment:** Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500  
**Applicant:** Endress+Hauser Flowtec AG



**Proline Promag H/P/W 500**

**Notes:**  
 This page applies to versions with extended order code covering:  
 5/H/P/5B\*\*\*-dd\*\*\*\*\*B...  
 5/W/5B\*\*\*-dd\*\*\*\*\*B...  
 with approval option  
 ICEX/ATEX: dd = 88, 90, 87, 88  
 05/H/P/5B\*\*\*-dd\*\*\*\*\*B...  
 05/W/5B\*\*\*-dd\*\*\*\*\*B...  
 CCSAus / CSA: dd = C2, C4, C7, C8  
 ICEX / ATEX: dd = 88, 90, 87, 88  
 5x5Bxx - dd\*\*\*\*\*B...  
 5x5Bxx - dd\*\*\*\*\*B...  
 05x5Bxx - dd\*\*\*\*\*B...

**Sensor of Standard version with sensor not insulated**

Sensor	Size / DN	Liner	T <sub>meas</sub> [°C]	T <sub>max</sub> [°C]													
				T <sub>6</sub> (85°C)	T <sub>5</sub> (100°C)	T <sub>4</sub> (135°C)	T <sub>3</sub> (200°C)	T <sub>2</sub> (300°C)	T <sub>1</sub> (450°C)	T <sub>6</sub> (85°C)	T <sub>5</sub> (100°C)	T <sub>4</sub> (135°C)	T <sub>3</sub> (200°C)	T <sub>2</sub> (300°C)	T <sub>1</sub> (450°C)		
Promag P	15..600	PTFE	-40	60	60	95	130	130	130	130	150	150	150	150	150	150	150
Promag W	25..200	PFA	-40	60	60	95	130	130	130	130	130	130	130	130	130	130	130
Promag H	25..1000	HG	-20	60	60	80	80	80	80	80	80	80	80	80	80	80	80
	25..1000	PU	-40	60	60	95	130	130	130	130	130	130	130	130	130	130	130
	25..1000	PU	-20	60	60	95	130	130	130	130	130	130	130	130	130	130	130

**Notes:**  
 (1) T<sub>max</sub> = 40°C (for limitation see name plate)  
 (2) T<sub>max</sub> may be reduced by versions. For limitation of range for T<sub>max</sub> see name plate  
 (3) Promag H limited to T<sub>max</sub> = 50°C @ class T6 and T<sub>meas</sub> max = 50°C @ class T6 for optional versions available with medium temperature measurement

**Sensor of High temperature version with sensor not insulated**

Sensor	Size / DN	Liner	T <sub>meas</sub> [°C]	T <sub>max</sub> [°C]													
				T <sub>6</sub> (85°C)	T <sub>5</sub> (100°C)	T <sub>4</sub> (135°C)	T <sub>3</sub> (200°C)	T <sub>2</sub> (300°C)	T <sub>1</sub> (450°C)	T <sub>6</sub> (85°C)	T <sub>5</sub> (100°C)	T <sub>4</sub> (135°C)	T <sub>3</sub> (200°C)	T <sub>2</sub> (300°C)	T <sub>1</sub> (450°C)		
Promag P	15..600	PTFE	-40	60	60	95	130	130	130	130	150	150	150	150	150	150	150
Promag W	25..200	PFA	-40	60	60	95	130	130	130	130	130	130	130	130	130	130	130
Promag H	25..1000	HG	-20	60	60	80	80	80	80	80	80	80	80	80	80	80	80
	25..1000	PU	-40	60	60	95	130	130	130	130	130	130	130	130	130	130	130
	25..1000	PU	-20	60	60	95	130	130	130	130	130	130	130	130	130	130	130

**Notes:**  
 (1) T<sub>max</sub> = 40°C (for limitation see name plate)  
 (2) T<sub>max</sub> may be reduced by versions. For limitation of range for T<sub>max</sub> see name plate

**Sensor of High temperature version with sensor insulated (insulation not in compliance to manual of E+H Flowtec)**

Sensor	Size / DN	Liner	T <sub>meas</sub> [°C]	T <sub>max</sub> to be measured at reference point at sensor face [°C]													
				T <sub>6</sub> (85°C)	T <sub>5</sub> (100°C)	T <sub>4</sub> (135°C)	T <sub>3</sub> (200°C)	T <sub>2</sub> (300°C)	T <sub>1</sub> (450°C)	T <sub>6</sub> (85°C)	T <sub>5</sub> (100°C)	T <sub>4</sub> (135°C)	T <sub>3</sub> (200°C)	T <sub>2</sub> (300°C)	T <sub>1</sub> (450°C)		
Promag P	all	PTFE	-40	60	60	93,8	130	130	130	130	130	130	130	130	130	130	130
Promag W	all	PFA	-40	60	60	93,8	130	130	130	130	130	130	130	130	130	130	130
Promag H	all	HG	-20	60	60	80	80	80	80	80	80	80	80	80	80	80	80
	all	PU	-40	60	60	93,8	130	130	130	130	130	130	130	130	130	130	130
	all	PU	-20	60	60	93,8	130	130	130	130	130	130	130	130	130	130	130

**Notes:**  
 (1) T<sub>max</sub> = 40°C (for limitation see name plate)  
 (2) location of reference point

reference point

**Transmitter for all versions:**

Version	T <sub>max</sub>
T6 (85°C)	T5 (100°C)
55	60

**Notes:**  
 (1) T<sub>max</sub> = -50°C (for limitation see name plate)

**Control Drawing ICEX, ATEX, CSA, cCSAus**  
 Zone 1, Zone 21, CII Div. 1, CIII, CIIII, CII Zone 1  
 Thermal Parameter  
 Proline Promag 300/500

**Revision History:**

Aenderungen:	A	B	C	D	E
10.03.2018 / Bn					
24.10.2018 / Bn					
03.05.2017 / Bn					
15.02.2018 / Bn					

**Approval:** FES0260D 2/3

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands



# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
 Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500  
 Applicant: Endress+Hauser Flowtec AG



### Proline Promag H/P/W 500

Notes: This page applies to versions with extended order code covering:

5/H/P/5B\*\* - dd\*\*\*\*\*A...  
 5W/5B\*\* - dd\*\*\*\*\*A...  
 with approval option  
 CCSAUS / CSA: dd = CN, C6  
 IECEX / ATEX: dd = B1, BN

05/H/P/5B\*\* - dd\*\*\*\*\*A...  
 05W/5B\*\* - dd\*\*\*\*\*A...  
 5x5Bxx - dd\*\*\*\*\*A...  
 05x5Bxx - dd\*\*\*\*\*A...

5x5Bxx - dd\*\*\*\*\*A...  
 05x5Bxx - dd\*\*\*\*\*A...

05x5Bxx - dd\*\*\*\*\*A...  
 05x5Bxx - dd\*\*\*\*\*A...

#### Sensor of Standard version with sensor not insulated

Sensor	Size / DN	Liner	T <sub>max</sub> [°C]	T <sub>max</sub> [°C]											
				T6	T5	T4	T3	T2	T1	T6	T5	T4	T3	T2	T1
Promag P	15...600	PTFE	-40	60	80	95	130	150	150	130	130	130	130	130	130
	25...200	PFA	-40	50	50	95	130	150	150	150	150	150	150	150	
Promag W	50...3000	HG	-20	60	80	80	95	130	130	130	130	130	130	130	
	25...1000	PU	-20	50	50	50	50	50	50	50	50	50	50	50	
Promag H	2...150	PFA	-40	45	80	95	130	150	150	150	150	150	150	150	
	60	PU	-20	45	80	95	135	135	135	135	135	135	135	135	

Notes: (1) T<sub>min</sub> = -40°C (for limitation see name plate)  
 (2) T<sub>max</sub> may be reduced by versions. For limitation of range for T<sub>max</sub> see name plate  
 (3) Promag H limited to T<sub>max</sub> = 50°C @ class T6 and T<sub>max</sub> = 50°C @ class T5 for optional versions available with medium temperature measurement

#### Sensor of High temperature version with sensor not insulated:

Sensor	Size / DN	Liner	T <sub>max</sub> [°C]	T <sub>max</sub> [°C]										
				T6	T5	T4	T3	T2	T1	T6	T5	T4	T3	T2
Promag P	15...600	PTFE	-40	60	80	95	130	130	130	130	130	130	130	130
	25...200	PFA	-40	60	80	95	130	150	150	150	150	150	150	
Promag W	50...3000	HG	-20	60	80	80	95	130	130	130	130	130	130	
	25...1000	PU	-20	50	50	50	50	50	50	50	50	50	50	

Notes: (1) T<sub>min</sub> = -40°C (for limitation see name plate)  
 (2) T<sub>max</sub> may be reduced by versions. For limitation of range for T<sub>max</sub> see name plate

#### Transmitter for all versions:

Type of enclosure	Ordinary location (°C)	T <sub>min</sub>	T <sub>5</sub>	T <sub>4</sub>
aluminum	60	---	45	60
plastic	60	---	---	---

Notes: (1) aluminum enclosure: T<sub>min</sub> = -50°C (for limitation see name plate)  
 (2) plastic enclosure: T<sub>min</sub> = -40°C

#### Sensor of High temperature version with sensor insulated (for insulation refer to manual of E+H Flowtec)

Sensor	Size / DN	Liner	T <sub>max</sub> [°C]	T <sub>max</sub> [°C]										
				T6	T5	T4	T3	T2	T1	T6	T5	T4	T3	T2
Promag P	15...600	PTFE	-40	60	80	75	95	130	130	130	130	130	130	130
	25...200	PFA	-40	60	75	95	130	130	130	130	130	130	130	
Promag W	50...3000	HG	-20	60	80	75	95	130	130	130	130	130	130	
	25...1000	PU	-20	50	50	50	50	50	50	50	50	50	50	

Notes: (1) T<sub>min</sub> = -40°C (for limitation see name plate)  
 (2) T<sub>max</sub> may be reduced by versions. For limitation of range for T<sub>max</sub> see name plate

#### Sensor of High temperature version with sensor insulated (insulation not in compliance to manual of E+H Flowtec):

Sensor	Size / DN	Liner	T <sub>max</sub> [°C]	T <sub>max</sub> [°C]										
				T6	T5	T4	T3	T2	T1	T6	T5	T4	T3	T2
Promag P	all	PTFE	-40	60	80	130	63.8	63.7	69	70.9	70.9	70.9	70.9	70.9
		PFA	-40	60	130	63.8	63.7	69	70.9	70.9	70.9	70.9	70.9	
Promag W	all	HG	-20	60	80	50	63.8	63.7	69	70.9	70.9	70.9	70.9	
		PU	-20	50	50	50	63.8	63.7	69	70.9	70.9	70.9	70.9	

Notes: (1) T<sub>min</sub> = -40°C (for limitation see name plate)  
 (2) location of reference point



Änderungen:	A	B	C	D	E	F
Änderungen:	11.10.2018/18/Bn	24.10.2018/Bn	03.08.2017/Bn	15.02.2018/Bn	15.02.2018/Bn	15.02.2018/Bn
Alle gezeigten Änderungen vorbehalten.	Datei Zeichnung darf ohne unsere Genehmigung nicht verändert werden (von dieser Version und Konstruktoren zugängiger Serviceversion)					
Control Drawing IECEX, ATEX, CSA, cCSAus	Zone 1, Zone 21, CII, Div. 1, CIII, CIIII, CII Zone 1					
Thermal Parameter	Proline Promag 300/500					
Erstellt durch:	Gerdien					
Erstellt für:	E+H/IE/FES/Bn					
Erstellt am:	15.02.2018					
Geprüft:	Gerdien					
Geprüft am:	15.02.2018					
Gezeichnet:	Gerdien					
Gezeichnet am:	15.02.2018					

**E+H** Flowtec AG, Käpenstrasse 7, CH-4153 Reinach, BL 1, Postfach

**FES0260D 3/3**

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
 Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500  
 Applicant: Endress+Hauser Flowtec AG



## 4 Proline Prosonic Flow 300/500

### 4.1 Marking

Proline Prosonic Flow G 300				
Model Code: 9*3*** – dd*ff*****+##*# 09*3*** – dd*ff*****+##*#				
dd = Approval	ff = I/O	ATEX marking		Marking of Ex protection
BB	CA, CB, CC, CD, HA, TA	⊕ II2(1)G		Ex db eb ia [ia Ga] IIC T6...T1 Gb
		⊕ II2(1)D		Ex tb [ia Da] IIIC T** °C Db
BD	BA, BB, GA, LA, NA, RA, SA, MA	⊕ II2G		Ex db eb ia IIC T6...T1 Gb
		⊕ II2D		Ex tb IIIC T** °C Db
BD	CA, CB, CC, CD, HA, TA	⊕ II2(1)G		Ex db ia [ia Ga] IIC T6...T1 Gb
		⊕ II2(1)D		Ex tb [ia Da] IIIC T** °C Db
BD	BA, BB, GA, LA, NA, RA, SA, MA	⊕ II2G		Ex db ia IIC T6...T1 Gb
		⊕ II2D		Ex tb IIIC T** °C Db

Proline Prosonic Flow G 500 with ISEM integrated in sensor				
Model Code: 5*5*** – dd*ff****A*****+##*# 05*5*** – dd*ff****A*****+##*#				
dd = Approval	ff = I/O	Device	ATEX marking	Marking of Ex protection transmitter
BJ and BN	HA, TA, BA, BB, GA, LA, NA, RA, SA, MA, CA, CB, CC, CD	Sensor	⊕ II2G	Ex db ia IIC T6...T1 Gb
			⊕ II2D	Ex ia tb IIIC T** °C Db

Proline Prosonic Flow P 500 with ISEM integrated in transmitter				
ii. Model Code: 9P5*** – dd*ff***B*****+##*# 09P5*** – dd*ff***B*****+##*#				
iii. DK9013 – dd***** ODK9013 – dd*****				
dd = Approval	ff = I/O	Device	ATEX marking	Marking of Ex protection
BB	CA, CB, CC, CD, HA, TA, BA, BB, GA, LA, NA, RA, SA, MA	Transmitter	⊕ II2(1)G	Ex db eb ia [ia Ga] IIC T6... T5 Gb
			⊕ II2(1)D	Ex tb [ia Da] IIIC T85°C Db
BD	CA, CB, CC, CD, HA, TA, BA, BB, GA, LA, NA, RA, SA, MA	Sensor	⊕ II2G	Ex ia IIC T6...T1 Gb
			⊕ II2D	Ex ia IIIC T** °C Db
BD	CA, CB, CC, CD, HA, TA, BA, BB, GA, LA, NA, RA, SA, MA	Transmitter	⊕ II2(1)G	Ex db ia [ia Ga] IIC T6... T5 Gb
			⊕ II2(1)D	Ex tb [ia Da] IIIC T85°C Db
BD	CA, CB, CC, CD, HA, TA, BA, BB, GA, LA, NA, RA, SA, MA	Sensor	⊕ II2G	Ex ia IIC T6...T1 Gb
			⊕ II2D	Ex ia IIIC T** °C Db

### 4.2 Order Code

xtended order code Proline Prosonic Flow G 300:

9G3bcc – ddeffghjlpstuuuvww + ##\*#

09G3bcc – ddeffghjlpstuuuvwwyy + ##\*#

for OEM-versio

Extended order code Proline Prosonic Flow G 500:

9G5bcc – ddeffghijkmnopsstuuuvww + ##\*#

09G5bcc – ddeffghijkmnopsstuuuvwwyy + ##\*#

for OEM-version

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500  
Applicant: Endress+Hauser Flowtec AG

---



- a = Type of sensor**  
G = Prosonic Flow G
- b = Generation**  
B = Generation of Flowmeter
- cc = Size**  
any double digits with combination of number or letter
- dd = Approval**  
Proline Prosonic Flow 300:  
BB = Ex db eb [ia] IIC T6...T1 Gb  
Ex tb IIIC T\*\* Db  
BD = Ex db [ia] IIC T6...T1 Gb  
Ex tb IIIC T\*\* Db
- Proline Prosonic Flow 500:  
BJ = [Ex ia] IIC (transmitter)  
Ex ia IIC T6...T1 Gb (sensor)  
Ex tb IIIC T\*\* Db (sensor)  
BN = [Ex ia] IIC (transmitter)  
Ex ia IIC T6...T1 Gb (sensor)  
Ex tb IIIC T\*\* Db (sensor)
- e = Power Supply**  
D = 24Vdc  
E = 100-230Vac  
I = 100-230Vac / 24Vdc  
X = sensor only
- ff = Input / Output 1**  
BA = 4-20mA HART  
BB = 4-20mA WHART  
CA = 4-20mA HART Ex i (passive)  
CB = 4-20mA WHART Ex i (passive)  
CC = 4-20mA HART Ex i (active)  
CD = 4-20mA WHART Ex i (active)  
GA = Profibus PA  
HA = Profibus PA Ex i  
LA = Profibus DP  
NA = EtherNet/IP  
RA = Profinet IO  
SA = Foundation Fieldbus  
TA = Foundation Fieldbus Ex i  
MA = Modbus RS485  
X = sensor only

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
Utrechtseweg 310,  
6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

---

- g = Input / Output 2**  
A = without Input/Output 2  
B = 4-20mA  
C = 4-20mA Ex i (passive)  
D = Configurable IO  
E = Pulse/Frequency/Switch output  
F = Pulse output phase-shifted  
G = Pulse/Frequency/Switch output Ex i  
H = Relay  
I = 4-20mA input  
J = Status input  
K = Pulse output Ex i  
L = Pulse output  
X = sensor only
- h = Input / Output 3**  
A = without Input/Output 3  
B = 4-20mA  
C = 4-20mA Ex i (passive)  
D = Configurable IO  
E = Pulse/Frequency/Switch output  
  
F = Pulse output phase-shifted  
G = Pulse/Frequency/Switch output Ex i  
H = Relay  
I = 4-20mA input  
J = Status input  
K = Pulse output Ex i  
L = Pulse output  
X = sensor only
- i = Input / Output 4 (Proline 500 only)**  
A = without Input/Output 4  
B = 4-20mA  
C = 4-20mA Ex i (passive)  
D = Configurable IO  
E = Pulse/Frequency/Switch output  
F = Pulse output phase-shifted  
G = Pulse/Frequency/Switch output Ex i  
H = Relay  
I = 4-20mA input  
J = Status input  
K = Pulse output Ex i  
L = Pulse output  
X = sensor only
- j = Display / Operation**  
with remote Display : O  
without remote Display : any single number or letter except O

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
Utrechtseweg 310,  
6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

- k = **Integrated ISEM electronic** (Proline 500 only)  
A = Sensor
- l = **Housing** (Proline 300 only)  
any single number or letter
- m = **Transmitter Housing** (Proline 500 only)  
any single number or letter
- n = **Sensor Housing** (Proline 500 only)  
any single number or letter
- o = **Cable Sensor Connection** (Proline 500 only)  
any single number or letter
- p = **Cable Entry**  
any single number or letter
- qq = **Upgrade Kit**  
any double digits with combination of number or letter
- rr = **Existing Product** (refer to section 3.3 for assignment table of flowmeter to replacement transmitter)  
any double digits with combination of number or letter
- ss = **Measuring tube material, sensor version**  
any double digits with combination of number or letter
- t = **Pressure component**  
any single number or letter
- uuu = **Process connection**  
any triple digits with combination of number or letter
- v = **Calibration**  
any single number or letter
- ww = **Device model (two digit)** (refer to section 3.3 for assignment table of flowmeter to replacement transmitter)  
A1 = product version 1
- yy = **Customer version (two digits)**  
any double digits with combination of number or letter
- \*\* = **Option in two digits (none, two or multiple of two digits)**  
any combination of number and/or letter
- #, + = **Signs used as indicator for optional abbreviation of extended order code**

Extended order code Proline Prosonic Flow P 500:

9P5bcc – ddeffghjkmoqrsstww + ###  
09P5bcc – ddeffghjkmoqrsstwwyy + ### for OEM-version  
9x5bxx – ddeffghjkmnopppqww + ### for replacement transmitter  
09x5bxx – ddeffghjkmnopppqwwyy + ### for replacement transmitter OEM

- b = **Generation**  
B = Generation of Flowmeter
- cc = **Mounting Type**  
any double digits with combination of number and/or letter

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
Utrechtseweg 310,  
6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500  
Applicant: Endress+Hauser Flowtec AG

---



- dd = **Approval Transmitter**
  - BB = Ex db eb [ia] IIC T6...T1 Gb  
Ex tb IIIC T\*\* Db
  - BD = Ex db [ia] IIC T6...T1 Gb  
Ex tb IIIC T\*\* Db
  
- e = **Power Supply**
  - D = 24Vdc
  - E = 100-230Vac
  - I = 100-230Vac / 24Vdc
  
- ff = **Input / Output 1**
  - BA = 4-20mA HART
  - BB = 4-20mA WHART
  - CA = 4-20mA HART Ex i (passive)
  - CB = 4-20mA WHART Ex i (passive)
  - CC = 4-20mA HART Ex i (active)
  - CD = 4-20mA WHART Ex i (active)
  - GA = Profibus PA
  - HA = Profibus PA Ex i
  - LA = Profibus DP
  - NA = EtherNet/IP
  - RA = Profinet IO
  - SA = Foundation Fieldbus
  - TA = Foundation Fieldbus Ex i
  - MA = Modbus RS485
  
- g = **Input / Output 2**
  - A = without Input/Output 2
  - B = 4-20mA
  - C = 4-20mA Ex i (passive)
  - D = Configurable IO
  - E = Pulse/Frequency/Switch output
  - F = Pulse output phase-shifted
  - G = Pulse/Frequency/Switch output Ex i
  - H = Relay
  - I = 4-20mA input
  - J = Status input
  - K = Pulse output Ex i
  - L = Pulse output
  
- h = **Input / Output 3**
  - A = without Input/Output 3
  - B = 4-20mA
  - C = 4-20mA Ex i (passive)
  - D = Configurable IO
  - E = Pulse/Frequency/Switch output

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
Utrechtseweg 310,  
6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500  
Applicant: Endress+Hauser Flowtec AG

---



- F = Pulse output phase-shifted
- G = Pulse/Frequency/Switch output Ex i
- H = Relay
- I = 4-20mA input
- J = Status input
- K = Pulse output Ex i
- L = Pulse output
- i = Input / Output 4**
  - A = without Input/Output 4
- j = Display / Operation**
  - any single number or letter
- k = Integrated ISEM electronic**
  - B = transmitter
- m = Transmitter Housing**
  - any single number or letter
- n = Cable Sensor Connection**
  - any single number or letter
- o = Cable Entry**
  - any single number or letter
- pp = Existing Product** (see assignment of flowmeter to replacement transmitter)
  - PA = Prosonic Flow P 500
- qq = Sensor type**
  - any double digits with combination of number and/or letter
- r = Process Temperature**
  - any single number or letter
- ss = Cable**
  - any double digits with combination of number and/or letter
- tt = Installation set**
  - any double digits with combination of number and/or letter
- ww = Device model (two digit)** (see assignment of flowmeter to replacement transmitter)
  - A2 = product version 2
- yy = Customer version (two digits)**
  - any double digits with combination of number or letter
- \*\* = Option in two digits (none, two or multiple of two digits)**
  - any combination of number and/or letter
- #, + = Signs used as indicator for optional abbreviation of extended order code**

Extended order code Proline Prosonic Flow P 500 Clamp-On sensor:  
DK9013 – cddqrrttssww + #\*\*#  
ODK9013 – cddqrrttsswwyy + #\*\*# for OEM-version

- c = Alteration Kit**
  - any single number or letter

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
Utrechtseweg 310,  
6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

---

- dd** = **Approval**  
Proline Prosonic Flow P 500:  
BB = Ex db eb [ia] IIC T6...T1 Gb  
Ex tb IIIC T\*\* Db  
BD = Ex db [ia] IIC T6...T1 Gb  
Ex tb IIIC T\*\* Db
- qq** = **Sensor type**  
any double digits with combination of number and/or letter
- r** = **Process Temperature**  
any single number or letter
- tt** = **Cable**  
any single number or letter
- ss** = **Installation set**  
any double digits with combination of number and/or letter
- ww** = **Device model (two digit) (see assignment of flowmeter to replacement transmitter)**  
A2 = product version 2
- yy** = **Customer version (two digits)**  
any double digits with combination of number or letter
- \*\*** = **Option in two digits (none, two or multiple of two digits)**  
any combination of number and/or letter
- #, +** = **Signs used as indicator for optional abbreviation of extended order code**

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
Utrechtseweg 310,  
6812 AR, Arnhem Netherlands



# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
 Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

## 4.3 Assignment of Flowmeter to Replacement Transmitter

The replacement transmitters are assigned to the flowmeter Proline Prosonic Flow G 300/500 as follows:

Product flowmeters			Replacement transmitter type			
model code	Generation code b =	device model code ww =	model code	Generation code b =	existing product pp =	device model code ww =
9G*b**-...ww, 09G*b**-...ww	B	A1 / A2	9x*bxx-...pp...ww, 09x*bxx-...pp...ww	B	AA	A1 / A2
9P*b**-...ww, 09P*b**-...ww	B	A1 / A2	9x*bxx-...pp...ww, 09x*bxx-...pp...ww	B	AB	A1 / A2

## 4.4 Parameters

### 4.4.1 Electrical Parameters

Power Supply	terminal no.	values
Order Code e =		
D <sup>1)</sup>	No. 1(L+/L), 2(L-/N)	U <sub>N</sub> = 19.2...28.8V <sub>DC</sub> U <sub>M</sub> = 250Vac
E <sup>1)</sup>	No. 1(L+/L), 2(L-/N)	U <sub>N</sub> = 85...264V <sub>AC</sub> U <sub>M</sub> = 250Vac
I <sup>2)</sup>	No. 1(L+/L), 2(L-/N)	U <sub>N</sub> = 19.2...28.8V <sub>DC</sub> /85...264V <sub>AC</sub> U <sub>M</sub> = 250 V

7) applicable for products with approval code dd = BA, BB, BC, BD, B7, B8

8) applicable for products with approval code dd = BI, BJ, BM, BN

Input/Output 1	terminal no.	values
Order Code ff =		
BA, BB, MA	No. 26, 27	U <sub>N</sub> = 30V <sub>DC</sub> U <sub>M</sub> = 250Vac
LA, GA, SA	No. 26, 27	U <sub>N</sub> = 32V <sub>DC</sub> U <sub>M</sub> = 250Vac
CA, CB	No. 26, 27	U <sub>i</sub> = 30V I <sub>i</sub> = 100mA P <sub>i</sub> = 1.25W L <sub>i</sub> = 0 C <sub>i</sub> = 0

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X

Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

Input/Output 1			
Order Code ff =	terminal no.	values	
CC, CD	No. 26, 27	1) U <sub>o</sub> = 21.8V I <sub>o</sub> = 90mA P <sub>o</sub> = 491mW L <sub>o</sub> = 4.1mH (IIC) / 15mH (IIB) C <sub>o</sub> = 160nF (IIC) / 1160nF (IIB)  U <sub>i</sub> = 30V I <sub>i</sub> = 10mA P <sub>i</sub> = 0.3W C <sub>i</sub> = 6nF L <sub>i</sub> = 4.1mH	2) U <sub>o</sub> = 21.8V I <sub>o</sub> = 90mA P <sub>o</sub> = 491mW L <sub>o</sub> = 9mH (IIC) / 39mH (IIB) C <sub>o</sub> = 600nF (IIC) / 4000nF (IIB)  U <sub>i</sub> = 30V I <sub>i</sub> = 10mA P <sub>i</sub> = 0.3W C <sub>i</sub> = 6nF L <sub>i</sub> = 4.1mH
HA, TA	No. 26, 27	1) <u>Profibus PA (Fisco Field Device) / Foundation Fieldbus</u> U <sub>i</sub> = 30V I <sub>i</sub> = 570mA P <sub>i</sub> = 8.5W L <sub>i</sub> = 10μH C <sub>i</sub> = 5nF	2) <u>Profibus PA (Fisco Field Device) / Foundation Fieldbus</u> U <sub>i</sub> = 32V I <sub>i</sub> = 570mA P <sub>i</sub> = 8.5W L <sub>i</sub> = 10μH C <sub>i</sub> = 5nF
NA, RA	IO1 / RJ45	U <sub>N</sub> = 30V <sub>DC</sub> U <sub>M</sub> = 250V <sub>AC</sub>	

<sup>1)</sup> applicable for products with approval code dd = BB, BD, B7, B8

<sup>2)</sup> applicable for products with approval code dd = BM, BN

Input/Output 2			
Order Code g =	terminal no.	values	
C, G, K	No. 24, 25	U <sub>i</sub> = 30V I <sub>i</sub> = 100mA P <sub>i</sub> = 1.25W L <sub>i</sub> = 0 C <sub>i</sub> = 0	
B, D, E, F, I, J, L	No. 24, 25	U <sub>N</sub> = 30V <sub>DC</sub> U <sub>M</sub> = 250V <sub>AC</sub>	
H	No. 24, 25	U <sub>N</sub> = 30V <sub>DC</sub> I <sub>N</sub> = 100mA <sub>DC</sub> / 500mA <sub>AC</sub> U <sub>M</sub> = 250V <sub>AC</sub>	

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
Utrechtseweg 310,  
6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X

Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

Input/Output 3		
Order Code h =	terminal no.	values
C, G, K	No. 22, 23	U <sub>i</sub> = 30V I <sub>i</sub> = 100mA P <sub>i</sub> = 1.25W L <sub>i</sub> = 0 C <sub>i</sub> = 0
B, D, E, F, I, J, L	No. 22, 23	U <sub>N</sub> = 30V <sub>DC</sub> U <sub>M</sub> = 250V <sub>ac</sub>
H	No. 22, 23	U <sub>N</sub> = 30V <sub>DC</sub> I <sub>N</sub> = 100mA <sub>DC</sub> / 500mA <sub>AC</sub> U <sub>M</sub> = 250V <sub>ac</sub>

Input/Output 4		
Order Code i =	terminal no.	values
C, G, K	No. 20, 21	U <sub>i</sub> = 30V I <sub>i</sub> = 100mA P <sub>i</sub> = 1.25W L <sub>i</sub> = 0 C <sub>i</sub> = 0
B, D, E, F, I, J, L	No. 20, 21	U <sub>N</sub> = 30V <sub>DC</sub> U <sub>M</sub> = 250V <sub>ac</sub>
H	No. 20, 21	U <sub>N</sub> = 30V <sub>DC</sub> I <sub>N</sub> = 100mA <sub>DC</sub> / 500mA <sub>AC</sub> U <sub>M</sub> = 250V <sub>ac</sub>

Service Interface		
Order Code dd =	terminal no.	values
BB, BD, B7, B8	Service Interface	Service Interface shall only be installed in areas which are known to be non hazardous
not for: BB, BD, B7, B8	Service Interface	U <sub>N</sub> = 3.3V

Antenna bushing		
Order Code dd =	terminal no.	values
BB, BJ, BN, B7	N connector	See conditions of safe use

Display remote		
Order Code dd =	terminal no.	values
BB, BD, B7, B8	No. 81, 82, 83, 84	U <sub>o</sub> = 3.9V I <sub>o</sub> = 1.5A (spark) 200mA (power)

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
Utrechtseweg 310,  
6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

		Po = 600mW Ri = 2.6Ω Co = 670μF Lo = 0
not for: BB, BD, B7, B8	No. 81, 82, 83, 84	UN = 3.3V IN = 150mA

For Transmitter with approval code dd = BB, BD, B7 and B8 connected to the Remote Display of Endress+Hauser, Type DKX001 or ODKX001, the cable parameter with ration L/R =  $\leq 0.024$  mH/Ω applies.

### Proline Prosonic Flow G Remote Transmitter and Remote Sensor:

9G\*\*\*\*-... and O9G\*\*\*\*-... with order code dd = BJ, BN, in combination with k = A:

Transmitter:

terminals 61, 62 ->  $U_N = 35V$   
terminals 63, 64 ->  $U_N = 3.3V$

Sensor:

terminals 61, 62 ->  $U_N = 35V$   
terminals 63, 64 ->  $U_N = 3.3V$

### Proline Prosonic Flow P Remote Transmitter and Remote Sensor:

9P\*\*\*\*-... and O9P\*\*\*\*-... with order code dd = BB, BD in combination with k = B:

Transmitter:

CH1, CH2 ->  $U_o = 40V$ ,  $I_o = 36.7mA$ ,  $P_o = 459mW$ ,  $L_i = n.a.$ ,  $C_i = n.a.$

Sensor:

Connector ->  $U_i = 40V$ ,  $I_i = n.a.$ ,  $P_i = n.a.$ ,  $L_i = n.a.$ ,  $C_i = n.a.$

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
 Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500  
 Applicant: Endress+Hauser Flowtec AG



## 4.4.2 Thermal Parameters (Zone 1)

**Proline Prosonic Flow G 300**

Notes:  
This page applies to versions with extended order code covering:  
9\*3B\*\* - dd... 9x3Bxx - dd...  
with approval option cCSAus / CSA: dd = CD, CE, C2, C4  
IECEX / ATEX: dd = BB, BD

**Temperature table for versions with sensor insulated and not insulated**  
(for insulation refer to manual of Endress+Hauser Flowtec)

Size / DN	T <sub>amb</sub>		T <sub>max</sub>		T <sub>code max</sub> [°C]						
	min [°C]	max [°C]	T6	T5	T4	T3	T2	T1	T2	T1	
25 ... 300	-50	90	40	40	40	90	90	90	90	90	90
			40	40	40	90	90	90	90	90	90
			55	—	—	—	—	—	—	—	—
			80	—	—	—	—	—	—	—	—
			45 (1)	70	65	120	150	150	150	150	150
			55 (1)	—	65	120	150	150	150	150	150
			60 (1)	—	65	120	150	150	150	150	150
			60 (1)	—	65	120	150	150	150	150	150

Notes:  
(1) Temperature not applicable for versions with sensor insulated  
(2) T<sub>amb</sub> = -40°C, -50°C respectively (see nomenclature)  
(3) values in brackets are applicable for installation where the transmitter is not installed above the sensor

**Temperature table for versions with sensor insulated**  
(for insulation not in compliance to manual of Endress+Hauser Flowtec)

Size / DN	T <sub>max</sub> to be measured at reference point at sensor neck [°C]					
	T6	T5	T4	T3	T2	T1
all	68	69	72	74	74	74
	68	69	72	74	74	74

Notes:  
(1) for versions with pressure sensor, the pressure sensor shall not be insulated  
(2) for safe use temperatures shall not exceed all of the following:  
- temperature table for versions with sensor not insulated (refer to table above)  
- temperature at reference point as listed in this table  
- T<sub>amb</sub> = -40°C, -50°C respectively (see nomenclature)  
- for maximum medium temperature and minimum medium temperature see nomenclature  
(3) versions with pressure sensor shall not exceed temperatures as listed in table besides for insulated and not insulated sensor  
(4) location of reference point

reference point

A	22.02.2018	Bn	E	Date	Date	Date	Date
B			S	Chief	Chief	Chief	Chief
C			H	Engineering	Engineering	Engineering	Engineering
D			L	design	design	design	design
E			K	approval	approval	approval	approval

Control Drawing IECEX, ATEX, CSA, cCSAus  
 Zone 1, Zone 2I, CII Div. 1, CIII, CIII, CII Zone 1  
 Thermal Parameter  
 Proline Prosonic Flow G 300/500

<p>Flowtec AG, Käpenstrasse 7, CH-4113 Reinach, BL 1, Postfach</p>	<p><b>FES0321A</b></p> <p>1/2</p>
--	-----------------------------------

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands

Page 55 of 66

Form 9400 Issue4

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
 Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500  
 Applicant: Endress+Hauser Flowtec AG



<p><b>Proline Prosonic Flow G 500</b></p> <p>Notes:                  This page applies to versions with extended order code covering:                  9*5*** - dd*****A... 09*5*** - dd*****A... 9x5Bxx - dd*****A... 09x5Bxx - dd*****A...                  with approval option cCSAus / CSA: dd = CN, O6                  IECEX / ATEX: dd = RL, BN</p>																																																																	
<p><b>Sensor: Temperature table for versions with sensor insulated and not insulated</b>                  (for insulation refer to manual of Endress+Hauser Flowtec)</p> <table border="1"> <thead> <tr> <th rowspan="2">Size / DN</th> <th colspan="2">T<sub>max</sub></th> <th colspan="2">T<sub>max</sub></th> <th colspan="2">T<sub>max</sub></th> <th colspan="2">T<sub>max</sub></th> <th colspan="2">T<sub>max</sub></th> <th colspan="2">T<sub>max</sub></th> </tr> <tr> <th>min [°C]</th> <th>max [°C]</th> <th>T6 (85°C)</th> <th>T5 (100°C)</th> <th>T4 (135°C)</th> <th>T3 (200°C)</th> <th>T2 (300°C)</th> <th>T1 (450°C)</th> <th>T6 (85°C)</th> <th>T5 (100°C)</th> <th>T4 (135°C)</th> <th>T3 (200°C)</th> </tr> </thead> <tbody> <tr> <td>25...300</td> <td>-50</td> <td>90</td> <td>40</td> <td>40</td> <td>40</td> <td>90</td> <td>90</td> <td>90</td> <td>90</td> <td>90</td> <td>90</td> <td>90</td> </tr> <tr> <td></td> <td></td> <td></td> <td>55</td> <td>40</td> <td>40</td> <td>90</td> <td>90</td> <td>90</td> <td>90</td> <td>90</td> <td>90</td> <td>90</td> </tr> <tr> <td></td> <td></td> <td></td> <td>60</td> <td>70</td> <td>85</td> <td>120</td> <td>150</td> <td>150</td> <td>150</td> <td>150</td> <td>150</td> <td>150</td> </tr> </tbody> </table> <p>Notes:                  (1) temperatures not applicable for versions with pressure sensor                  (2) T<sub>max</sub> = -40°C, -50°C respectively (see nameplate)                  (3) for applicable version with maximum medium temperature and minimum medium temperature see nameplate</p>		Size / DN	T <sub>max</sub>		T <sub>max</sub>		T <sub>max</sub>		T <sub>max</sub>		T <sub>max</sub>		T <sub>max</sub>		min [°C]	max [°C]	T6 (85°C)	T5 (100°C)	T4 (135°C)	T3 (200°C)	T2 (300°C)	T1 (450°C)	T6 (85°C)	T5 (100°C)	T4 (135°C)	T3 (200°C)	25...300	-50	90	40	40	40	90	90	90	90	90	90	90				55	40	40	90	90	90	90	90	90	90				60	70	85	120	150	150	150	150	150	150
Size / DN	T <sub>max</sub>		T <sub>max</sub>		T <sub>max</sub>		T <sub>max</sub>		T <sub>max</sub>		T <sub>max</sub>																																																						
	min [°C]	max [°C]	T6 (85°C)	T5 (100°C)	T4 (135°C)	T3 (200°C)	T2 (300°C)	T1 (450°C)	T6 (85°C)	T5 (100°C)	T4 (135°C)	T3 (200°C)																																																					
25...300	-50	90	40	40	40	90	90	90	90	90	90	90																																																					
			55	40	40	90	90	90	90	90	90	90																																																					
			60	70	85	120	150	150	150	150	150	150																																																					
<p><b>Sensor: Temperature table for versions with sensor insulated</b>                  (for insulation not in compliance to manual of Endress+Hauser Flowtec)</p> <table border="1"> <thead> <tr> <th rowspan="2">Size / DN</th> <th colspan="2">T<sub>max</sub> to be measured at reference point at sensor neck [°C]</th> <th colspan="2">T<sub>max</sub> to be measured at reference point at sensor [°C]</th> <th colspan="2">T<sub>max</sub> to be measured at reference point at sensor [°C]</th> <th colspan="2">T<sub>max</sub> to be measured at reference point at sensor [°C]</th> </tr> <tr> <th>T6 (80°C)</th> <th>T5 (100°C)</th> <th>T4 (135°C)</th> <th>T3 (200°C)</th> <th>T2 (300°C)</th> <th>T1 (450°C)</th> <th>T6 (80°C)</th> <th>T5 (100°C)</th> </tr> </thead> <tbody> <tr> <td>all</td> <td>65</td> <td>71</td> <td>77</td> <td>77</td> <td>77</td> <td>77</td> <td>77</td> <td>77</td> </tr> </tbody> </table> <p>Notes:                  (1) for versions with pressure sensor the pressure sensor shall not be insulated for safe use temperatures shall not exceed all of the following:                  - temperature table for versions with sensor not insulated (refer to table above)                  - temperature at reference point as listed in this table                  - T<sub>min</sub> = -40°C, -50°C respectively (see nameplate)                  - for maximum medium temperature and minimum medium temperature see nameplate                  (2) versions with pressure sensor shall not exceed temperatures as listed in table beside for insulated and not insulated sensor                  (3) location of reference point                  (4) location of reference point</p>		Size / DN	T <sub>max</sub> to be measured at reference point at sensor neck [°C]		T <sub>max</sub> to be measured at reference point at sensor [°C]		T <sub>max</sub> to be measured at reference point at sensor [°C]		T <sub>max</sub> to be measured at reference point at sensor [°C]		T6 (80°C)	T5 (100°C)	T4 (135°C)	T3 (200°C)	T2 (300°C)	T1 (450°C)	T6 (80°C)	T5 (100°C)	all	65	71	77	77	77	77	77	77																																						
Size / DN	T <sub>max</sub> to be measured at reference point at sensor neck [°C]		T <sub>max</sub> to be measured at reference point at sensor [°C]		T <sub>max</sub> to be measured at reference point at sensor [°C]		T <sub>max</sub> to be measured at reference point at sensor [°C]																																																										
	T6 (80°C)	T5 (100°C)	T4 (135°C)	T3 (200°C)	T2 (300°C)	T1 (450°C)	T6 (80°C)	T5 (100°C)																																																									
all	65	71	77	77	77	77	77	77																																																									
<p><b>Transmitter for all versions</b></p> <table border="1"> <thead> <tr> <th rowspan="2">Type of enclosure</th> <th rowspan="2">Ordinary/location (°C)</th> <th colspan="4">T<sub>max</sub></th> </tr> <tr> <th>T6 (85°C)</th> <th>T5 (100°C)</th> <th>T4 (135°C)</th> <th>T3 (200°C)</th> </tr> </thead> <tbody> <tr> <td>aluminium</td> <td>60</td> <td>---</td> <td>45</td> <td>60</td> <td>---</td> </tr> <tr> <td>plastic</td> <td>60</td> <td>---</td> <td>---</td> <td>---</td> <td>---</td> </tr> </tbody> </table> <p>Notes: (1) aluminium enclosure: T<sub>max</sub> min = 50°C (for limitation see name plate)                  plastic enclosure: T<sub>max</sub> min = 40°C</p>		Type of enclosure	Ordinary/location (°C)	T <sub>max</sub>				T6 (85°C)	T5 (100°C)	T4 (135°C)	T3 (200°C)	aluminium	60	---	45	60	---	plastic	60	---	---	---	---																																										
Type of enclosure	Ordinary/location (°C)			T <sub>max</sub>																																																													
		T6 (85°C)	T5 (100°C)	T4 (135°C)	T3 (200°C)																																																												
aluminium	60	---	45	60	---																																																												
plastic	60	---	---	---	---																																																												
<p>Änderungen: A 22.02.2018 / Bn F Die Zeichnung untersuchen, korrigieren, Erneuert durch: 07.02.2018 Bn                  B G Die Zeichnung darf ohne unsere Erlaubnis nicht weiterverbreitet werden. Ersteller: FES / Bn                  C H Genehmigung wieder verweigert werden. FILE: M:\Zerlegung\FES0321A\FES0321A_SPC                  D J andere Personen und Konstruktoren zugebilligt gemacht werden.                  E K</p> <p>Control Drawing IECEX, ATEX, CSA, cCSAus                  Zone 1, Zone 21, CII Div. 1, CIII, CIIII, CII Zone 1                  Thermal Parameter                  Proline Prosonic Flow G 300/500</p>																																																																	
<p>Flowtec AG, Kaiserstrasse 7, CH-4153 Birmaholz, BL 1, Postfach</p>																																																																	
<p><b>FES0321A 2/2</b></p>																																																																	

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
 Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

## 5 Proline t-mass 300/500

### 5.1 Marking

Proline t-mass F/I 300			
Model Code: 6F3*** – dd*ff*****+###		O6F3*** – dd*ff*****+###	
6I3*** – dd*ff*****+###		O6I3*** – dd*ff*****+###	
dd = Approval	ff = I/O	ATEX marking	Marking of Ex protection
BB	CA, CB, CC, CD, HA, TA	⊕ II2(1)G ⊕ II1/2(1)G ⊕ II2(1)D	Ex db eb ia [ia Ga] IIC T4...T1 Gb Ex db eb ia [ia Ga] IIC T4...T1 Ga/Gb Ex tb [ia Da] IIIC T** °C Db
	BA, BB, GA, LA, NA, RA, SA, MA	⊕ II2G ⊕ II1/2G ⊕ II2D	Ex db eb ia IIC T4...T1 Gb Ex db eb ia IIC T4...T1 Ga/Gb Ex tb IIIC T** °C Db
BD	CA, CB, CC, CD, HA, TA	⊕ II2(1)G ⊕ II1/2(1)G ⊕ II2(1)D	Ex db ia [ia Ga] IIC T4...T1 Gb Ex db ia [ia Ga] IIC T4...T1 Ga/Gb Ex tb [ia Da] IIIC T** °C Db
	BA, BB, GA, LA, NA, RA, SA, MA	⊕ II2G ⊕ II1/2G ⊕ II2D	Ex db ia IIC T4...T1 Gb Ex db ia IIC T4...T1 Ga/Gb Ex tb IIIC T** °C Db

Proline t-mass F/I 500 with ISEM integrated in sensor				
Model Code: 6F5*** – dd*ff*****A*****+###		O6F5*** – dd*ff*****A*****+###		
6I5*** – dd*ff*****A*****+###		O6I5*** – dd*ff*****A*****+###		
dd = Approval	ff = I/O	Device	ATEX marking	Marking of Ex protection transmitter
BJ and BN	HA, TA, BA, BB, GA, LA, NA, RA, SA, MA, CA, CB, CC, CD	Transmitter	⊕ II(1)G ⊕ II(1)D	[Ex ia] IIC [Ex ia] IIIC
		Sensor	⊕ II2G ⊕ II1/2G ⊕ II2D	Ex db ia IIC T4...T1 Gb Ex db ia IIC T4...T1 Ga/Gb Ex ia tb IIIC T** °C Db

### 5.2 Order Code

Extended order code Proline t-mass 300:

6F3bcc – ddeffghjpsstttvww + ###  
 6I3bcc – ddeffghjpsstttuuvww + ###  
 O6F3bcc – ddeffghjpsstttvwwyy + ###  
 O6I3bcc – ddeffghjpsstttuuvwwyy + ###  
 6x3bxx – ddeffghjlpssww + ###  
 O6x3bxx – ddeffghjlpsswwyy + ###

for OEM-version  
 for OEM-version  
 for replacement transmitter  
 for replacement transmitter OEM

Extended order code Proline t-mass 500:

6F5bcc – ddeffghijkmnopsstttvww + ###  
 6I5bcc – ddeffghijkmnopsstttuuvww + ###  
 O6F5cc – ddeffghijkmnopsstttvwwyy + ###  
 O6I5cc – ddeffghijkmnopsstttuuvwwyy + ###  
 6x5bxx – ddeffghijkmpssww + ###  
 O6x5bxx – ddeffghijkmpsswwyy + ###

for OEM-version  
 for OEM-version  
 for replacement transmitter  
 for replacement transmitter OEM

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500  
Applicant: Endress+Hauser Flowtec AG

---



- b = Generation**  
B = Generation of Flowmeter
- cc = Size**  
any combination of number and/or letter up to size = DN100 (t-mass F) / 1500mm (t-mass I)
- dd = Approval**  
Proline t-mass 300:  
BB = Ex db eb [ia] IIC T4...T1 Gb  
Ex tb IIIC T\* Db  
BD = Ex db [ia] IIC T4...T1 Gb  
Ex tb IIIC T\* Db
- Proline t-mass 500:  
BJ = [Ex ia] IIC (transmitter)  
Ex db ia IIC T4...T1 Gb (sensor)  
Ex tb IIIC T\*\* Db (sensor)  
BN = [Ex ia] IIC (transmitter)  
Ex db ia IIC T4...T1 Gb (sensor)  
Ex tb IIIC T\* Db (sensor)
- e = Power Supply**  
D = 24Vdc  
E = 100-230Vac  
I = 100-230Vac / 24Vdc  
X = sensor only
- ff = Input / Output 1**  
BA = 4-20mA HART  
BB = 4-20mA WHART  
CA = 4-20mA HART Ex i (passive)  
CB = 4-20mA WHART Ex i (passive)  
CC = 4-20mA HART Ex i (active)  
CD = 4-20mA WHART Ex i (active)  
GA = Profibus PA  
HA = Profibus PA Ex i  
LA = Profibus DP  
MA = Modbus RS485  
NA = EtherNet/IP  
RA = Profinet IO  
SA = Foundation Fieldbus  
TA = Foundation Fieldbus Ex i  
XX = sensor only

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
Utrechtseweg 310,  
6812 AR, Arnhem Netherlands



# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500  
Applicant: Endress+Hauser Flowtec AG

---



- g = Input / Output 2**
  - A = without Input/Output 2
  - B = 4-20mA
  - C = 4-20mA Ex i (passive)
  - D = Configurable IO
  - E = Pulse/Frequency/Switch output
  - F = Pulse output phase-shifted
  - G = Pulse/Frequency/Switch output Ex i
  - H = Relay
  - I = 4-20mA input
  - J = Status input
  - K = Pulse output Ex i
  - L = Pulse output
  - X = sensor only
- h = Input / Output 3**
  - A = without Input/Output 3
  - B = 4-20mA
  - C = 4-20mA Ex i (passive)
  - D = Configurable IO
  - E = Pulse/Frequency/Switch output
  - F = Pulse output phase-shifted
  - G = Pulse/Frequency/Switch output Ex i
  - H = Relay
  - I = 4-20mA input
  - J = Status input
  - K = Pulse output Ex i
  - L = Pulse output
  - X = sensor only
- i = Input / Output 4 (Proline 500 only)**
  - A = without Input/Output 4
  - B = 4-20mA
  - C = 4-20mA Ex i (passive)
  - D = Configurable IO
  - E = Pulse/Frequency/Switch output
  - F = Pulse output phase-shifted
  - G = Pulse/Frequency/Switch output Ex i
  - H = Relay
  - I = 4-20mA input
  - J = Status input
  - K = Pulse output Ex i
  - L = Pulse output
  - X = sensor only
- j = Display / Operation**
  - with remote Display : O
  - without remote Display : any single number or letter except O
- k = Integrated ISEM electronic (Proline 500 only)**
  - A = SensorI

This certificate and its schedules may only be reproduced in its entirety and without change  
CSA Group Netherlands B.V.  
Utrechtseweg 310,  
6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
 Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

- l** = **Housing** (Proline 300 only)  
any single number or letter
- m** = **Transmitter Housing** (Proline 500 only)  
any single number or letter
- n** = **Sensor Housing** (Proline 500 only)  
any single number or letter
- o** = **Cable Sensor Connection** (Proline 500 only)  
any single number or letter
- p** = **Cable Entry**  
any single number or letter
- ss** = **material sensor**  
any double digits with combination of number or letter
- ttt** = **Process connection**  
any triple digits with combination of number or letter
- uu** = **gasket**  
any double number or letter
- v** = **Calibration**  
any single number or letter
- ww** = **Device Model (two digit)** (refer to section 4.3 for assignment table of flowmeter to replacement transmitter)  
A1 = product version 1
- yy** = **Customer version (two digits)**  
any double digits with combination of number or letter
- \*\*** = **Option in two digits (none, two or multiple of two digits)**  
any combination of number and/or letter
- #, +** = **Signs used as indicator for optional abbreviation of extended order code**

## 5.3 Assignment of Flowmeter to Replacement Transmitter

The replacement transmitters are assigned to the flowmeter Proline t-mass 300/500 as follows:

Product flowmeters			Replacement transmitter type			
model code	Generation code b =	device model code ww =	model code	Generation code b =	existing product rr =	device model code ww =
6F*b**-...ww, O6F*b**-...ww	B	A1	6x*bxx...ww, O6x*bxx...ww	B	n.a.	A1
6I*b**-...ww, O6I*b**-...ww	B	A1	6x*bxx-...ww, O6x*bxx-...ww	B	n.a.	A1

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
 Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

## 5.4 Parameters

### 5.4.1 Electrical Parameters

Power Supply		
Order Code e =	terminal no.	values
D <sup>1)</sup>	No. 1(L+/L), 2(L-/N)	U <sub>N</sub> = 19.2...28.8V <sub>DC</sub> U <sub>M</sub> = 250V <sub>AC</sub>
E <sup>1)</sup>	No. 1(L+/L), 2(L-/N)	U <sub>N</sub> = 85...264V <sub>AC</sub> U <sub>M</sub> = 250V <sub>AC</sub>
I <sup>2)</sup>	No. 1(L+/L), 2(L-/N)	U <sub>N</sub> = 19.2...28.8V <sub>DC</sub> / 85...264V <sub>AC</sub> U <sub>M</sub> = 250 V

9) applicable for products with approval code dd = BA, BB, BC, BD, B7, B8

10) applicable for products with approval code dd = BI, BJ, BM, BN

Input/Output 1																								
Order Code ff =	terminal no.	values																						
BA, BB, MA	No. 26, 27	U <sub>N</sub> = 30V <sub>DC</sub> U <sub>M</sub> = 250V <sub>AC</sub>																						
LA, GA, SA	No. 26, 27	U <sub>N</sub> = 32V <sub>DC</sub> U <sub>M</sub> = 250V <sub>AC</sub>																						
CA, CB	No. 26, 27	U <sub>i</sub> = 30V I <sub>i</sub> = 100mA P <sub>i</sub> = 1.25W L <sub>i</sub> = 0 C <sub>i</sub> = 0																						
CC, CD	No. 26, 27	<table border="0"> <tr> <td>1)</td> <td>2)</td> </tr> <tr> <td>U<sub>O</sub> = 21.8V</td> <td>U<sub>O</sub> = 21.8V</td> </tr> <tr> <td>I<sub>O</sub> = 90mA</td> <td>I<sub>O</sub> = 90mA</td> </tr> <tr> <td>P<sub>O</sub> = 491mW</td> <td>P<sub>O</sub> = 491mW</td> </tr> <tr> <td>L<sub>O</sub> = 4.1mH (IIC) / 15mH (IIB)</td> <td>L<sub>O</sub> = 9mH (IIC) / 39mH (IIB)</td> </tr> <tr> <td>C<sub>O</sub> = 160nF (IIC) / 1160nF (IIB)</td> <td>C<sub>O</sub> = 600nF (IIC) / 4000nF (IIB)</td> </tr> <tr> <td>U<sub>i</sub> = 30V</td> <td>U<sub>i</sub> = 30V</td> </tr> <tr> <td>I<sub>i</sub> = 10mA</td> <td>I<sub>i</sub> = 10mA</td> </tr> <tr> <td>P<sub>i</sub> = 0.3W</td> <td>P<sub>i</sub> = 0.3W</td> </tr> <tr> <td>C<sub>i</sub> = 6nF</td> <td>C<sub>i</sub> = 6nF</td> </tr> <tr> <td>L<sub>i</sub> = 4.1mH</td> <td>L<sub>i</sub> = 4.1mH</td> </tr> </table>	1)	2)	U <sub>O</sub> = 21.8V	U <sub>O</sub> = 21.8V	I <sub>O</sub> = 90mA	I <sub>O</sub> = 90mA	P <sub>O</sub> = 491mW	P <sub>O</sub> = 491mW	L <sub>O</sub> = 4.1mH (IIC) / 15mH (IIB)	L <sub>O</sub> = 9mH (IIC) / 39mH (IIB)	C <sub>O</sub> = 160nF (IIC) / 1160nF (IIB)	C <sub>O</sub> = 600nF (IIC) / 4000nF (IIB)	U <sub>i</sub> = 30V	U <sub>i</sub> = 30V	I <sub>i</sub> = 10mA	I <sub>i</sub> = 10mA	P <sub>i</sub> = 0.3W	P <sub>i</sub> = 0.3W	C <sub>i</sub> = 6nF	C <sub>i</sub> = 6nF	L <sub>i</sub> = 4.1mH	L <sub>i</sub> = 4.1mH
1)	2)																							
U <sub>O</sub> = 21.8V	U <sub>O</sub> = 21.8V																							
I <sub>O</sub> = 90mA	I <sub>O</sub> = 90mA																							
P <sub>O</sub> = 491mW	P <sub>O</sub> = 491mW																							
L <sub>O</sub> = 4.1mH (IIC) / 15mH (IIB)	L <sub>O</sub> = 9mH (IIC) / 39mH (IIB)																							
C <sub>O</sub> = 160nF (IIC) / 1160nF (IIB)	C <sub>O</sub> = 600nF (IIC) / 4000nF (IIB)																							
U <sub>i</sub> = 30V	U <sub>i</sub> = 30V																							
I <sub>i</sub> = 10mA	I <sub>i</sub> = 10mA																							
P <sub>i</sub> = 0.3W	P <sub>i</sub> = 0.3W																							
C <sub>i</sub> = 6nF	C <sub>i</sub> = 6nF																							
L <sub>i</sub> = 4.1mH	L <sub>i</sub> = 4.1mH																							

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
 Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

Input/Output 1																
Order Code ff =	terminal no.	values														
HA, TA	No. 26, 27	<table border="0"> <tr> <td>1)</td> <td>2)</td> </tr> <tr> <td><u>Profibus PA (Fisco Field Device) / Foundation Fieldbus</u></td> <td><u>Profibus PA (Fisco Field Device) / Foundation Fieldbus</u></td> </tr> <tr> <td><math>U_i = 30V</math></td> <td><math>U_i = 32V</math></td> </tr> <tr> <td><math>I_i = 570mA</math></td> <td><math>I_i = 570mA</math></td> </tr> <tr> <td><math>P_i = 8.5W</math></td> <td><math>P_i = 8.5W</math></td> </tr> <tr> <td><math>L_i = 10\mu H</math></td> <td><math>L_i = 10\mu H</math></td> </tr> <tr> <td><math>C_i = 5nF</math></td> <td><math>C_i = 5nF</math></td> </tr> </table>	1)	2)	<u>Profibus PA (Fisco Field Device) / Foundation Fieldbus</u>	<u>Profibus PA (Fisco Field Device) / Foundation Fieldbus</u>	$U_i = 30V$	$U_i = 32V$	$I_i = 570mA$	$I_i = 570mA$	$P_i = 8.5W$	$P_i = 8.5W$	$L_i = 10\mu H$	$L_i = 10\mu H$	$C_i = 5nF$	$C_i = 5nF$
1)	2)															
<u>Profibus PA (Fisco Field Device) / Foundation Fieldbus</u>	<u>Profibus PA (Fisco Field Device) / Foundation Fieldbus</u>															
$U_i = 30V$	$U_i = 32V$															
$I_i = 570mA$	$I_i = 570mA$															
$P_i = 8.5W$	$P_i = 8.5W$															
$L_i = 10\mu H$	$L_i = 10\mu H$															
$C_i = 5nF$	$C_i = 5nF$															
NA, RA	IO1 / RJ45	$U_N = 30V_{DC}$ $U_M = 250V_{AC}$														

<sup>1)</sup> applicable for products with approval code dd = BB, BD, B7, B8

<sup>2)</sup> applicable for products with approval code dd = BM, BN

Input/Output 2		
Order Code g =	terminal no.	values
C, G, K	No. 24, 25	$U_i = 30V$ $I_i = 100mA$ $P_i = 1.25W$ $L_i = 0$ $C_i = 0$
B, D, E, F, I, J, L	No. 24, 25	$U_N = 30V_{DC}$ $U_M = 250V_{AC}$
H	No. 24, 25	$U_N = 30V_{DC}$ $I_N = 100mA_{DC} / 500mA_{AC}$ $U_M = 250V_{AC}$

Input/Output 3		
Order Code h =	terminal no.	values
C, G, K	No. 22, 23	$U_i = 30V$ $I_i = 100mA$ $P_i = 1.25W$ $L_i = 0$ $C_i = 0$
B, D, E, F, I, J, L	No. 22, 23	$U_N = 30V_{DC}$ $U_M = 250V_{AC}$
H	No. 22, 23	$U_N = 30V_{DC}$ $I_N = 100mA_{DC} / 500mA_{AC}$ $U_M = 250V_{AC}$

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
 Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500



Applicant: Endress+Hauser Flowtec AG

Input/Output 4		
Order Code i =	terminal no.	values
C, G, K	No. 20, 21	U <sub>i</sub> = 30V I <sub>i</sub> = 100mA P <sub>i</sub> = 1.25W L <sub>i</sub> = 0 C <sub>i</sub> = 0
B, D, E, F, I, J, L	No. 20, 21	U <sub>N</sub> = 30V <sub>DC</sub> U <sub>M</sub> = 250Vac
H	No. 20, 21	U <sub>N</sub> = 30V <sub>DC</sub> I <sub>N</sub> = 100mA <sub>DC</sub> / 500mA <sub>AC</sub> U <sub>M</sub> = 250Vac

Service Interface		
Order Code dd =	terminal no.	values
BB, BD, B7, B8	Service Interface	Service Interface shall only be installed in areas which are known to be non hazardous
not for: BB, BD, B7, B8	Service Interface	U <sub>N</sub> = 3.3V

Antenna bushing		
Order Code dd =	terminal no.	values
BB, BJ, BN, B7	N connector	See conditions of safe use

Display remote		
Order Code dd =	terminal no.	values
BB, BD, B7, B8	No. 81, 82, 83, 84	U <sub>o</sub> = 3.9V I <sub>o</sub> = 1.5A (spark) 200mA (power) P <sub>o</sub> = 600mW R <sub>i</sub> = 2.6Ω C <sub>o</sub> = 670μF L <sub>o</sub> = 0
not for: BB, BD, B7, B8	No. 81, 82, 83, 84	U <sub>N</sub> = 3.3V I <sub>N</sub> = 150mA

For Transmitter with approval code dd = BB, BD, B7 and B8 connected to the Remote Display of Endress+Hauser, Type DKX001 or ODKX001, the cable parameter with ration L/R = ≤ 0.024 mH/Ω applies.

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500  
Applicant: Endress+Hauser Flowtec AG

---



## Proline t-mass Remote Transmitter and Remote Sensor:

6\*\*\*\*-... and O6\*\*\*\*-... with order code dd = BJ, BN in combination with k = A:

Transmitter:

terminals 61, 62, 63, 64                   ->  $U_o = 13.8V$ ,  $I_o = 1.156A$ ,  $P_o = 3.3W$

Sensor:

terminals 61, 62, 63, 64                   ->  $U_i = 14V$ ,  $I_i = 1.2A$ ,  $P_i = 3.4W$

For interconnection of transmitter to sensor any cable may be used with the following requirements:

- $L/R \leq 0.0089 \text{ mH}/\Omega$  and  $C_{\text{cable}} \leq 760\text{nF}$  for group IIC,  $L/R \leq 0.0356 \text{ mH}/\Omega$  and  $C_{\text{cable}} \leq 4.2\mu\text{F}$  for group IIB  
or
- $L_{\text{cable}} \leq 26\mu\text{H}$  and  $C_{\text{cable}} \leq 760\text{nF}$  for group IIC,  $L_{\text{cable}} \leq 104\mu\text{H}$  and  $C_{\text{cable}} \leq 4.2\mu\text{F}$  for group IIB

This certificate and its schedules may only be reproduced in its entirety and without change



CSA Group Netherlands B.V.  
Utrechtseweg 310,  
6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
 Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500  
 Applicant: Endress+Hauser Flowtec AG



## 5.4.2 Thermal Parameters (Zone 1)

Proline t-mass 300																																																											
<p><b>Notes:</b>                      This page applies to versions with extended order code covering:                      6*3B** - dd... 6x3Bxx - dd...                      with approval option cCSAus / CSA: dd = CD, CE, C2, C4                      ECEX / ATEX: dd = BB, BD 06x3Bxx - dd...</p>																																																											
<p><b>Temperature table for versions with sensor Insulated and not insulated</b>                      (for insulation refer to manual of Endress+Hauser Flowtec)</p>																																																											
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">Size / DN</th> <th colspan="2">T<sub>max</sub></th> <th colspan="2">T<sub>max</sub></th> <th colspan="2">T<sub>max</sub></th> <th colspan="2">T<sub>max</sub></th> <th colspan="2">T<sub>max</sub></th> </tr> <tr> <th>min [°C]</th> <th>max [°C]</th> <th>T6 (85°C)</th> <th>T5 (100°C)</th> <th>T4 (135°C)</th> <th>T3 (200°C)</th> <th>T2 (300°C)</th> <th>T1 (450°C)</th> <th>T6 (85°C)</th> <th>T5 (100°C)</th> </tr> </thead> <tbody> <tr> <td>all</td> <td>-50</td> <td>180</td> <td>50</td> <td>55</td> <td>60</td> <td>60</td> <td>60</td> <td>60</td> <td>100</td> <td>100</td> </tr> </tbody> </table> <p><b>Notes:</b> (1) T<sub>6</sub> min = 40°C, 50°C respectively (see parameter)                      (2) values in brackets are applicable for insulation where the transmitter is not installed above the sensor</p>	Size / DN	T <sub>max</sub>		T <sub>max</sub>		T <sub>max</sub>		T <sub>max</sub>		T <sub>max</sub>		min [°C]	max [°C]	T6 (85°C)	T5 (100°C)	T4 (135°C)	T3 (200°C)	T2 (300°C)	T1 (450°C)	T6 (85°C)	T5 (100°C)	all	-50	180	50	55	60	60	60	60	100	100	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">Size / DN</th> <th colspan="2">T<sub>max</sub> to be measured at reference point at sensor neck [°C]</th> <th colspan="2">T<sub>max</sub> to be measured at reference point at sensor neck [°C]</th> <th colspan="2">T<sub>max</sub> to be measured at reference point at sensor neck [°C]</th> <th colspan="2">T<sub>max</sub> to be measured at reference point at sensor neck [°C]</th> </tr> <tr> <th>T6 (85°C)</th> <th>T5 (100°C)</th> <th>T4 (135°C)</th> <th>T3 (200°C)</th> <th>T2 (300°C)</th> <th>T1 (450°C)</th> <th>T6 (85°C)</th> <th>T5 (100°C)</th> </tr> </thead> <tbody> <tr> <td>all</td> <td>73</td> <td>73</td> <td>76</td> <td>77</td> <td>77</td> <td>77</td> <td>77</td> <td>77</td> </tr> </tbody> </table> <p><b>Notes:</b> (1) for safe use temperatures shall not exceed all of the following:                      - temperature table for versions with sensor not insulated (refer to table above)                      - T<sub>6</sub> min = 40°C, 50°C respectively (see nameplate)                      - for maximum medium temperature and minimum medium temperature see nameplate                      (2) location of reference point</p> 	Size / DN	T <sub>max</sub> to be measured at reference point at sensor neck [°C]		T <sub>max</sub> to be measured at reference point at sensor neck [°C]		T <sub>max</sub> to be measured at reference point at sensor neck [°C]		T <sub>max</sub> to be measured at reference point at sensor neck [°C]		T6 (85°C)	T5 (100°C)	T4 (135°C)	T3 (200°C)	T2 (300°C)	T1 (450°C)	T6 (85°C)	T5 (100°C)	all	73	73	76	77	77	77	77	77
Size / DN		T <sub>max</sub>		T <sub>max</sub>		T <sub>max</sub>		T <sub>max</sub>		T <sub>max</sub>																																																	
	min [°C]	max [°C]	T6 (85°C)	T5 (100°C)	T4 (135°C)	T3 (200°C)	T2 (300°C)	T1 (450°C)	T6 (85°C)	T5 (100°C)																																																	
all	-50	180	50	55	60	60	60	60	100	100																																																	
Size / DN	T <sub>max</sub> to be measured at reference point at sensor neck [°C]		T <sub>max</sub> to be measured at reference point at sensor neck [°C]		T <sub>max</sub> to be measured at reference point at sensor neck [°C]		T <sub>max</sub> to be measured at reference point at sensor neck [°C]																																																				
	T6 (85°C)	T5 (100°C)	T4 (135°C)	T3 (200°C)	T2 (300°C)	T1 (450°C)	T6 (85°C)	T5 (100°C)																																																			
all	73	73	76	77	77	77	77	77																																																			
<p><b>Temperature table for versions with sensor insulated</b>                      (for insulation refer to manual of Endress+Hauser Flowtec)</p>																																																											
<p><b>Control Drawing ECEX, ATEX, CSA, cCSAus</b>                      Zone 1, Zone 21, CII Div. 1, CII, CIII, CII Zone 1                      Thermal Parameter                      Proline t-mass 300/500</p>																																																											
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 20%;">Kunden-orig.: K</td> <td style="width: 20%;">18.07.2018 / Bn</td> <td style="width: 20%;">E</td> <td style="width: 40%;">Datei: 18.07.2018 / Bn</td> </tr> <tr> <td>G</td> <td>S</td> <td></td> <td>Gezeichnet von: S</td> </tr> <tr> <td>D</td> <td>H</td> <td></td> <td>Geprüft von: H</td> </tr> <tr> <td>E</td> <td>J</td> <td></td> <td>Geprüft von: J</td> </tr> <tr> <td></td> <td>K</td> <td></td> <td>Geprüft von: K</td> </tr> </table> <p>Alle gezeichneten Untereinheiten, Vorrichtungen oder Zeichnung darf ohne unsere Genehmigung weder verändert noch ohne unsere schriftliche Zustimmung kopiert werden.</p> <p>Erstellt für: FES / Bn                      FILE: W:\zoning\FES0331A\FES0331A.dwg</p>	Kunden-orig.: K	18.07.2018 / Bn	E	Datei: 18.07.2018 / Bn	G	S		Gezeichnet von: S	D	H		Geprüft von: H	E	J		Geprüft von: J		K		Geprüft von: K	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">Erstellt durch: FES</td> <td style="width: 50%;">18.07.2018</td> </tr> <tr> <td>Gezeichnet: S</td> <td>18.07.2018</td> </tr> <tr> <td>Geprüft: H</td> <td>18.07.2018</td> </tr> <tr> <td>Geprüft: J</td> <td>18.07.2018</td> </tr> <tr> <td>Geprüft: K</td> <td>18.07.2018</td> </tr> </table>	Erstellt durch: FES	18.07.2018	Gezeichnet: S	18.07.2018	Geprüft: H	18.07.2018	Geprüft: J	18.07.2018	Geprüft: K	18.07.2018																												
Kunden-orig.: K	18.07.2018 / Bn	E	Datei: 18.07.2018 / Bn																																																								
G	S		Gezeichnet von: S																																																								
D	H		Geprüft von: H																																																								
E	J		Geprüft von: J																																																								
	K		Geprüft von: K																																																								
Erstellt durch: FES	18.07.2018																																																										
Gezeichnet: S	18.07.2018																																																										
Geprüft: H	18.07.2018																																																										
Geprüft: J	18.07.2018																																																										
Geprüft: K	18.07.2018																																																										
 Flowtec AG, Kippenstrasse 7, CH-4153 Reinach BLI, Postfach																																																											
<p><b>FES0331A 1/2</b></p>																																																											

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands

# Certificate Annexe

Certificate Number: Sira 16ATEX2219X  
 Equipment: Proline Promag 300/500, Proline Promass 300/500, Proline Cubemass 300/500, Proline Prosonic Flow 300/500, Proline t-mass 300/500  
 Applicant: Endress+Hauser Flowtec AG



**Proline t-mass 500**

Notes:  
 This page applies to versions with extended order code covering:  
 6'S\*\*\* - dd\*\*\*\*\*A... 06'S\*\*\* - dd\*\*\*\*\*A... 6x6Bxx - dd\*\*\*\*\*A... 06x6Bxx - dd\*\*\*\*\*A...  
 with approval option cSSAus / CSA; dd = CN, CS cSSAus / CSA; dd = BL, BN  
 IECEx / ATEX

**Sensor: Temperature table for versions with sensor insulated and not insulated**  
 (for insulation refer to manual of Endress+Hauser Flowtec)

Size / DN	T <sub>amb</sub>		T <sub>ref</sub>		T <sub>surround</sub> (°C)		T <sub>1</sub>	T <sub>2</sub>		
	min	max	(°C)	(°C)	(80°C)	(100°C)			(135°C)	(200°C)
all	-50	180	80	100	115	130	130	130	130	130

Notes: (1) T<sub>amb</sub> = -40°C, -50°C respectively (see nameplate)

**Sensor: Temperature table for versions with sensor insulated**  
 (for insulation not in compliance to manual of Endress+Hauser Flowtec)

Size / DN	T <sub>amb</sub> to be measured at reference point at		T <sub>ref</sub> (°C)		T <sub>surround</sub> (°C)		T <sub>1</sub>	T <sub>2</sub>
	min	max	(80°C)	(100°C)	(135°C)	(200°C)		
all	-50	180	80	100	115	130	130	130

Notes: (1) for safe use temperatures shall not exceed all of the following:  
 - temperature table for versions with sensor not insulated (refer to table above)  
 - T<sub>amb</sub> = -40°C, -50°C respectively (see nameplate)  
 - for maximum medium temperature and minimum medium temperature see nameplate  
 (1) location of reference point

**Transmitter for all versions**

Type of enclosure	T <sub>amb</sub>		T <sub>ref</sub>		T <sub>1</sub>	T <sub>2</sub>
	Ordinary location (°C)	(85°C)	(100°C)	(135°C)		
aluminium	60	—	—	45	80	—
plastic	60	—	—	—	—	—

Notes: (1) aluminium enclosure: T<sub>amb</sub> min = -50°C (for limitation see name plate)  
 plastic enclosure: T<sub>amb</sub> min = -40°C

Änderungen:	A	19.07.2018	Bn	F	Alle gezeichneten Untereinheiten vorarbeiten.	Erstellt durch:
	B			G	Diese Zeichnung darf ohne unsere Genehmigung weder vervielfältigt werden noch	Erstellt für:
	C			H	anfern, sinovone und konstruieren	Entwickler: FES / Bn
	D			J	abgelegt gemacht werden.	FILE: W:\Zerlegung\FES0331A\FES0331A.docx
	E			K		

Control Drawing IECEx: ATEX, CSA, cSSAus  
 Zone 1, Zone 21, CII Dv. 1, CII, CIIII, CII Zone 1  
 Thermal Parameter  
 Proline t-mass 300/500

**FES0331A 2/2**

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.  
 Utrechtseweg 310,  
 6812 AR, Arnhem Netherlands