

DATA SHEET

AO815 System 800xA hardware selector



The AO815 Analog Output Module has 8 unipolar analog output channels. The module performs self-diagnostic cyclically. Module diagnostics include:

- External Channel Error is reported (only reported on active channels) if the process power supply that supply voltage to output circuitry is too low, or the output current is less than the output set value and the output set value is greater than 1 mA (open circuit).
- Internal Channel Error is reported if the output circuit can not give the right current value.
- Module Error is reported in case of Output Transistor Error, Short Circuit, Checksum Error, Internal Power Supply Error or Watchdog error.

The module has HART pass-through functionality. Only point to point communication is supported. The output filter must be enabled on channels used for HART communication.

Features and benefits

- 8 channels of 4...20 mA
- 1 group of 8 channels isolated from ground
- Analog inputs are short circuit secured to ZP or +24 V
- HART pass-through communication

General info		
Туре	Analog Output	
Signal specification	4.20 mA	
Article number	3BSE052605R1	
Number of channels	8	
HART	Yes	
SOE	No	
Redundancy	No	
High integrity	No	
Intrinsic safety	No	
Mechanics	S800	

Detailed data		
Resolution	12 bit	
Isolation	Groupwise isolated from ground	
Under/over range	±15%	
Output load	Max 750 Ω	
Error	Max. 0.1%	
Temperature drift	Max. 50 ppm/°C	
Input filter (rise time 0-90%)	23 ms (0-90%), max 4 mA / 12.5 ms	
Update cycle time	10 ms	
Current limiting	Short circuit proof current limited output	
Maximum field cable length	600 meters (656 yards)	
Rated insulation voltage	50 V	
Dielectric test voltage	500 V a.c.	
Power dissipation	3.5 W (typ.)	
Current consumption +5 V Modulebus	Max. 125 mA	
Current consumption +24 V Modulebus	0	
Current consumption +24 V external	Max. 165 mA	

Diagnostics	
Front LED's	F(ault), R(un), W(arning), O(SP)
Supervision	Module Error: Output power low. Channel Error: Open circuit (for current >1 mA)
Status indication of supervision	Module Error, Module Warning, Channel Error

Environment and certification		
CE mark	Yes	
Electrical safety	IEC 61131-2, UL 508	
Hazardous Location	C1 Div 2 cULus, C1 Zone 2 cULus, ATEX Zone 2	
Marine certification	BV, DNV-GL, LR	
Protection rating	IP20 according to IEC 60529	
Corrosive atmosphere ISA-S71.04	G3	
Climatic operating conditions	0 to +55 °C (Storage -25 to +70 °C), RH=5 to 95 % no condensation, IEC/EN 61131-2	
Pollution degree	Degree 2, IEC 60664-1	
Mechanical operating conditions	IEC/EN 61131-2	
EMC	EN 61000-6-4, EN 61000-6-2	
Overvoltage categories	IEC/EN 606641, EN 50178	
Equipment class	Class I according to IEC 61140; (earth protected)	
Max ambient temperature	55 °C (131 °F), for vertical mounting in compact MTU 40 °C (104 °F)	
RoHS compliance	EN 50581:2012	
WEEE compliance	DIRECTIVE/2012/19/EU	

Compability	
Use with MTU	TU810, TU812, TU814, TU830, TU833
Keying code	DB

Intrinsic Safety parameters

Dimensions	
Height	119 mm (4.7")
Width	45 mm (1.77")
Depth	102 mm (4.01"), 111 mm (4.37") including connector
Weight	0.21 kg (0.46 lbs.)

Related products





www.abb.com/800xA www.abb.com/controlsystems

800xA is a registered or pending trademark of ABB. All rights to other trademarks reside with their respective owners.

We reserve the right to make technical changes to the products or modify the contents of this document without prior notice. With regard to purchase orders, the agreed particulars shall prevail. ABB does not assume any responsibility for any errors or incomplete information in this document.

We reserve all rights to this document and the items and images it contains. The reproduction, disclosure to third parties or the use of the content of this document including parts thereof – are prohibited without ABB's prior written permission.

Copyright© 2018 ABB All rights reserved