

Part no. Article no.

NZM1-XSRM-L 266671



V2 ---1 x

Similar to illustration

Delivery programme	
Equipment supplied	Door coupling rotary handle Mounting brackets Special short extension shaft External warning plate/marking plate in German/English Black and yellow lightning symbol
Function	Red-yellow for emergency switching off
Protection class	IP66 UL/CSA Type 4X, Type 12
Locking facility	lockable in 0 position on handle
Project planning information	External warning plate/designation label can be clipped on. For enhanced busbar tag shroud on the incomer side, please order IP2X protection against contact with a finger.
Actuation	Actuation on the left
For use with	NZM1(-4) PN1(-4), N(S)1(-4)
Notes	
Additional terminal arrangement for flange operator with mounting bracket	
NZM1-XS(R)M, NZM2-XS(R)M	
Additional terminals K25, K50, K95, K150 → 093827	
Actuation:	
3 pole For actuation on the right For actuation on the left	4-Pole For actuation on the right For actuation on the left

Mounting areas Variation options		WE V1	V2	V3	V4	MII V1
Maximum number of	K25	2 x	-	-	-	-
additional terminals	K50	-	2 x	-	-	-
	K95	-	-	1 x	-	1 x
	K150	-	-	1 x	1 x	-

Example: In mounting area MI, variation option 1 allows the K25 additional terminal to be mounted twice.

# Design verification as per IEC/EN 61439

IEC/EN 61439 design verification	
10.2 Strength of materials and parts	
10.2.2 Corrosion resistance	Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures	Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects	Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation	Meets the product standard's requirements.
10.2.5 Lifting	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact	Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions	Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances	Meets the product standard's requirements.
10.5 Protection against electric shock	Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components	Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections	Is the panel builder's responsibility.

10.8 Connections for external conductors	Is the panel builder's responsibility.
10.9 Insulation properties	
10.9.2 Power-frequency electric strength	Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage	Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material	Is the panel builder's responsibility.
10.10 Temperature rise	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

#### **Technical data ETIM 5.0**


Low-voltage industrial components (EG000017) / Handle for power circuit breaker (EC000229)


Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Handle for switch devices (ecl@ss8-27-37-04-14 [AKF012010])		
Lockable	Yes	
Colour	Red	
Suitable for emergency stop	Yes	
With axe	Yes	
Suitable for power circuit breaker	Yes	
Suitable for switch disconnector	Yes	

#### **Approvals**

Product Standards	UL489; CSA-C22.2 No. 5-09; IEC60947, CE marking
UL File No.	E140305
UL Category Control No.	DIHS
CSA File No.	022086
CSA Class No.	1437-01
North America Certification	UL listed, CSA certified
Degree of Protection	IEC: IP66, UL/CSA Type 4X, 12

### Dimensions





# Additional product information (links)

IL01203006Z (AWA1230-2041) Side wall actuator NZM1

IL01203006Z (AWA1230-2041) Side wall actuator ftp://ftp.moeller.net/DOCUMENTATION/AWA\_INSTRUCTIONS/IL01203006Z2013\_03.pdf NZM1