Circuit-breaker, 3p, 15A

Part no. NZMH2-AF15-NA Catalog No. 269188




Similar to illustration

| Delivery program | | | |
|---|---------------------|----|---|
| Product range | | | Circuit-breaker |
| Protective function | | | System and cable protection |
| Standard/Approval | | | UL/CSA, IEC |
| Release system | | | Thermomagnetic release |
| Installation type | | | Fixed |
| Description | | | Switches conform to UL/CSA as well as the IEC regulations. IEC switching performance values are contained on the rating plate. Fixed overload releases Ir |
| Frame size | | | NZM2 |
| Number of poles | | | 3 pole |
| Standard equipment | | | Screw connection |
| Switching capacity | | | |
| SCCR 480Y/277 V 60 Hz | I _{cu} | kA | 150 |
| SCCR 480 V 60 Hz | I _{cu} | kA | 150 |
| SCCR 600Y/347 V 60 Hz | I _{cu} | kA | 65 |
| Rated current = rated uninterrupted current | | | |
| Rated current = rated uninterrupted current | $I_n = I_u$ | Α | 15 |
| Setting range | | | |
| Overload trip | | | |
| 中 | l _r | Α | 15 - 15 |
| Short-circuit releases | | | |
| Non-delayed | $I_i = I_n x \dots$ | | 350 A fixed |

Technical data General

| Standards | | | IEC/EN 60947 |
|---|---|------|--|
| Protection against direct contact | | | Finger and back of hand proof to VDE 0106 Part 100 |
| Climatic proofing | | | Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30 |
| Ambient temperature | | | |
| Ambient temperature, storage | 0 | С | - 40 - + 70 |
| Operation | 0 | С | -25 - +70 |
| Mechanical shock resistance (10 ms half-sinusoidal shock) according to IEC 60068-2-27 | g | I | 20 (half-sinusoidal shock 20 ms) |
| Safe isolation to EN 61140 | | | |
| Between auxiliary contacts and main contacts | V | / AC | 500 |
| between the auxiliary contacts | V | / AC | 300 |
| Weight | k | g | 2.345 |
| Mounting position | | | |
| Mounting position | | | Vertical and 90° in all directions |



With XFI earth-fault release: - NZM1, N1, NZM2, N2: vertical and 90° in all directions

90° in all directions
with plug-in unit
- NZM1, N1, NZM2, N2: vertical, 90°
right/left
with withdrawable unit:
- NZM3, N3: vertical, 90° right/left
- NZM4, N4: vertical

with remote operator:
- NZM2, N(S)2, NZM3, N(S)3,
NZM4, N(S)4: vertical and 90° in all directions

| Direction of incoming supply | as required |
|--|---|
| Degree of protection | |
| Device | In the operating controls area: IP20 (basic degree of protection) |
| Enclosures | With insulating surround: IP40 With door coupling rotary handle: IP66 |
| Terminations | Tunnel terminal: IP10 Phase isolator and strip terminal: IP00 |
| Other technical data (sheet catalogue) | Weight Temperature dependency, Derating Effective power loss |

Circuit-breakers

| Rated surge voltage invariability | U_{imp} | | |
|---------------------------------------|------------------|------|-------|
| Main contacts | | V | 8000 |
| Auxiliary contacts | | V | 6000 |
| Rated operational voltage | U _e | V AC | 690 |
| Overvoltage category/pollution degree | | | III/3 |
| Rated insulation voltage | Ui | V | 1000 |
| Use in unearthed supply systems | | V | ≦ 690 |

Switching capacity

| Rated short-circuit making capacity | I _{cm} | | |
|--|-----------------|---------|---|
| 240 V | I _{cm} | kA | 330 |
| 400/415 V | I _{cm} | kA | 330 |
| 440 V 50/60 Hz | I _{cm} | kA | 286 |
| 525 V 50/60 Hz | I _{cm} | kA | 105 |
| 690 V 50/60 H | Ic | kA | 40 |
| Rated short-circuit breaking capacity I_{cn} | I _{cn} | | |
| Icu to IEC/EN 60947 test cycle O-t-CO | lcu | kA | |
| 240 V 50/60 Hz | I _{cu} | kA | 150 |
| 400/415 V 50/60 Hz | I _{cu} | kA | 150 |
| 440 V 50/60 Hz | I _{cu} | kA | 130 |
| 525 V 50/60 Hz | I _{cu} | kA | 50 |
| 690 V 50/60 Hz | I _{cu} | kA | 20 |
| Ics to IEC/EN 60947 test cycle 0-t-C0-t-C0 | lcs | kA | |
| 240 V 50/60 Hz | I _{cs} | kA | 150 |
| 400/415 V 50/60 Hz | I _{cs} | kA | 150 |
| 440 V 50/60 Hz | I _{cs} | kA | 130 |
| 525 V 50/60 Hz | I _{cs} | kA | 37.5 |
| 690 V 50/60 Hz | I _{cs} | kA | 5 |
| Maximum low-voltage h.b.c. fuse | | A gG/gL | 355 |
| | | | Maximum back-up fuse, if the expected short-circuit currents at the installation location exceed the switching capacity of the circuit-breaker. |
| Technical data that diverge from products for the IEC market | | | |

Switching capacity of NA switches (UL489, CSA 22.2 No. 5.1)

| Short-circuit current rating SCCR | | | |
|-----------------------------------|-----------------|----|-----|
| SCCR 240 V 60 Hz | I _{cu} | kA | 150 |
| SCCR 480Y/277 V 60 Hz | I _{cu} | kA | 150 |
| SCCR 480 V 60 Hz | I _{cu} | kA | 150 |
| SCCR 600Y/347 V 60 Hz | I _{cu} | kA | 65 |

| Rated short-time withstand current | | | |
|---|-----------------|-----------------|-------------------------------|
| t = 0.3 s | I _{cw} | kA | 1.9 |
| t = 1 s | I _{cw} | kA | 1.9 |
| Utilization category to IEC/EN 60947-2 | ·Cvv | | A |
| Lifespan, mechanical(of which max. 50 % trip by shunt/undervoltage release) | Operations | | 20000 |
| Lifespan, electrical | Орегинона | | 2000 |
| AC-1 | | | |
| 400 V 50/60 Hz | Operations | | 10000 |
| 690 V 50/60 Hz | Operations | | 7500 |
| AC3 | Operations | | 7300 |
| | 0 | | 6500 |
| 400 V 50/60 Hz | Operations | | 6500 |
| 415 V 50/60 Hz | Operations | | 6500 |
| 690 V 50/60 Hz | Operations | 0 " | 5000 |
| Max. operating frequency | | Ops/h | 120 |
| Total break time at short-circuit Terminal capacity | | ms | < 10 |
| Standard equipment | | | Screw connection |
| Round copper conductor | | | |
| Box terminal | | | |
| Solid | | mm ² | 1 x (12 6) |
| | | | |
| Stranded | | mm ² | 1 x (4 350) |
| Tunnel terminal | | | |
| Solid | | mm ² | 1 x 16 |
| Stranded | | | |
| Stranded | | mm^2 | 1 x (4 350) |
| Bolt terminal and rear-side connection | | | |
| Direct on the switch | | | |
| Solid | | mm ² | 1 x (11 6) |
| Stranded | | mm ² | 1 x (4 3/0) |
| Al conductors, Cu cable | | | |
| Tunnel terminal | | | |
| Solid | | mm ² | 1 x 16 |
| Bolt terminal and rear-side connection | | IIIIII | |
| Flat copper strip, with holes | | | 2 x 16 x 0.8 |
| | min. | mm | 10 x 16 x 0.8 |
| Flat copper strip, with holes | max. | mm | 10 X 10 X U.0 |
| Cu strip (number of segments x width x segment thickness) Box terminal | | | |
| DUX LETHINIA | min | mm | 2.0.00 |
| | min. | mm | 2 x 9 x 0.8 10 x 16 x 0.8 |
| Rolt terminal and rear eide connection | max. | mm | 10 \ 10 \ \ 0.0 |
| Bolt terminal and rear-side connection | min | mm | 2 × 16 × 0.9 |
| Flat copper strip, with holes | min. | mm | 2 x 16 x 0.8 10 x 16 x 0.8 |
| Flat copper strip, with holes Copper husbar (width x thickness) | max. | mm | 10 A 10 A 0.0 |
| Copper busbar (width x thickness) Bolt terminal and rear-side connection | mm | | |
| | | | MO |
| Screw connection | | | M8 |
| Direct on the switch | min | mm | 16 v E |
| | min. | mm | 16 x 5 |
| Control cables | max. | mm | 20 x 5 |
| Control capies | | 2 | 1/10 14\ |
| | | mm ² | 1 x (18 14) 2 x (18 16) |
| | | | |

Design verification as per IEC/EN 61439

| | Technical data for design verification | | |
|--|--|--|--|
|--|--|--|--|

| Rated operational current for specified heat dissipation | In | Α | 15 |
|---|------------------|----|--|
| Equipment heat dissipation, current-dependent | P_{vid} | W | 2.87 |
| Operating ambient temperature min. | | °C | -25 |
| Operating ambient temperature max. | | °C | 70 |
| IEC/EN 61439 design verification | | | |
| 10.2 Strength of materials and parts | | | |
| 10.2.2 Corrosion resistance | | | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | | | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | | Meets the product standard's requirements. |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects $$ | | | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | | | Meets the product standard's requirements. |
| 10.2.5 Lifting | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | | | Meets the product standard's requirements. |
| 10.3 Degree of protection of ASSEMBLIES | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | | | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | | | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | | | Is the panel builder's responsibility. |
| 10.9 Insulation properties | | | |
| 10.9.2 Power-frequency electric strength | | | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | | | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | | | Is the panel builder's responsibility. |
| 10.10 Temperature rise | | | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | | | Is the panel builder's responsibility. The specifications for the switch gear must be observed. $\label{eq:specification}$ |
| 10.12 Electromagnetic compatibility | | | Is the panel builder's responsibility. The specifications for the switch gear must be observed. $\label{eq:specification}$ |
| 10.13 Mechanical function | | | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

Technical data ETIM 8.0

Low-voltage industrial components (EG000017) / Power circuit-breaker for trafo/generator/installation protection (EC000228)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Circuit breaker for power transformer, generator and system protection (ecl@ss10.0.1-27-37-04-09 [AJZ716013])

| p | | |
|---|----|--|
| Rated permanent current lu | Α | 15 |
| Rated voltage | V | 690 - 690 |
| Rated short-circuit breaking capacity Icu at 400 V, 50 Hz | kA | 150 |
| Overload release current setting | Α | 15 - 15 |
| Adjustment range short-term delayed short-circuit release | Α | 0 - 0 |
| Adjustment range undelayed short-circuit release | А | 350 - 350 |
| Integrated earth fault protection | | No |
| Type of electrical connection of main circuit | | Screw connection |
| Device construction | | Built-in device fixed built-in technique |
| Suitable for DIN rail (top hat rail) mounting | | No |
| DIN rail (top hat rail) mounting optional | | Yes |
| Number of auxiliary contacts as normally closed contact | | 0 |
| Number of auxiliary contacts as normally open contact | | 0 |
| Number of auxiliary contacts as change-over contact | | 0 |
| With switched-off indicator | | No |
| With integrated under voltage release | | No |
| Number of poles | | 3 |
| Position of connection for main current circuit | | Front side |
| Type of control element | | Rocker lever |
| | | |

| Complete device with protection unit | Yes |
|--------------------------------------|------|
| Motor drive integrated | No |
| Motor drive optional | Yes |
| Degree of protection (IP) | IP20 |