

Please be informed that the data shown in this PDF Document is generated from our Online Catalog. Please find the complete data in the user's documentation. Our General Terms of Use for Downloads are valid (http://phoenixcontact.com/download)



Feed-through terminal block, Connection method: Push-in connection, Cross section: 0.5 mm² - 25 mm², AWG: 20 - 4, Width: 12.2 mm, Color: gray, Mounting type: NS 35/7,5, NS 35/15

### Why buy this product

- The Push-in connection terminal blocks are characterized by the system features of the CLIPLINE complete system and by easy and tool-free wiring of conductors with ferrules or solid conductors
- The compact design and front connection enable wiring in a confined space
- In addition to the testing facility in the double function shaft, all terminal blocks provide an additional test connection
- Tested for railway applications



### **Key Commercial Data**

| Packing unit | 25 pc           |
|--------------|-----------------|
| GTIN         | 4 046356 737555 |

### Technical data

### General

| 1                 |
|-------------------|
| 3                 |
| 1                 |
| 16 mm²            |
| gray              |
| PA                |
| V0                |
| Railway industry  |
| Machine building  |
| Plant engineering |
| 8 kV              |
| 3                 |
| III               |
| I                 |
|                   |



### Technical data

### General

| Nominal current I <sub>N</sub> Nominal voltage U <sub>N</sub> 1000 V Open side panel Shock protection test specification Back of the hand protection Back of the h | ductor cross section) |
|--|-----------------------|
| Open side panel   Yes  |                       |
| Shock protection test specification  Back of the hand protection  Back of the hand protection  Guaranteed  Finger protection  Result of surge voltage test  Test passed  Surge voltage test Surge voltage test  Test passed  Surge voltage test Test passed  Power frequency withstand voltage setpoint  Result of power-frequency withstand voltage setpoint  Result of the test for mechanical stability of terminal points (5 x conductor connection)  Result of bending test  Bending test conductor cross section/weight  Test passed  Bending test conductor cross section/weight  D.5 mm² / 0.3 kg  16 mm² / 2.9 kg  25 mm² / 4.5 kg  Tensile test result  Conductor cross section tensile test  Tractive force setpoint  Conductor cross section tensile test  Tractive force setpoint  Conductor cross section tensile test  Tractive force setpoint  Test passed  Test passed  Tractive force setpoint  Tonu N  Conductor cross section tensile test  Test passed  Requirements, voltage drop  Sont circuit stability result  Test passed  Short circuit stability result  Conductor cross section short circuit testing  Short-time current  1.92 kA  Result of aging test  Ageing test for screwless modular terminal block temperature cycles  192  Result of termal test  Test passed   |                       |
| Back of the hand protection  Finger protection  Result of surge voltage test  Surge voltage test setpoint  Result of power-frequency withstand voltage test  Power frequency withstand voltage setpoint  Result of the test for mechanical stability of terminal points (5 x conductor connection)  Result of bending test  Bending test conductor cross section/weight  Test passed  Bending test conductor cross section/weight  Test passed  Bending test result  Test passed  Conductor cross section tensile test  Test passed  Conductor cross section tensile test  Tractive force setpoint  Conductor cross section tensile test  Tractive force setpoint  Conductor cross section tensile test  Tractive force setpoint  Test passed  Test passed  Tight fit on carrier  NS 35  Setpoint  Solve in temperature-rise test  Test passed  Requirements, voltage drop  Solve in temperature-rise test  Test passed  Short circuit stability result  Test passed  Conductor cross section short circuit testing  Short-time current  1.92 kA  Conductor cross section short circuit testing  Short-time current  Test passed  Ageing test for screwless modular terminal block temperature cycles  Result of thermal test  Test passed  |                       |
| Finger protection  Result of surge voltage test  Surge voltage test setpoint  Result of power-frequency withstand voltage test  Test passed  Power frequency withstand voltage setpoint  Result of the test for mechanical stability of terminal points (5 x conductor connection)  Result of bending test  Bending test conductor cross section/weight  Test passed  Bending test conductor cross section/weight  Test passed  16 mm² / 2.9 kg  25 mm² / 4.5 kg  Tensile test result  Test passed  Conductor cross section tensile test  0.5 mm²  Tractive force setpoint  Conductor cross section tensile test  16 mm²  Tractive force setpoint  Conductor cross section tensile test  Tractive force setpoint  Tracti                     | 360-514):2002-11      |
| Result of surge voltage test Surge voltage test setpoint Surge voltage test setpoint Result of power-frequency withstand voltage test Power frequency withstand voltage setpoint Result of the test for mechanical stability of terminal points (5 x conductor connection) Result of bending test Bending test conductor cross section/weight D.5 mm² / 0.3 kg 16 mm² / 2.9 kg 25 mm² / 4.5 kg Test passed Conductor cross section tensile test Test passed Conductor cross section tensile test Tractive force setpoint Conductor cross section tensile test Tractive force setpoint Test passed Tight fit on support Test passed Tight fit on carrier NS 35 Setpoint Result of tight fit on support Test passed Requirements, voltage drop Short circuit stability result Test passed Short circuit stability result Test passed Conductor cross section short circuit testing Short-time current 1.92 kA Conductor cross section short circuit testing Short-time current Test passed Ageing test for screwless modular terminal block temperature cycles 192 Result of termal test Test passed   |                       |
| Surge voltage test setpoint  Result of power-frequency withstand voltage test  Power frequency withstand voltage setpoint  Result of the test for mechanical stability of terminal points (5 x conductor connection)  Result of the test for mechanical stability of terminal points (5 x conductor connection)  Result of bending test  Bending test conductor cross section/weight  Description of the mm² / 0.3 kg  16 mm² / 0.3 kg  16 mm² / 2.9 kg  25 mm² / 4.5 kg  Tensile test result  Test passed  Conductor cross section tensile test  0.5 mm²  Tractive force setpoint  Conductor cross section tensile test  16 mm²  Tractive force setpoint  100 N  Conductor cross section tensile test  25 mm²  Tractive force setpoint  135 N  Result of tight fit on support  Test passed  Tight fit on carrier  NS 35  Setpoint  Result of voltage-drop test  Requirements, voltage drop  4 3.2 mV  Result of temperature-rise test  Test passed  Short circuit stability result  Conductor cross section short circuit testing  Short-time current  1.92 kA  Conductor cross section short circuit testing  Short-time current  Result of aging test  Ageing test for screwless modular terminal block temperature cycles  Result of thermal test  Test passed   |                       |
| Result of power-frequency withstand voltage test Power frequency withstand voltage setpoint Power frequency withstand voltage frequency frest passed Power frequency withstand voltage setpoint Power frequency withstand voltage frequency frest passed Power frequency withstand voltage frequency frequency frest passed Power frequency withstand voltage frequency fr                     |                       |
| Power frequency withstand voltage setpoint  Result of the test for mechanical stability of terminal points (5 x conductor connection)  Result of bending test  Bending test conductor cross section/weight  10.5 mm² / 0.3 kg  16 mm² / 2.9 kg  25 mm² / 4.5 kg  Test passed  Conductor cross section tensile test  7. Test passed  Conductor cross section tensile test  1. Test passed  Tractive force setpoint  1. On N  Conductor cross section tensile test  1. Test passed  Tractive force setpoint  1. Test passed  Tractive force setpoint  1. Test passed  Tight fit on support  Test passed  Tight fit on carrier  NS 35  Setpoint  5 N  Result of voltage-drop test  Requirements, voltage drop  4. 3.2 mV  Result of temperature-rise test  Test passed  Short circuit stability result  Test passed  Conductor cross section short circuit testing  Short-time current  1. 92 kA  Conductor cross section short circuit testing  Short-time current  3 kA  Result of aging test  Ageing test for screwless modular terminal block temperature cycles  192  Result of thermal test  Test passed  |                       |
| Result of the test for mechanical stability of terminal points (5 x conductor connection)  Result of bending test  Bending test conductor cross section/weight  Description of the test form mechanical stability of terminal points (5 x Test passed  Bending test conductor cross section/weight  Description of the test feature of the section of the sect                      |                       |
| conductor connection)  Result of bending test  Bending test conductor cross section/weight  Description of the property of th                      |                       |
| Bending test conductor cross section/weight    0.5 mm² / 0.3 kg  |                       |
| 16 mm² / 2.9 kg         25 mm² / 4.5 kg         Tensile test result       Test passed         Conductor cross section tensile test       0.5 mm²         Tractive force setpoint       20 N         Conductor cross section tensile test       16 mm²         Tractive force setpoint       100 N         Conductor cross section tensile test       25 mm²         Tractive force setpoint       135 N         Result of tight fit on support       Test passed         Tight fit on carrier       NS 35         Setpoint       5 N         Result of voltage-drop test       Test passed         Requirements, voltage drop       ≤ 3.2 mV         Result of temperature-rise test       Test passed         Short circuit stability result       Test passed         Conductor cross section short circuit testing       16 mm²         Short-time current       1.92 kA         Conductor cross section short circuit testing       25 mm²         Short-time current       3 kA         Result of aging test       Test passed         Ageing test for screwless modular terminal block temperature cycles       192         Result of thermal test       Test passed   |                       |
| Tensile test result  Conductor cross section tensile test  Conductor cross section tensile test  Tractive force setpoint  Conductor cross section tensile test  16 mm²  Tractive force setpoint  Conductor cross section tensile test  100 N  Conductor cross section tensile test  Tractive force setpoint  100 N  Conductor cross section tensile test  Tractive force setpoint  135 N  Result of tight fit on support  Test passed  Tight fit on carrier  NS 35  Setpoint  Result of voltage-drop test  Requirements, voltage drop  ≤ 3.2 mV  Result of temperature-rise test  Test passed  Short circuit stability result  Conductor cross section short circuit testing  Short-time current  1.92 kA  Conductor cross section short circuit testing  Short-time current  Test passed  Ageing test for screwless modular terminal block temperature cycles  Test passed  |                       |
| Tensile test result  Conductor cross section tensile test  0.5 mm²  Tractive force setpoint  20 N  Conductor cross section tensile test  16 mm²  Tractive force setpoint  100 N  Conductor cross section tensile test  25 mm²  Tractive force setpoint  135 N  Result of tight fit on support  Test passed  Tight fit on carrier  NS 35  Setpoint  Result of voltage-drop test  Requirements, voltage drop  Result of temperature-rise test  Test passed  Test passed  Conductor cross section short circuit testing  Short-time current  1.92 kA  Conductor cross section short circuit testing  Short-time current  3 kA  Result of aging test  Test passed  Test passed  Test passed  |                       |
| Conductor cross section tensile test  Tractive force setpoint  Conductor cross section tensile test  16 mm²  Tractive force setpoint  100 N  Conductor cross section tensile test  25 mm²  Tractive force setpoint  135 N  Result of tight fit on support  Test passed  Tight fit on carrier  NS 35  Setpoint  Result of voltage-drop test  Requirements, voltage drop  Result of temperature-rise test  Test passed  Short circuit stability result  Conductor cross section short circuit testing  Short-time current  1.92 kA  Conductor cross section short circuit testing  Short-time current  Ageing test for screwless modular terminal block temperature cycles  Result of thermal test  Test passed  |                       |
| Tractive force setpoint  Conductor cross section tensile test  16 mm²  Tractive force setpoint  100 N  Conductor cross section tensile test  25 mm²  Tractive force setpoint  135 N  Result of tight fit on support  Test passed  Tight fit on carrier  NS 35  Setpoint  Result of voltage-drop test  Requirements, voltage drop  Result of temperature-rise test  Test passed  Short circuit stability result  Conductor cross section short circuit testing  Short-time current  1.92 kA  Conductor cross section short circuit testing  Short-time current  3 kA  Result of aging test  Test passed  Ageing test for screwless modular terminal block temperature cycles  Result of thermal test  Test passed   |                       |
| Conductor cross section tensile test       16 mm²         Tractive force setpoint       100 N         Conductor cross section tensile test       25 mm²         Tractive force setpoint       135 N         Result of tight fit on support       Test passed         Tight fit on carrier       NS 35         Setpoint       5 N         Result of voltage-drop test       Test passed         Requirements, voltage drop       ≤ 3.2 mV         Result of temperature-rise test       Test passed         Short circuit stability result       Test passed         Conductor cross section short circuit testing       16 mm²         Short-time current       1.92 kA         Conductor cross section short circuit testing       25 mm²         Short-time current       3 kA         Result of aging test       Test passed         Ageing test for screwless modular terminal block temperature cycles       192         Result of thermal test       Test passed   |                       |
| Tractive force setpoint  Conductor cross section tensile test  25 mm²  Tractive force setpoint  135 N  Result of tight fit on support  Test passed  Tight fit on carrier  NS 35  Setpoint  Result of voltage-drop test  Requirements, voltage drop  Result of temperature-rise test  Test passed  Short circuit stability result  Conductor cross section short circuit testing  Short-time current  1.92 kA  Conductor cross section short circuit testing  Short-time current  3 kA  Result of aging test  Test passed  Ageing test for screwless modular terminal block temperature cycles  Result of thermal test  Test passed   |                       |
| Conductor cross section tensile test       25 mm²         Tractive force setpoint       135 N         Result of tight fit on support       Test passed         Tight fit on carrier       NS 35         Setpoint       5 N         Result of voltage-drop test       Test passed         Requirements, voltage drop       ≤ 3.2 mV         Result of temperature-rise test       Test passed         Short circuit stability result       Test passed         Conductor cross section short circuit testing       16 mm²         Short-time current       1.92 kA         Conductor cross section short circuit testing       25 mm²         Short-time current       3 kA         Result of aging test       Test passed         Ageing test for screwless modular terminal block temperature cycles       192         Result of thermal test       Test passed   |                       |
| Tractive force setpoint  Result of tight fit on support  Test passed  Tight fit on carrier  NS 35  Setpoint  Setpoint  Result of voltage-drop test  Test passed  Requirements, voltage drop  Result of temperature-rise test  Test passed  Short circuit stability result  Conductor cross section short circuit testing  Short-time current  1.92 kA  Conductor cross section short circuit testing  Short-time current  3 kA  Result of aging test  Ageing test for screwless modular terminal block temperature cycles  Result of thermal test  Test passed   |                       |
| Result of tight fit on support       Test passed         Tight fit on carrier       NS 35         Setpoint       5 N         Result of voltage-drop test       Test passed         Requirements, voltage drop       ≤ 3.2 mV         Result of temperature-rise test       Test passed         Short circuit stability result       Test passed         Conductor cross section short circuit testing       16 mm²         Short-time current       1.92 kA         Conductor cross section short circuit testing       25 mm²         Short-time current       3 kA         Result of aging test       Test passed         Ageing test for screwless modular terminal block temperature cycles       192         Result of thermal test       Test passed   |                       |
| Tight fit on carrier  Setpoint  Setpoint  Setpoint  Result of voltage-drop test  Requirements, voltage drop  Result of temperature-rise test  Test passed  Short circuit stability result  Conductor cross section short circuit testing  Short-time current  Conductor cross section short circuit testing  Short-time current  Short-time current  3 kA  Result of aging test  Ageing test for screwless modular terminal block temperature cycles  Test passed  Test passed  Test passed  |                       |
| Setpoint       5 N         Result of voltage-drop test       Test passed         Requirements, voltage drop       ≤ 3.2 mV         Result of temperature-rise test       Test passed         Short circuit stability result       Test passed         Conductor cross section short circuit testing       16 mm²         Short-time current       1.92 kA         Conductor cross section short circuit testing       25 mm²         Short-time current       3 kA         Result of aging test       Test passed         Ageing test for screwless modular terminal block temperature cycles       192         Result of thermal test       Test passed   |                       |
| Result of voltage-drop test       Test passed         Requirements, voltage drop       ≤ 3.2 mV         Result of temperature-rise test       Test passed         Short circuit stability result       Test passed         Conductor cross section short circuit testing       16 mm²         Short-time current       1.92 kA         Conductor cross section short circuit testing       25 mm²         Short-time current       3 kA         Result of aging test       Test passed         Ageing test for screwless modular terminal block temperature cycles       192         Result of thermal test       Test passed  |                       |
| Requirements, voltage drop       ≤ 3.2 mV         Result of temperature-rise test       Test passed         Short circuit stability result       Test passed         Conductor cross section short circuit testing       16 mm²         Short-time current       1.92 kA         Conductor cross section short circuit testing       25 mm²         Short-time current       3 kA         Result of aging test       Test passed         Ageing test for screwless modular terminal block temperature cycles       192         Result of thermal test       Test passed  |                       |
| Result of temperature-rise test  Short circuit stability result  Conductor cross section short circuit testing  16 mm²  Short-time current  1.92 kA  Conductor cross section short circuit testing  25 mm²  Short-time current  3 kA  Result of aging test  Ageing test for screwless modular terminal block temperature cycles  Result of thermal test  Test passed   |                       |
| Short circuit stability result  Conductor cross section short circuit testing  Short-time current  1.92 kA  Conductor cross section short circuit testing  25 mm²  Short-time current  3 kA  Result of aging test  Ageing test for screwless modular terminal block temperature cycles  Result of thermal test  Test passed  |                       |
| Conductor cross section short circuit testing  Short-time current  1.92 kA  Conductor cross section short circuit testing  25 mm²  Short-time current  3 kA  Result of aging test  Ageing test for screwless modular terminal block temperature cycles  Result of thermal test  Test passed  |                       |
| Short-time current  Conductor cross section short circuit testing  25 mm²  Short-time current  3 kA  Result of aging test  Ageing test for screwless modular terminal block temperature cycles  Result of thermal test  Test passed  Test passed   |                       |
| Conductor cross section short circuit testing 25 mm²  Short-time current 3 kA  Result of aging test Test passed  Ageing test for screwless modular terminal block temperature cycles 192  Result of thermal test Test passed   |                       |
| Short-time current 3 kA  Result of aging test Test passed  Ageing test for screwless modular terminal block temperature cycles 192  Result of thermal test Test passed   |                       |
| Result of aging test  Ageing test for screwless modular terminal block temperature cycles  Result of thermal test  Test passed  Test passed  |                       |
| Ageing test for screwless modular terminal block temperature cycles  Result of thermal test  Test passed   |                       |
| Result of thermal test Test passed   |                       |
|  |                       |
| Proof of thermal characteristics (needle flame) effective duration 30 s  |                       |
| 1, 1, 1, 1, 1, 1, 1, 1, 1, 1, 1, 1, 1, 1   |                       |
| Oscillation, broadband noise test result Test passed   |                       |
| Test specification, oscillation, broadband noise DIN EN 50155 (VDE 011   | 15-200):2008-03       |



### Technical data

### General

| Test spectrum   | Service life test category 2, bogie mounted   |
|---|---|
| Test frequency  | $f_1 = 5 \text{ Hz to } f_2 = 250 \text{ Hz}$ |
| ASD level   | 6.12 (m/s <sup>2</sup> ) <sup>2</sup> /Hz     |
| Acceleration  | 3.12 g  |
| Test duration per axis  | 5 h   |
| Test directions   | X-, Y- and Z-axis                             |
| Shock test result   | Test passed                                   |
| Test specification, shock test  | DIN EN 50155 (VDE 0115-200):2008-03           |
| Shock form  | Half-sine                                     |
| Acceleration  | 30g   |
| Shock duration  | 18 ms   |
| Number of shocks per direction  | 3   |
| Test directions   | X-, Y- and Z-axis (pos. and neg.)             |
| Relative insulation material temperature index (Elec., UL 746 B)        | 130 °C  |
| Temperature index of insulation material (DIN EN 60216-1 (VDE 0304-21)) | 130 °C  |
| Static insulating material application in cold                          | -60 °C  |

### Dimensions

| Width            | 12.2 mm  |
|------------------|----------|
| End cover width  | 2.2 mm   |
| Length           | 100.2 mm |
| Height NS 35/7,5 | 52.6 mm  |
| Height NS 35/15  | 60.1 mm  |

### Connection data

| Connection method   | Push-in connection |
|---|--------------------|
| Connection in acc. with standard  | IEC 60947-7-1      |
| Conductor cross section solid min.  | 0.5 mm²            |
| Conductor cross section solid max.  | 25 mm <sup>2</sup> |
| Conductor cross section AWG min.  | 20                 |
| Conductor cross section AWG max.  | 4                  |
| Conductor cross section flexible min.   | 0.5 mm²            |
| Conductor cross section flexible max.   | 16 mm <sup>2</sup> |
| Min. AWG conductor cross section, flexible  | 20                 |
| Max. AWG conductor cross section, flexible  | 6                  |
| Conductor cross section flexible, with ferrule without plastic sleeve min.              | 0.5 mm²            |
| Conductor cross section flexible, with ferrule without plastic sleeve max.              | 16 mm²             |
| Conductor cross section flexible, with ferrule with plastic sleeve min.                 | 0.5 mm²            |
| Conductor cross section flexible, with ferrule with plastic sleeve max.                 | 16 mm²             |
| 2 conductors with same cross section, stranded, TWIN ferrules with plastic sleeve, min. | 1.5 mm²            |



### Technical data

### Connection data

| 2 conductors with same cross section, stranded, TWIN ferrules with plastic sleeve, max. | 4 mm² |
|---|-------|
| Stripping length  | 18 mm |
| Internal cylindrical gage   | A7    |

### Standards and Regulations

| Connection in acc. with standard       | IEC 60947-7-1 |
|--|---------------|
| Flammability rating according to UL 94 | V0            |

### Classifications

### eCl@ss

| eCl@ss 4.0 | 27141120 |
|------------|----------|
| eCl@ss 4.1 | 27141120 |
| eCl@ss 5.0 | 27141120 |
| eCl@ss 5.1 | 27141120 |
| eCl@ss 6.0 | 27141120 |
| eCl@ss 7.0 | 27141120 |
| eCl@ss 8.0 | 27141120 |
| eCl@ss 9.0 | 27141120 |

#### **ETIM**

| ETIM 3.0 | EC000897 |
|----------|----------|
| ETIM 4.0 | EC000897 |
| ETIM 5.0 | EC000897 |

### **UNSPSC**

| UNSPSC 6.01   | 30211811 |
|---------------|----------|
| UNSPSC 7.0901 | 39121410 |
| UNSPSC 11     | 39121410 |
| UNSPSC 12.01  | 39121410 |
| UNSPSC 13.2   | 39121410 |

### Approvals

### Approvals

Approvals

VDE Zeichengenehmigung / IECEE CB Scheme / CSA / UL Recognized / cUL Recognized / EAC / EAC / BV / LR / cULus Recognized

Ex Approvals

ATEX



### Approvals

Approvals submitted

### Approval details

| VDE Zeichengenehmigung |        |
|------------------------|--------|
|                        |        |
| mm²/AWG/kcmil          | 0.5-16 |
| Nominal current IN     | 76 A   |
| Nominal voltage UN     | 1000 V |

| IECEE CB Scheme CB |        |
|--------------------|--------|
|                    |        |
| mm²/AWG/kcmil      | 0.5-16 |
| Nominal current IN | 76 A   |
| Nominal voltage UN | 1000 V |

| CSA (1)            |       |       |
|--------------------|-------|-------|
|                    | В     | С     |
| mm²/AWG/kcmil      | 20-4  | 20-4  |
| Nominal current IN | 70 A  | 70 A  |
| Nominal voltage UN | 600 V | 600 V |

| UL Recognized <b>5</b> |       |       |
|------------------------|-------|-------|
|                        | В     | С     |
| mm²/AWG/kcmil          | 20-4  | 20-4  |
| Nominal current IN     | 85 A  | 85 A  |
| Nominal voltage UN     | 600 V | 600 V |

| cUL Recognized |      |      |
|----------------|------|------|
|                | В    | С    |
| mm²/AWG/kcmil  | 20-4 | 20-4 |



### Approvals

|                    | В     | С     |
|--------------------|-------|-------|
| Nominal current IN | 85 A  | 85 A  |
| Nominal voltage UN | 600 V | 600 V |

| Nonlinar Voltage ON    | 000 1 | 000 V |
|------------------------|-------|-------|
|                        |       |       |
| EAC                    |       |       |
|                        |       |       |
| EAC                    |       |       |
|                        |       |       |
| BV                     |       |       |
|                        |       |       |
| LR                     |       |       |
|                        |       |       |
|                        |       |       |
| cULus Recognized C Nus |       |       |

### Accessories

#### Accessories

DIN rail

DIN rail perforated - NS 35/ 7,5 PERF 2000MM - 0801733



DIN rail, material: steel galvanized and passivated with a thick layer, perforated, height 7.5 mm, width 35 mm, length: 2000 mm

DIN rail, unperforated - NS 35/7,5 UNPERF 2000MM - 0801681



DIN rail, material: Steel, unperforated, height 7.5 mm, width 35 mm, length: 2 m

DIN rail perforated - NS 35/7,5 WH PERF 2000MM - 1204119



DIN rail 35 mm (NS 35)



### Accessories

DIN rail - NS 35/7,5 WH UNPERF 2000MM - 1204122



DIN rail 35 mm (NS 35)

DIN rail, unperforated - NS 35/7,5 AL UNPERF 2000MM - 0801704



DIN rail, unperforated, Width: 35 mm, Height: 7.5 mm, Length: 2000 mm, Color: silver

DIN rail perforated - NS 35/7,5 ZN PERF 2000MM - 1206421



DIN rail, material: Galvanized, perforated, height 7.5 mm, width 35 mm, length: 2 m

DIN rail, unperforated - NS 35/7,5 ZN UNPERF 2000MM - 1206434



DIN rail, material: Galvanized, unperforated, height 7.5 mm, width 35 mm, length: 2 m

DIN rail, unperforated - NS 35/ 7,5 CU UNPERF 2000MM - 0801762




DIN rail, material: Copper, unperforated, height 7.5 mm, width 35 mm, length: 2 m



### Accessories

End cap - NS 35/7,5 CAP - 1206560





DIN rail perforated - NS 35/15 PERF 2000MM - 1201730



DIN rail, material: steel galvanized and passivated with a thick layer, perforated, height 15 mm, width 35 mm, length: 2000 mm

DIN rail, unperforated - NS 35/15 UNPERF 2000MM - 1201714



DIN rail, material: Steel, unperforated, height 15 mm, width 35 mm, length: 2 m

DIN rail perforated - NS 35/15 WH PERF 2000MM - 0806602



DIN rail 35 mm (NS 35)

DIN rail - NS 35/15 WH UNPERF 2000MM - 1204135



DIN rail 35 mm (NS 35)



### Accessories

DIN rail, unperforated - NS 35/15 AL UNPERF 2000MM - 1201756



DIN rail, deep drawn, high profile, unperforated, 1.5 mm thick, material: aluminum, height 15 mm, width 35 mm, length 2000 mm

DIN rail perforated - NS 35/15 ZN PERF 2000MM - 1206599



DIN rail, material: Galvanized, perforated, height 15 mm, width 35 mm, length: 2 m

DIN rail, unperforated - NS 35/15 ZN UNPERF 2000MM - 1206586



DIN rail, material: Galvanized, unperforated, height 15 mm, width 35 mm, length: 2 m

DIN rail, unperforated - NS 35/15 CU UNPERF 2000MM - 1201895



DIN rail, material: Copper, unperforated, 1.5 mm thick, height 15 mm, width 35 mm, length:  $2\ m$ 

End cap - NS 35/15 CAP - 1206573



DIN rail end piece, for DIN rail NS 35/15



### Accessories

DIN rail, unperforated - NS 35/15-2,3 UNPERF 2000MM - 1201798



DIN rail, material: Steel, unperforated, 2.3 mm thick, height 15 mm, width 35 mm, length: 2 m

#### Documentation

Mounting material - PT-IL - 3208090

Operating decal for the push-in Technology



#### End block

End clamp - E/UK - 1201442



End clamp, Width: 9.5 mm, Height: 35.3 mm, Length: 50.5 mm, Color: gray

End clamp - E/UK 1 - 1201413



End clamps, for supporting the ends of double-level and three-level terminal blocks, width: 10 mm, color: gray

End clamp - CLIPFIX 35 - 3022218



Quick mounting end clamp for NS 35/7,5 DIN rail or NS 35/15 DIN rail, with marking option, width: 9.5 mm, color: gray



### Accessories

End clamp - CLIPFIX 35-5 - 3022276



Quick mounting end clamp for NS 35/7.5 DIN rail or NS 35/15 DIN rail, with marking option, with parking option for FBS...5, FBS...6, KSS 5, KSS 6, width: 5.15 mm, color: gray

End clamp - E/NS 35 N - 0800886



End clamp, width: 9.5 mm, color: gray

#### End cover

End cover - D-PT 16-TWIN N - 3208799



End cover, Length: 100.2 mm, Width: 2.2 mm, Color: gray

#### Insulating sleeve

Insulating sleeve - MPS-IH WH - 0201663



Insulating sleeve, Color: white

Insulating sleeve - MPS-IH RD - 0201676



Insulating sleeve, Color: red



### Accessories

Insulating sleeve - MPS-IH BU - 0201689



Insulating sleeve, Color: blue

Insulating sleeve - MPS-IH YE - 0201692



Insulating sleeve, Color: yellow

Insulating sleeve - MPS-IH GN - 0201702



Insulating sleeve, Color: green

Insulating sleeve - MPS-IH GY - 0201728



Insulating sleeve, Color: gray

Insulating sleeve - MPS-IH BK - 0201731



Insulating sleeve, Color: black

Jumper



#### Accessories

Plug-in bridge - FBS 2-12 - 3005950



Plug-in bridge, Pitch: 12 mm, Number of positions: 2, Color: red

#### Labeled terminal marker

Zack Marker strip, flat - ZBF 12 CUS - 0825018



Zack Marker strip, flat, can be ordered: Strip, white, labeled according to customer specifications, Mounting type: Snap into flat marker groove, for terminal block width: 12 mm, Lettering field: 5.15 x 12.15 mm

Marker for terminal blocks - UC-TMF 12 CUS - 0824670



Marker for terminal blocks, can be ordered: by sheet, white, labeled according to customer specifications, Mounting type: Snap into flat marker groove, for terminal block width: 12 mm, Lettering field: 11.45 x 5.1 mm

Marker for terminal blocks - UCT-TMF 12 CUS - 0829686



Marker for terminal blocks, can be ordered: by sheet, white, labeled according to customer specifications, Mounting type: Snap into flat marker groove, for terminal block width: 12 mm, Lettering field: 11.2 x 4.7 mm

Zack marker strip - ZB 12 CUS - 0824942



Zack marker strip, can be ordered: Strip, white, labeled according to customer specifications, Mounting type: Snap into tall marker groove, for terminal block width: 12.2 mm, Lettering field: 10.5 x 12.15 mm



#### Accessories

Marker for terminal blocks - ZB 12,LGS:L1-N,PE - 0812146



Marker for terminal blocks, Strip, white, labeled, Printed horizontally: L1, L2, L3, N, PE, Mounting type: Snap into tall marker groove, for terminal block width: 12.2 mm, Lettering field: 10.5 x 12.15 mm

Marker for terminal blocks - UC-TM 12 CUS - 0824613



Marker for terminal blocks, can be ordered: by sheet, white, labeled according to customer specifications, Mounting type: Snap into tall marker groove, for terminal block width: 12 mm, Lettering field: 11.45 x 10.5 mm

Marker for terminal blocks - UCT-TM 12 CUS - 0829630



Marker for terminal blocks, can be ordered: by sheet, white, labeled according to customer specifications, Mounting type: Snap into tall marker groove, for terminal block width: 12 mm, Lettering field: 10.8 x 9.6 mm

#### Planning and marking software

Software - CLIP-PROJECT ADVANCED - 5146040



Multilingual software for convenient configuration of Phoenix Contact products on standard DIN rails.

#### Software - CLIP-PROJECT PROFESSIONAL - 5146053



Multilingual software for terminal strip configuration. A marking module enables the professional marking of markers and labels for identifying terminal blocks, conductors and cables, and devices.

Reducing bridge



### Accessories

Reducing bridge - RB ST 16-(2,5/4) - 3030886



Reducing bridge, Pitch: 11 mm, Number of positions: 2, Color: red

Reducing bridge - RB 16-6 - 3047072



Reducing bridge, Pitch: 6 mm, Number of positions: 2, Color: red

#### Screwdriver tools

Screwdriver - SZF 1-0,6X3,5 - 1204517



Actuation tool, for ST terminal blocks, also suitable for use as a bladed screwdriver, size: 0.6 x 3.5 x 100 mm, 2-component grip, with non-slip grip

Screwdriver - SZF 3-1,0X5,5 - 1206612



Actuation tool, for ST terminal blocks, also suitable for use as a bladed screwdriver, size:  $1.0 \times 5.5 \times 150$  mm, 2-component grip, with non-slip grip

#### Terminal marking

Zack Marker strip, flat - ZBF 12:UNBEDRUCKT - 0809735



Zack Marker strip, flat, Strip, white, unlabeled, can be labeled with: Plotter, Mounting type: Snap into flat marker groove, for terminal block width: 12 mm, Lettering field: 5.15 x 12.15 mm



#### Accessories

Marker for terminal blocks - UC-TMF 12 - 0819233



Marker for terminal blocks, Sheet, white, unlabeled, can be labeled with: BLUEMARK CLED, BLUEMARK LED, Plotter, Mounting type: Snap into flat marker groove, for terminal block width: 12 mm, Lettering field: 11.45 x 5.1 mm

Marker for terminal blocks - UCT-TMF 12 - 0829214



Marker for terminal blocks, Sheet, white, unlabeled, can be labeled with: THERMOMARK CARD, BLUEMARK CLED, BLUEMARK LED, TOPMARK LASER, Mounting type: Snap into flat marker groove, for terminal block width: 12 mm, Lettering field: 11.2 x 4.7 mm

Zack marker strip - ZB 12:UNPRINTED - 0812120



Zack marker strip, Strip, white, unlabeled, can be labeled with: Plotter, Mounting type: Snap into tall marker groove, for terminal block width: 12.2 mm, Lettering field: 12 x 10.5 mm

Marker for terminal blocks - UC-TM 12 - 0819194



Marker for terminal blocks, Sheet, white, unlabeled, can be labeled with: BLUEMARK CLED, BLUEMARK LED, Plotter, Mounting type: Snap into tall marker groove, for terminal block width: 12 mm, Lettering field: 11.45 x 10.5 mm

Marker for terminal blocks - UCT-TM 12 - 0829144



Marker for terminal blocks, Sheet, white, unlabeled, can be labeled with: THERMOMARK CARD, BLUEMARK CLED, BLUEMARK LED, TOPMARK LASER, Mounting type: Snap into tall marker groove, for terminal block width: 12 mm, Lettering field: 10.8 x 9.6 mm



### Accessories

Marker for terminal blocks - TMT (EX9,5)R - 0828295



Marker for terminal blocks, Roll, white, unlabeled, can be labeled with: THERMOMARK ROLL, THERMOMARK ROLL X1, THERMOMARK X, THERMOMARK S1.1, Mounting type: Snap into universal marker groove, Snap into tall marker groove, Lettering field: 9.5 x 50000 mm

Marker for terminal blocks - US-TM 100 - 0829255



Marker for terminal blocks, Card, white, unlabeled, can be labeled with: THERMOMARK CARD, Mounting type: Snap into universal marker groove, Lettering field: 104 x 9.8 mm

#### Test plug terminal block

Test plugs - MPS-MT - 0201744



Test plugs, Color: silver

### **Drawings**

Circuit diagram

· · · · · ·

Phoenix Contact 2016 @ - all rights reserved http://www.phoenixcontact.com