

product brand name	SENTRON
Product designation	LV HRC fuse link



LV HRC FUSE LINK GL/GG WITH INSULATED GRIP LUGS WITH COMBINATION INDICATOR SIZE 00, 160A, AC 400V

Similar to image

Technical data:		
Current / for AC / rated value	A	160
Operating class of the fuse link		gG
Size of the fallback-system / acc. to DIN EN 60269-1		NH00
Supply voltage		
• for AC / rated value	V	400
Switching capacity current		
• in accordance with IEC 60947-2 / rated value	kA	120
Design of the fuse link		LV HRC fuse link
Design of an identification indicator		Combination alarms
type of the assembly		Insulated grip lugs
mounting position		Any, preferably vertical
Protection class IP		IP20, with connected conductors
Climatic class		-20 to +50 at 95% relative humidity
Ambient temperature		
• minimum	°C	-5
• maximum	°C	40

Ambient temperature / during storage / note		Air humidity 90% at 20 °C
Product description		Using screw adapter or adapter sleeves
Design of the switching contact		Non-corroding, silver-plated
Net weight	g	203
Item designation / according to DIN EN 61346-2		F
Item designation / according to DIN EN 81346-2		F

#### Certificates/approvals:

##### General Product Approval



##### Test Certificates

[Special Test Certificate](#)

#### Further information:

##### Information- and Downloadcenter (Catalogs, Brochures,...)

<http://www.siemens.com/lowvoltage/catalogs>

##### Industry Mall (Online ordering system)

<https://eb.automation.siemens.com/mall/en/WW/Catalog/Product/3NA6836-4>

##### Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

<http://support.automation.siemens.com/WW/view/en/3NA6836-4/all>

##### Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)

[http://www.automation.siemens.com/bilddb/cax\\_en.aspx?mlfb=3NA6836-4](http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=3NA6836-4)

##### CAX-Online-Generator

<http://www.siemens.com/cax>

##### Tender specifications

[Datanorm](#) [GAEB81](#) [GAEB83](#) [RTF](#) [TXT](#)

last change:

Mar 3, 2014