SIEMENS

Product data sheet

CONTACTOR, AC-3 5.5 KW/400 V, DC 24 V, 3-POLE, SIZE S0, SCREW CONNECTION

General details:		
Product brand name		SIRIUS
Product designation	_	power contactor
Size of the contactor		S0
Protection class IP / frontal/front side		IP20
Degree of pollution		3
Altitude of installation site / at a height over sea level / maximum	m	2,000
Ambient temperature / during the operating phase	°C	-25 60
Real loss power / per conductor / typical	W	0.5
Item designation		
according to DIN EN 61346-2		Q
 according to DIN 40719 extendable after IEC 204-2 / according to IEC 750 		К
Mechanical operating cycles as operating time		
of the contactor / typical		10,000,000
 of the contactor with added auxiliary switch block / typical 		10,000,000
 of the contactor with added electronics-compatible auxiliary switch block / typical 		5,000,000
Main circuit:		
Number of poles / for main current circuit		3
Number of NC contacts / for main contacts		0
Number of NO contacts / for main contacts		3
Operating current / at AC-1 / at 400 V / at 40 °C ambient temperature / rated value	A	40
Operating current / at AC-1 / at 400 V / at 60 °C ambient temperature / rated value	A	35
Operating current		
• at AC-3 / at 400 V / rated value	А	12
• with 1 current path		
• at DC-1		
• at 24 V / rated value	А	35
• at 110 V / rated value	А	4.5
• at DC-3 / at DC-5		

at 24 V / rated value	А	20
• at 110 V / rated value	А	2.5
with 2 current paths in series		
• at DC-1		
at 24 V / rated value	А	35
• at 110 V / rated value	А	35
• at DC-3 / at DC-5		
at 24 V / rated value	А	35
at 110 V / rated value	А	15
with 3 current paths in series		
• at DC-1		
at 24 V / rated value	А	35
• at 110 V / rated value	А	35
• at DC-3 / at DC-5		
at 24 V / rated value	А	35
• at 110 V / rated value	А	35
Service power		
• at AC-1 / at 400 V / rated value	kW	23
• at AC-2 / at 400 V / rated value	kW	5.5
• at AC-3		
• at 400 V / rated value	kW	5.5
• at 500 V / rated value	kW	7.5
• at 690 V / rated value	kW	7.5
Control circuit:		
Design of activation of the operating mechanism		conventional
Type of voltage / of the controlled supply voltage		DC
Control supply voltage / 1		
• for DC		
rated value	V	24
Auxiliary circuit:		
Contact reliability / of the auxiliary contacts		1 faulty switching per 100 million (17 V, 1 mA)
Number of NC contacts / for auxiliary contacts		
instantaneous switching		0
lagging switching		0
Number of NO contacts / for auxiliary contact		
instantaneous switching		0
leading switching		0
Operating current / of the auxiliary contacts		

• at AC-12 / maximum	А	10
• at AC-15		
• at 230 V	А	6
• at 400 V	А	3
• at DC-12		
• at 60 V	А	6
• at 110 V	А	3
• at 220 V	А	1
• at DC-13		
• at 24 V	А	10
• at 60 V	А	2
• at 110 V	А	1
• at 220 V	А	0.3

Short-circuit:

Design of the fuse link			
 for short-circuit protection of the auxiliary switch / required 		fuse gL/gG: 10 A	
 for short-circuit protection of the main circuit 			
 at type of coordination 1 / required 		fuse gL/gG: 63 A	
 at type of coordination 2 / required 		fuse gL/gG: 25 A	
Installation/mounting/dimensions:			
Type of fixing/fixation		screw and snap-on mounting onto 35 mm standard mounting rail according to DIN EN 50022	
Series installation		Yes	
Width	mm	45	
Height	mm	85	

distance, to be maintained, to earthed part / sidewards	mm	6
Connection type:		
design of the electrical connection		
for main current circuit		screw-type terminals
 for auxiliary and control current circuit 		screw-type terminals

101

mm


Further information:


Depth


Information- and Downloadcenter (Catalogs, Brochures,...) http://www.siemens.com/industrial-controls/catalogs


Global Industry Mall (Online ordering system) http://www.siemens.com/industrial-controls/mall

Service&Support (Manuals, Certificates, Characteristics, FAQs,...) http://support.automation.siemens.com/WW/view/en/3RT1024-1BB40/all Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...) http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=3RT1024-1BB40









last change:

Jun 14, 2010