SIEMENS

Data sheet

6AG1414-5HM06-7AB0



SIPLUS S7-400 CPU 414-5H -25 ... + 70 DEGREES C WITH CONFORMAL COATING BASED ON 6ES7414-5HM06-0AB0 . CENTRAL UNIT FOR S7-400H AND S7-400F/FH, 5 INTERFACES: 1X MPI/DP, 1X DP, 1X PN AND 2 FOR SYNC MODULES 4 MB MEMORY (512 KB DATA/512 KB CODE)

Figure similar

General information	
Product type designation	CPU 414-5H PN/DP
Hardware product version	1
Firmware version	V6.0
Engineering with	
 Programming package 	As of STEP 7 V5.5 SP2 with HF1
CiR – Configuration in RUN	
CiR synchronization time, basic load	100 ms
CiR synchronization time, time per I/O byte	0 µs
Supply voltage	
Rated value (DC)	
• 24 V DC	No; Power supply via system power supply
Input current	
from backplane bus 5 V DC, typ.	1.6 A
from backplane bus 5 V DC, max.	1.9 A
from backplane bus 24 V DC, max.	150 mA; 150 mA per DP interface

from interface 5 V DC, max.	90 mA; At each DP interface
Power loss	
Power loss, typ.	7.5 W
Memory	
Type of memory	RAM
Work memory	
 integrated 	4 Mbyte
 integrated (for program) 	2 Mbyte
• integrated (for data)	2 Mbyte
• expandable	No
Load memory	
expandable FEPROM	Yes; with Memory Card (FLASH)
 expandable FEPROM, max. 	64 Mbyte
 integrated RAM, max. 	512 kbyte
• expandable RAM	Yes
• expandable RAM, max.	64 Mbyte
Backup	,
• present	Yes
with battery	Yes; all data
• without battery	No
malout battory	
Battery	
-	
Battery	180 μA; Valid up to 40°C
Battery Backup battery	180 μA; Valid up to 40°C 1 000 μA
Backup battery • Backup current, typ.	
Battery Backup battery • Backup current, typ. • Backup current, max.	1 000 μA Dealt with in the module data manual with the secondary
Battery Backup battery • Backup current, typ. • Backup current, max. • Backup time, max. • Feeding of external backup voltage to CPU	1 000 μA Dealt with in the module data manual with the secondary conditions and the factors of influence
Battery Backup battery • Backup current, typ. • Backup current, max. • Backup time, max.	1 000 μA Dealt with in the module data manual with the secondary conditions and the factors of influence
Battery Backup battery • Backup current, typ. • Backup current, max. • Backup time, max. • Feeding of external backup voltage to CPU CPU processing times	1 000 μA Dealt with in the module data manual with the secondary conditions and the factors of influence 5 V DC to 15 V DC
Battery Backup battery • Backup current, typ. • Backup current, max. • Backup time, max. • Feeding of external backup voltage to CPU CPU processing times for bit operations, typ.	1 000 μA Dealt with in the module data manual with the secondary conditions and the factors of influence 5 V DC to 15 V DC 18.75 ns
Battery Backup battery • Backup current, typ. • Backup current, max. • Backup time, max. • Feeding of external backup voltage to CPU CPU processing times for bit operations, typ. for word operations, typ.	1 000 μA Dealt with in the module data manual with the secondary conditions and the factors of influence 5 V DC to 15 V DC 18.75 ns 18.75 ns
Battery Backup battery • Backup current, typ. • Backup current, max. • Backup time, max. • Feeding of external backup voltage to CPU CPU processing times for bit operations, typ. for word operations, typ. for fixed point arithmetic, typ.	1 000 μA Dealt with in the module data manual with the secondary conditions and the factors of influence 5 V DC to 15 V DC 18.75 ns 18.75 ns 18.75 ns
Battery Backup battery • Backup current, typ. • Backup current, max. • Backup time, max. • Feeding of external backup voltage to CPU CPU processing times for bit operations, typ. for word operations, typ. for fixed point arithmetic, typ. for floating point arithmetic, typ.	1 000 μA Dealt with in the module data manual with the secondary conditions and the factors of influence 5 V DC to 15 V DC 18.75 ns 18.75 ns 18.75 ns
Battery Backup battery • Backup current, typ. • Backup current, max. • Backup time, max. • Feeding of external backup voltage to CPU CPU processing times for bit operations, typ. for fixed point arithmetic, typ. for floating point arithmetic, typ. CPU-blocks	1 000 μA Dealt with in the module data manual with the secondary conditions and the factors of influence 5 V DC to 15 V DC 18.75 ns 18.75 ns 18.75 ns
Battery Backup battery • Backup current, typ. • Backup current, max. • Backup time, max. • Feeding of external backup voltage to CPU CPU processing times for bit operations, typ. for fixed point arithmetic, typ. for floating point arithmetic, typ. CPU-blocks DB	1 000 μA Dealt with in the module data manual with the secondary conditions and the factors of influence 5 V DC to 15 V DC 18.75 ns 18.75 ns 18.75 ns 37.5 ns
Battery Backup battery • Backup current, typ. • Backup current, max. • Backup time, max. • Feeding of external backup voltage to CPU CPU processing times for bit operations, typ. for fixed point arithmetic, typ. for floating point arithmetic, typ. CPU-blocks DB • Number, max.	1 000 μA Dealt with in the module data manual with the secondary conditions and the factors of influence 5 V DC to 15 V DC 18.75 ns 18.75 ns 18.75 ns 37.5 ns 6 000; Number range: 1 to 16000
Battery Backup battery • Backup current, typ. • Backup current, max. • Backup time, max. • Feeding of external backup voltage to CPU CPU processing times for bit operations, typ. for for word operations, typ. for floating point arithmetic, typ. for floating point arithmetic, typ. DB • Number, max. • Size, max.	1 000 μA Dealt with in the module data manual with the secondary conditions and the factors of influence 5 V DC to 15 V DC 18.75 ns 18.75 ns 18.75 ns 37.5 ns 6 000; Number range: 1 to 16000
Battery Backup battery • Backup current, typ. • Backup current, max. • Backup time, max. • Feeding of external backup voltage to CPU CPU processing times for bit operations, typ. for fixed point arithmetic, typ. for floating point arithmetic, typ. for floating point arithmetic, typ. FB	1 000 μA Dealt with in the module data manual with the secondary conditions and the factors of influence 5 V DC to 15 V DC 18.75 ns 18.75 ns 18.75 ns 37.5 ns 6 000; Number range: 1 to 16000 64 kbyte

• Size, max.64 kbyte00• Size, max.64 kbyte• Number of free cycle OBs1, 0B 10• Number of free cycle OBs4, 0B 10-13• Number of free cycle OBs4, 0B 20-33• Number of delay alam OBs4, 0B 20-33• Number of orgoces alam OBs4, 0B 40-43• Number of process alam OBs2, 0B 80, 10.102• Number of struct OBs2, 0B 80, 10.102• Number of synchronous error OBs2, 0B 80, 102• Number of synchronous error OBs2, 0B 121, 122• Number of process alam DB2, 0B 121, 122• Number of process alam DB2, 0B 121, 122• Number of DB <th>• Number, max.</th> <th>3 000; Number range: 0 to 7999</th>	• Number, max.	3 000; Number range: 0 to 7999
OB • Number, max. see instruction list • Size, max. 64 kbyte • Number of free cycle OBs 1; 0B 1 • Number of free cycle OBs 4; 0B 20-23 • Number of cyclic interrupt OBs 4; 0B 20-23 • Number of process alarn OBs 4; 0B 40-43 • Number of of PV1 alarn OBs 3; 0B 55-57 • Number of asynchronous error OBs 2; 0B 100, 102 • Number of synchronous error OBs 9; 0B 80-88 • Number of synchronous error OBs 2; 0B 121, 122 • Number of synchronous error OBs 2; 0B 121, 122 • Number of synchronous error OBs 2; 0B 121, 122 • Number of synchronous error OBs 2; 0B 121, 122 • Number of synchronous error OBs 2; 0B 121, 122 • Number of synchronous error OBs 2; 0B 121, 122 • Number of synchronous error OBs 2; 0B 121, 122 • Number of synchronous error OBs 2; 0B 121, 122 • Number 2; 0B 22, 122 • Number 2; 0B 22, 122 • Number 2; 0B 22, 122 • Outer imit 0 - upper limit 0		
- Size, max.64 kbyle- Number of free cycle OBs1; OB 1- Number of tine alarm OBs4; OB 10-13- Number of delay alarm OBs4; OB 20-23- Number of process alarm OBs4; OB 32-35- Number of process alarm OBs4; OB 32-35- Number of process alarm OBs4; OB 40-43- Number of process alarm OBs3; OB 55-57- Number of synchronous error OBs2; OB 100, 102- Number of synchronous error OBs9; OB 80-88- Number of synchronous error OBs24- Number of synchronous error OBs24- Additional within an error OB1- Per priority class24- additubal2048- Reentivity2048- enters2047- upper limit0- upper limit2047- upper limit0- upper limit0- upper limit0- upper limit0- upper limit0- upper limit0- upper limit0<		
Number of free cycle OBs1, 0B 1• Number of time alarm OBs4, 0B 10-13• Number of delay alarm OBs4, 0B 32-33• Number of opcics alarm OBs4, 0B 32-35• Number of process alarm OBs3, 0B 55-57• Number of DPV1 alarn OBs3, 0B 55-57• Number of synchronous error OBs2, 0B 10, 102• Number of synchronous error OBs2, 0B 121, 122• Number of synchronous error OBs2, 0B 121, 122• Number of synchronous error OBs2, 0B 121, 122• Per priority class24• additional within an error OB1• Number2048• Retentivity2048• Retentivity2048• Counter2047• Lower limit0- upper limit2047• proper limit99• Drower limit99• InvertentivitySFB• Number2048• Number2048• number2048• Lower limit0- upper limit2047• presetVes• Number2048• Number2048• Number2048• Number2048• Number2048• Preset2048• Number2048• Internet2047• Internet2047• Lower limit0• Lower limit2047• Lower limit2047• Lower limit2047• Lower limit2047• Lower limit2047• L	 Number, max. 	see instruction list
• Number of time and OBs4. 0B 10-13• Number of delay alarm OBs4. 0B 20-23• Number of cyclic interrupt OBs4. 0B 32-35• Number of process alarn OBs2. 0B 40-43• Number of DPV1 alarm OBs2. 0B 100, 102• Number of dstutp OBs2. 0B 100, 102• Number of synchronous error OBs2. 0B 100, 102• Number of synchronous error OBs2. 0B 121, 122• Number of synchronous error OBs2. 0B 121, 122• Number of synchronous error OBs2. 0B 121, 122• Number of synchronous error OBs2• additional within an error OB1• Counters, tuners and their retentivity2• Aumber2. 048• Number2. 048• Number2. 047- adjustable2. 047- ouver limit0- ouver limit999• Dever limit999• Dever limit999• ForesetVes• TypeSF• Number2. 048• Number2. 048• StimesVes• ouver limit99• Ouver limit99• Outer Intertertertertertertertertertertertertert	• Size, max.	64 kbyte
• Number of time alarm OBs4, 0B 10-13• Number of delay alarm OBs4, 0B 20-23• Number of cyclic interrupt OBs4, 0B 20-23• Number of process alarm OBs4, 0B 40-43• Number of DPV 1 alarm OBs2, 0B 40-43• Number of startup OBs2, 0B 100, 102• Number of synchronous error OBs9, 0B 80-88• Number of synchronous error OBs2, 0B 121, 122• Number of synchronous error OBs2, 0B 121, 122• Number of synchronous error OBs2, 0B 121, 122• Per priority class2, 4• additional within an error OB1• Counters, tuners and their retentivity2• Aumober2, 048• Number0- adjustableVes- olover limit0- olover limit0- ouper limit2, 047- preset2, 016 Z, 7• Counters, tuners99• EcounterVes• presentVes• presentVes• TypeSF• NumberVes• TypeSF• NumberVes• TypeSF• NumberVes• TypeSF• NumberVes• TypeVes• AdjustableVes• TypeSF• Number2047• ouper limit2047• ouper limit2047• ouper limit2047• ouper limit2047• ouper limit2047• ouper limit• ouper lim		1; OB 1
• Number of delay alarm OBs4. 0B 20-23• Number of cyclic interrupt OBs4. 0B 32-35• Number of process alarm OBs3. 0B 55-57• Number of startup OBs2. 0B 100, 102• Number of asynchronous error OBs2. 0B 100, 102• Number of asynchronous error OBs2. 0B 121, 122• Number of synchronous error OBs2. 0B 121, 122• Auther of synchronous error OBs2. 0B 121, 122• Auther of synchronous error OBs2. 0B 121, 122• Auther of synchronous error OBs1• Auther of synchronous error OBs2. 0B 121, 122• Auther of synchronous error OBs2. 048• Auther of synchronous error OBs2. 047• Auther of synchronous error OBs2. 048• Author of the synchronous error OBs2. 048• Author of the synchronous error of the synchron	-	4; OB 10-13
Number of cyclic interupt OBS4, OB 32-35Number of process alarm OBS4, OB 40-43Number of DPV1 alarm OBS3, OB 55-57Number of strupt OBS2, OB 100, 102Number of strupt OBS2, OB 80-88Number of synchronous error OBS2, OB 80-88Number of synchronous error OBS2, OB 121, 122Number of synchronous error OBS24- eper priority class24- additional within an error OB1CounterS7 counter2048- additional within an error OB2048Retentivity2047- adjustableYes- lower limit0- upper limit2047- lower limit0- upper limit999EC counter1- lower limit0- upper limit2048- presetVes- foresent1- lower limit0- upper limit2047- upper limit2048- foresentVes- foresentVes- foresentVes- fore limit0- upper limit2048- fore limit2048- fore limit2048- fore limit2048- fore limit2048- fore limit2048- equistableYes- adjustable2048- inter limit0- upper limit2047- upper limit2047- upper limit2047- upper l		
• Number of process alarn OBs4.0 B 40-43• Number of DPV1 alarn OBs3.0 B 55-57• Number of startup OBs2.0 B 100, 102• Number of asynchronous error OBs9.0 B 80-88• Number of asynchronous error OBs2.0 B 121, 122Nesting depth24• per priority class2.4• additional within an error OB12.048SocietySocietyOuters timers and their retentivitySocietySocietyOuters timers and their retentivitySocietyOuters timers and their retentivity- adjustableYes- adjustableYesOuter timet- Prover timit- adjustableYesOuter timet (inited only by RAM capacity)Society- adjustableYes- adjustableYes		

— upper limit	9 990 s
IEC timer	
• present	Yes
• Туре	SFB
• Number	Unlimited (limited only by RAM capacity)
Data areas and their retentivity	
retentive data area in total	Total working and load memory (with backup battery)
Flag	
• Number, max.	8 192 byte
Retentivity available	Yes
Retentivity preset	MB 0 to MB 15
 Number of clock memories 	8; in 1 memory byte
Data blocks	
• Number, max.	6 000; Number range: 1 to 16000
• Size, max.	64 kbyte
Local data	
• adjustable, max.	16 kbyte
• preset	8 kbyte
Address area	
I/O address area	
Inputs	8 kbyte
Outputs	8 kbyte
of which distributed	
— MPI/DP interface, inputs	2 kbyte
— MPI/DP interface, outputs	2 kbyte
— DP interface, inputs	6 kbyte
— DP interface, outputs	6 kbyte
— PROFINET interface, inputs	8 kbyte
— PROFINET interface, outputs	8 kbyte
Process image	
 Inputs, adjustable 	8 kbyte
• Outputs, adjustable	8 kbyte
• Inputs, default	256 byte
• Outputs, default	256 byte
• consistent data, max.	244 byte
 Access to consistent data in process image 	Yes
Subprocess images	
 Number of subprocess images, max. 	15
Digital channels	
Inputs	65 536
— of which central	65 536

Outputs	65 536
— of which central	65 536
Analog channels	
Inputs	4 096
— of which central	4 096
Outputs	4 096
— of which central	4 096
Hardware configuration	
Number of expansion units, max.	21
connectable OPs	63
Multicomputing	No
Interface modules	
 Number of connectable IMs (total), max. 	6
 Number of connectable IM 460s, max. 	6
 Number of connectable IM 463s, max. 	4; Single mode only
Number of DP masters	
integrated	2
• via CP	10; CP 443-5 Extended
 Mixed mode IM + CP permitted 	No
• via interface module	0
Number of IO Controllers	
 integrated 	1
• via CP	0
Number of operable FMs and CPs (recommended)	
• FM	See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections
● CP, PtP	See manual Automation System S7-400H fault-tolerant systems. Limited by number of slots and number of connections
 PROFIBUS and Ethernet CPs 	14; Of which max. 10 CP as DP master
Slots	
required slots	2
Time of day	
Clock	
 Hardware clock (real-time) 	Yes
 retentive and synchronizable 	Yes
Resolution	1 ms
 Deviation per day (buffered), max. 	1.7 s; Power off
 Deviation per day (unbuffered), max. 	8.6 s; Power on
Operating hours counter	
Number	16
Number/Number range	0 to 15

 Range of values 	SFCs 2, 3 and 4: 0 to 32767 hours SFC 101: 0 to 2^31 - 1 hours
Granularity	1 hour
retentive	Yes
Clock synchronization	
• supported	Yes
• to MPI, master	Yes
• to MPI, slave	Yes
• to DP, master	Yes
• to DP, slave	Yes
• in AS, master	Yes
● in AS, slave	Yes
• on Ethernet via NTP	Yes; As client
Time difference in system when synchronizing via	
• Ethernet, max.	10 ms; Via NTP
• MPI, max.	200 ms
linker for an	
Interfaces Number of RS 485 interfaces	2
Number of other interfaces	2; Fiber-optic interface
1. Interface	
Interface type	Integrated
Physics	RS 485 / PROFIBUS + MPI
Isolated	Yes
Power supply to interface (15 to 30 V DC), max.	150 mA
Number of connection resources	MPI: 32, DP: 16
Functionality	
• MPI	Yes
 PROFIBUS DP master 	Yes
PROFIBUS DP slave	No
MPI	
 Number of connections 	32; If a diagnostics repeater is used on the line, the number of connection resources on the line is reduced by 1
 Transmission rate, max. 	12 Mbit/s
Services	
— PG/OP communication	Yes
— Routing	Yes
— Global data communication	No
— S7 basic communication	No
— S7 communication	Yes
- S7 communication, as client	Yes
— S7 communication, as server	Yes
DP master	

 Number of connections, max. 	16; If a diagnostics repeater is used on the line, the number of connection resources on the line is reduced by 1
 Transmission rate, max. 	12 Mbit/s
 Number of DP slaves, max. 	32
Services	
— PG/OP communication	Yes
— Routing	Yes
— Global data communication	No
— S7 basic communication	No
— S7 communication	Yes
— S7 communication, as client	Yes
— S7 communication, as server	Yes
— Equidistance	No
— Isochronous mode	No
— SYNC/FREEZE	No
— Activation/deactivation of DP slaves	No
 — Direct data exchange (slave-to-slave communication) 	No
— DPV1	Yes
Address area	
— Inputs, max.	2 kbyte
— Outputs, max.	2 kbyte
User data per DP slave	
— User data per DP slave, max.	244 byte
— Inputs, max.	244 byte
— Outputs, max.	244 byte
— Slots, max.	244
— per slot, max.	128 byte
DP slave	
 Number of connections 	No configuration of CPU as DP slave
2. Interface	
Interface type	PROFINET
Physics	Ethernet RJ45
Isolated	Yes
automatic detection of transmission rate	Yes; Autosensing
Autonegotiation	Yes
Autocrossing	Yes
Change of IP address at runtime, supported	No
Number of connection resources	64

Media redundancy	
supported	Yes
 Switchover time on line break, typ. 	200 ms
 Number of stations in the ring, max. 	50
Functionality	
PROFINET IO Controller	Yes
PROFINET IO Device	No
• PROFINET CBA	No
PROFIBUS DP master	No
PROFIBUS DP slave	No
Open IE communication	Yes
• Web server	No
 Point-to-point connection 	No
PROFINET IO Controller	
• Transmission rate, max.	100 Mbit/s
Services	
— PG/OP communication	Yes
— S7 routing	Yes
— S7 communication	Yes
— Isochronous mode	No
— Open IE communication	Yes
— Shared device	Yes; Single mode only
— Prioritized startup	No
 — Number of connectable IO Devices, max. 	256; In redundant mode via both interfaces
 — Number of connectable IO Devices for RT, max. 	256
— of which in line, max.	256
- Activation/deactivation of IO Devices	No
 IO Devices changing during operation (partner ports), supported 	No
- Device replacement without swap medium	Yes
— Send cycles	250 μs, 500 μs, 1 ms, 2 ms, 4 ms
— Updating time	250 μs to 512 ms, minimum value depends on the number of configured user data and the configured single or redundant mode
Address area	
— Inputs, max.	8 kbyte
— Outputs, max.	8 kbyte
— User data consistency, max.	1 024 byte
Open IE communication	
 Number of connections, max. 	62
 Local port numbers used at the system end 	0, 20, 21, 25, 102, 135, 161, 34962, 34963, 34964, 65532, 65533, 65534, 65535

• Keep-alive function, supported

Yes

3. Interface	
Interface type	Integrated
Physics	RS 485 / PROFIBUS
Power supply to interface (15 to 30 V DC), max.	150 mA
Number of connection resources	16
Functionality	Yes
PROFIBUS DP master	
PROFIBUS DP slave DP master	No
	16
Number of connections, max.	
• Transmission rate, max.	12 Mbit/s
Number of DP slaves, max.	96
Services	Vee
— PG/OP communication	Yes
— Routing	Yes
— Global data communication	No
— S7 basic communication	No
— S7 communication	Yes
— S7 communication, as client	Yes
— S7 communication, as server	Yes
— Equidistance	No
— Isochronous mode	No
- SYNC/FREEZE	No
 Activation/deactivation of DP slaves 	No
 — Direct data exchange (slave-to-slave communication) 	No
— DPV0	Yes
— DPV1	Yes
Address area	
— Inputs, max.	6 kbyte
— Outputs, max.	6 kbyte
User data per DP slave	
— User data per DP slave, max.	244 byte
— Inputs, max.	244 byte
— Outputs, max.	244 byte
— Slots, max.	244
— per slot, max.	128 byte
1. Interface	
Interface type	Pluggable synchronization submodule (FO)

Plug-in interface modules	Synchronization modules 6ES7960-1AA06-0XA0 or 6ES7960- 1AB06-0XA0
5. Interface	
Interface type	Pluggable synchronization submodule (FO)
Plug-in interface modules	Synchronization modules 6ES7960-1AA06-0XA0 or 6ES7960- 1AB06-0XA0
Isochronous mode	
Isochronous operation (application synchronized up to terminal)	No
Equidistance	No
Communication functions	
PG/OP communication	Yes
 Number of connectable OPs without message processing 	63
 Number of connectable OPs with message processing 	63; When using Alarm_S/SQ and Alarm_D/DQ
Data record routing	Yes
S7 routing	Yes
Global data communication	
• supported	No
S7 basic communication	
• supported	No
S7 communication	
• supported	Yes
• as server	Yes
• as client	Yes
• User data per job, max.	64 kbyte
 User data per job (of which consistent), max. 	462 byte; 1 variable
S5 compatible communication	
• supported	Yes; (via CP max. 10 and FC AG_SEND and FC AG_RECV)
• User data per job, max.	8 kbyte
 User data per job (of which consistent), max. 	240 byte
 Number of simultaneous AG-SEND/AG-RECV orders per CPU, max. 	64/64
Standard communication (FMS)	
• supported	Yes; Via CP and loadable FB
Open IE communication	
• TCP/IP	Yes; via integrated PROFINET interface and loadable FBs
— Number of connections, max.	62
— Data length, max.	32 kbyte
 several passive connections per port, supported 	Yes

• ISO-on-TCP (RFC1006)	Yes; Via integrated PROFINET interface or CP 443-1 and
	loadable FBs
— Number of connections, max.	62
— Data length, max.	32 kbyte; 1452 bytes via CP 443-1 Adv.
• UDP	Yes; via integrated PROFINET interface and loadable FBs
— Number of connections, max.	62
— Data length, max.	1 472 byte
Web server	
• supported	No
Number of connections	
• overall	64
 usable for PG communication 	
- reserved for PG communication	1
— adjustable for PG communication, max.	0
 usable for OP communication 	
— reserved for OP communication	1
— adjustable for OP communication, max.	0
 usable for S7 basic communication 	
- reserved for S7 basic communication	0
— adjustable for S7 basic communication,	0
max.	
 usable for S7 communication 	
 reserved for S7 communication 	0
 adjustable for S7 communication, max. 	0
• usable for routing	
— reserved for routing	0
— adjustable for routing, max.	0
C7 massage functions	
S7 message functions Number of login stations for message functions, max.	63; Max. 63 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 8
	with Alarm, Alarm_8, Alarm_8P, Notify and Notify_8 (e.g. WinCC)
Symbol-related messages	No
SCAN procedure	No
Block related messages	Yes
Process diagnostic messages	Yes
simultaneously active Alarm-S blocks, max.	400; Simultaneously active alarm_S/SQ blocks or alarm_D/DQ blocks
Alarm 8-blocks	Yes
 Number of instances for alarm 8 and S7 	2 500
communication blocks, max.	
• preset, max.	900
Process control messages	Yes

Number of archives that can log on simultaneously (SFB 37 AR_SEND)	16
Test commissioning functions	
Status block	Yes
Single step	Yes
Number of breakpoints	16
Status/control	
 Status/control variable 	Yes; Up to 16 variable tables
Variables	Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters
 Number of variables, max. 	70
Forcing	
Forcing	Yes
 Forcing, variables 	Inputs/outputs, bit memories, distributed I/Os
 Number of variables, max. 	256
Diagnostic buffer	
• present	Yes
 Number of entries, max. 	3 200
— adjustable	Yes
— preset	120
Service data	
• can be read out	Yes
EMC	
Emission of radio interference acc. to EN 55 011	
 Limit class A, for use in industrial areas 	Yes
• Limit class B, for use in residential areas	No
Standards, approvals, certificates CE mark	Yes
Ambient conditions	
Ambient temperature during operation	
• min.	-25 °C; = Tmin
• max.	70 °C; = Tmax; @ 60°C for UL/ATEX/FM and safety-related application
Ambient temperature during storage/transportation	
• min.	-40 °C
● max.	70 °C
Extended ambient conditions	
 relative to ambient temperature-atmospheric pressure-installation altitude 	Tmin Tmax at 1 080 hPa 795 hPa (-1 000 m +2 000 m) // Tmin (Tmax - 10 K) at 795 hPa 658 hPa (+2 000 m +3 500 m) // Tmin (Tmax - 20 K) at 658 hPa 540 hPa (+3 500 m +5 000 m). For "F-Systems" applications max. +2 000 m above sea level permissible

Relative humidity			
 With condensation, tested in accordance with IEC 60068-2-38, max. 	100 %; RH incl. condensation/frost (no commissioning under condensation conditions)		
Resistance			
 against biologically active substances / conformity with EN 60721-3-3 	Yes; Class 3B2 mold, fungus and dry rot spores (with the exception of fauna). The supplied connector covers must remain on the unused interfaces during operation!		
 against chemically active substances / conformity with EN 60721-3-3 	Yes; Class 3C4 (RH < 75%) incl. salt spray according to EN 60068-2-52 (degree of severity 3). The supplied connector covers must remain on the unused interfaces during operation!		
 against mechanically active substances / conformity with EN 60721-3-3 	Yes; Class 3S4 incl. sand, dust. The supplied connector covers must remain on the unused interfaces during operation!		
Configuration			
Configuration software			
• STEP 7	Yes		
Programming			
Command set	see instruction list		
Nesting levels	7		

Yes • Access to consistent data in process image

	· Access to consistent data in process image	100
	 System functions (SFC) 	see instruction list
	 System function blocks (SFB) 	see instruction list
	Programming language	
	— LAD	Yes
	— FBD	Yes
	— STL	Yes
	— SCL	Yes
	— CFC	Yes
	— GRAPH	Yes
	— HiGraph®	Yes
Number of simultaneously active SFCs		
	— RD_REC	8
	— WR_REC	8
	— WR_PARM	8
	— PARM_MOD	1
	— WR_DPARM	2
	— DPNRM_DG	8
	— RDSYSST	8

1

8

8

- DP_TOPOL

- RDREC

- WRREC Know-how protection

Number of simultaneously active SFBs

 User program protection/password protection Block encryption 	Yes Yes; With S7 block Privacy		
Dimensions			
Width	50 mm		
Height	290 mm		
Depth	219 mm		
Weights			
Weight, approx.	995 g		
last modified:	03/11/2017		