SIEMENS

Data sheet

6ES7412-2EK07-0AB0

SIMATIC S7-400, CPU 412-2 PN CENTRAL PROCESSING UNIT WITH: 1 MB WORKING MEMORY, (0,5 MB CODE; 0,5 MB DATA) INTERFACES: 1. IF MPI/DP 12 MBIT/S (X1), 2. IF ETHERNET/PROFINET (X5),

General information	
Product type designation	CPU 412-2 PN
Hardware product version	01
Firmware version	V7.0
Engineering with	
Programming package	STEP 7 V5.5 or higher with HSP 262
CiR – Configuration in RUN	
CiR synchronization time, basic load	100 ms
CiR synchronization time, time per I/O byte	30 µs
Supply voltage	
Rated value (DC)	
• 24 V DC	No; Power supply via system power supply
Input current	
from backplane bus 5 V DC, typ.	1.1 A
from backplane bus 5 V DC, max.	1.4 A
from backplane bus 24 V DC, max.	150 mA; 150 mA per DP interface
from interface 5 V DC, max.	90 mA; At the DP interface
Power loss	
Power loss, typ.	5.5 W
Power loss, max.	7 W
Memory	
Type of memory	RAM
Work memory	
• integrated	1 Mbyte
• integrated (for program)	512 kbyte
• integrated (for data)	512 kbyte
• expandable	No
Load memory	
expandable FEPROM	Yes; with Memory Card (FLASH)
• expandable FEPROM, max.	64 Mbyte
• integrated RAM, max.	512 kbyte
expandable RAM	Yes; with Memory Card (RAM)
·	

expandable RAM, max.	64 Mbyte
Backup	
• present	Yes
with battery	Yes; all data
without battery	No
Battery	
Backup battery	
Backup current, typ.	180 μA; up to 40 °C
 Backup current, max. 	850 μΑ
Backup time, max.	Dealt with in the module data manual with the secondary conditions and the factors of influence
 Feeding of external backup voltage to CPU 	5 V DC to 15 V DC
CPU processing times	
for bit operations, typ.	31.25 ns
for word operations, typ.	31.25 ns
for fixed point arithmetic, typ.	31.25 ns
for floating point arithmetic, typ.	62.5 ns
CPU-blocks	
DB	
Number, max.	3 000; Number range: 1 to 16000
• Size, max.	64 kbyte
FB	
Number, max.	1 500; Number range: 0 to 7999
• Size, max.	64 kbyte
FC	
Number, max.	1 500; Number range: 0 to 7999
• Size, max.	64 kbyte
OB	
Number, max.	see instruction list
• Size, max.	64 kbyte
Number of free cycle OBs	1; OB 1
 Number of time alarm OBs 	2; OB 10, 11
Number of delay alarm OBs	2; OB 20, 21
Number of cyclic interrupt OBs	2; OB 32, 35 (shortest cycle that can be set = 500 µs)
Number of process alarm OBs	2; OB 40, 41
 Number of DPV1 alarm OBs 	3; OB 55-57
Number of isochronous mode OBs	2; OB 61-62
Number of multicomputing OBs	1; OB 60
Number of background OBs	1; OB 90
Number of startup OBs	3; OB 100-102
Number of asynchronous error OBs	9; OB 80-88

 Number of synchronous error OBs 	2; OB 121, 122
Nesting depth	
• per priority class	24
additional within an error OB	1
Counters, timers and their retentivity S7 counter	
Number	2 048
	2 040
Retentivity	Yes
— adjustable	
— lower limit	0
— upper limit	2 047
— preset	Z 0 to Z 7
Counting range	
— lower limit	0
— upper limit	999
IEC counter	
• Number	Unlimited (limited only by RAM capacity)
S7 times	
• Number	2 048
Retentivity	
— adjustable	Yes
— lower limit	0
— upper limit	2 047
— preset	No times retentive
Time range	
— lower limit	10 ms
— upper limit	9 990 s
IEC timer	
• present	Yes
• Type	SFB
• Number	Unlimited (limited only by RAM capacity)
Data areas and their retentivity	
retentive data area in total	Total working and load memory (with backup battery)
Flag	
• Number, max.	4 kbyte; Size of bit memory address area
 Retentivity available 	Yes
 Retentivity preset 	MB 0 to MB 15
 Number of clock memories 	8; in 1 memory byte
Data blocks	
• Number, max.	3 000; Number range: 1 to 16000
• Size, max.	64 kbyte

Local data	
adjustable, max.	8 kbyte
• preset	4 kbyte
A days a cus a	
Address area I/O address area	
• Inputs	4 kbyte
Outputs	4 kbyte
of which distributed	·
— MPI/DP interface, inputs	2 kbyte
MPI/DP interface, outputs	2 kbyte
— PROFINET interface, inputs	4 kbyte
— PROFINET interface, outputs	4 kbyte
Process image	.,
Inputs, adjustable	4 kbyte
Outputs, adjustable	4 kbyte
Inputs, default	128 byte
Outputs, default	128 byte
• consistent data, max.	244 byte
Access to consistent data in process image	Yes
Subprocess images	
Number of subprocess images, max.	15
Digital channels	
• Inputs	32 768
— of which central	32 768
Outputs	32 768
— of which central	32 768
Analog channels	
● Inputs	2 048
— of which central	2 048
Outputs	2 048
— of which central	2 048
Hardware configuration	
Number of expansion units, max.	21
connectable OPs	47
Multicomputing	Yes; 4 CPUs max. (with UR1 or UR2)
Interface modules	
 Number of connectable IMs (total), max. 	6
 Number of connectable IM 460s, max. 	6
 Number of connectable IM 463s, max. 	4; IM 463-2
Number of DP masters	
• integrated	1

● via CP	10; CP 443-5 Extended
• via IM 467	4
Mixed mode IM + CP permitted	No; IM 467 cannot be used jointly with CP 443-5 Ext. or CP 443-1 in PROFINET IO mode
• via interface module	0
 Number of pluggable S5 modules (via adapter capsule in central device), max. 	6
Number of IO Controllers	
• integrated	1
• via CP	4; Max. 4 in the central controller; no mixed operation of different CP 443-1 types in PROFINET IO mode
Number of operable FMs and CPs (recommended)	
• FM	Limited by number of slots and number of connections
• CP, PtP	CP 440: Limited by number of slots; CP 441: Limited by number of slots and number of connections
PROFIBUS and Ethernet CPs	14; In total max. 10 CPs as DP master and PROFINET controller, of which up to 10 IMs or CPs as DP master and up to 4 CPs as PROFINET controller
Slots	
• required slots	1
Time of day	
Time of day Clock	
	Yes
Clock	Yes Yes
Clock • Hardware clock (real-time)	
Clock • Hardware clock (real-time) • retentive and synchronizable	Yes
Clock • Hardware clock (real-time) • retentive and synchronizable • Resolution	Yes 1 ms
Clock • Hardware clock (real-time) • retentive and synchronizable • Resolution • Deviation per day (buffered), max.	Yes 1 ms 1.7 s; Power off
Clock • Hardware clock (real-time) • retentive and synchronizable • Resolution • Deviation per day (buffered), max. • Deviation per day (unbuffered), max.	Yes 1 ms 1.7 s; Power off
Clock Hardware clock (real-time) retentive and synchronizable Resolution Deviation per day (buffered), max. Deviation per day (unbuffered), max. Operating hours counter	Yes 1 ms 1.7 s; Power off 8.6 s; For power On
Clock • Hardware clock (real-time) • retentive and synchronizable • Resolution • Deviation per day (buffered), max. • Deviation per day (unbuffered), max. Operating hours counter • Number	Yes 1 ms 1.7 s; Power off 8.6 s; For power On
Clock Hardware clock (real-time) retentive and synchronizable Resolution Deviation per day (buffered), max. Deviation per day (unbuffered), max. Operating hours counter Number Number	Yes 1 ms 1.7 s; Power off 8.6 s; For power On 16 0 to 15
Clock • Hardware clock (real-time) • retentive and synchronizable • Resolution • Deviation per day (buffered), max. • Deviation per day (unbuffered), max. Operating hours counter • Number • Number • Number/Number range • Range of values	Yes 1 ms 1.7 s; Power off 8.6 s; For power On 16 0 to 15 SFCs 2, 3 and 4: 0 to 32767 hours SFC 101: 0 to 2^31 - 1 hours
Clock • Hardware clock (real-time) • retentive and synchronizable • Resolution • Deviation per day (buffered), max. • Deviation per day (unbuffered), max. Operating hours counter • Number • Number/Number range • Range of values • Granularity	Yes 1 ms 1.7 s; Power off 8.6 s; For power On 16 0 to 15 SFCs 2, 3 and 4: 0 to 32767 hours SFC 101: 0 to 2^31 - 1 hours 1 hour
Clock Hardware clock (real-time) retentive and synchronizable Resolution Deviation per day (buffered), max. Deviation per day (unbuffered), max. Operating hours counter Number Number Range of values Granularity retentive	Yes 1 ms 1.7 s; Power off 8.6 s; For power On 16 0 to 15 SFCs 2, 3 and 4: 0 to 32767 hours SFC 101: 0 to 2^31 - 1 hours 1 hour
Clock Hardware clock (real-time) retentive and synchronizable Resolution Deviation per day (buffered), max. Deviation per day (unbuffered), max. Operating hours counter Number Number Range of values Granularity retentive Clock synchronization	Yes 1 ms 1.7 s; Power off 8.6 s; For power On 16 0 to 15 SFCs 2, 3 and 4: 0 to 32767 hours SFC 101: 0 to 2^31 - 1 hours 1 hour Yes
Clock Hardware clock (real-time) retentive and synchronizable Resolution Deviation per day (buffered), max. Deviation per day (unbuffered), max. Operating hours counter Number Number Range of values Granularity retentive Clock synchronization supported	Yes 1 ms 1.7 s; Power off 8.6 s; For power On 16 0 to 15 SFCs 2, 3 and 4: 0 to 32767 hours SFC 101: 0 to 2^31 - 1 hours 1 hour Yes Yes
Clock • Hardware clock (real-time) • retentive and synchronizable • Resolution • Deviation per day (buffered), max. • Deviation per day (unbuffered), max. Operating hours counter • Number • Number • Number range • Range of values • Granularity • retentive Clock synchronization • supported • to MPI, master	Yes 1 ms 1.7 s; Power off 8.6 s; For power On 16 0 to 15 SFCs 2, 3 and 4: 0 to 32767 hours SFC 101: 0 to 2^31 - 1 hours 1 hour Yes Yes Yes
Clock Hardware clock (real-time) retentive and synchronizable Resolution Deviation per day (buffered), max. Deviation per day (unbuffered), max. Periation per day (unbuffered), max. Operating hours counter Number Number Range of values Range of values Granularity retentive Clock synchronization supported to MPI, master to MPI, slave	Yes 1 ms 1.7 s; Power off 8.6 s; For power On 16 0 to 15 SFCs 2, 3 and 4: 0 to 32767 hours SFC 101: 0 to 2^31 - 1 hours 1 hour Yes Yes Yes Yes Yes
Clock Hardware clock (real-time) retentive and synchronizable Resolution Deviation per day (buffered), max. Deviation per day (unbuffered), max. Operating hours counter Number Number Number/Number range Range of values Granularity retentive Clock synchronization supported to MPI, master to DP, master	Yes 1 ms 1.7 s; Power off 8.6 s; For power On 16 0 to 15 SFCs 2, 3 and 4: 0 to 32767 hours SFC 101: 0 to 2^31 - 1 hours 1 hour Yes Yes Yes Yes Yes Yes
Clock Hardware clock (real-time) retentive and synchronizable Resolution Deviation per day (buffered), max. Deviation per day (unbuffered), max. Deviation per day (unbuffered), max. Operating hours counter Number Number Number/Number range Range of values Granularity retentive Clock synchronization supported to MPI, master to MPI, slave to DP, master to DP, slave	Yes 1 ms 1.7 s; Power off 8.6 s; For power On 16 0 to 15 SFCs 2, 3 and 4: 0 to 32767 hours SFC 101: 0 to 2^31 - 1 hours 1 hour Yes Yes Yes Yes Yes Yes Yes Yes

● to IF 964 DP	No
Time difference in system when synchronizing via	
• Ethernet, max.	10 ms
• MPI, max.	200 ms
Interfaces	
Interfaces/bus type	1 x MPI/PROFIBUS DP, 1 x PROFINET (2 ports)
Number of RS 485 interfaces	1; Combined MPI / PROFIBUS DP
1. Interface	
Interface type	Integrated
Physics	RS 485 / PROFIBUS + MPI
Isolated	Yes
Power supply to interface (15 to 30 V DC), max.	150 mA
Number of connection resources	MPI: 32, DP: 16
Functionality	
• MPI	Yes
PROFIBUS DP master	Yes
PROFIBUS DP slave	Yes
MPI	
Number of connections	32; If a diagnostics repeater is used on the line, the number of
	connection resources on the line is reduced by 1
 Transmission rate, max. 	12 Mbit/s
Services	
— PG/OP communication	Yes
— Routing	Yes
 Global data communication 	Yes
 S7 basic communication 	Yes
— S7 communication	Yes
— S7 communication, as client	Yes
— S7 communication, as server	Yes
DP master	
Number of connections, max.	16; If a diagnostics repeater is used on the line, the number of
, , , , , , , , , , , , , , , , , , , ,	connection resources on the line is reduced by 1
• Transmission rate, max.	12 Mbit/s
Number of DP slaves, max.	32
Services	
— PG/OP communication	Yes
— Routing	Yes; S7 routing
Global data communication	No
S7 basic communication	Yes
— S7 communication	Yes
— S7 communication, as client	Yes
— 57 communication, as chefit	, 60

 S7 communication, as server 	Yes
— Equidistance	Yes
— Isochronous mode	Yes
— SYNC/FREEZE	Yes
 Activation/deactivation of DP slaves 	Yes
 Direct data exchange (slave-to-slave communication) 	Yes
— DPV1	Yes
Address area	
— Inputs, max.	2 kbyte
— Outputs, max.	2 kbyte
User data per DP slave	
— User data per DP slave, max.	244 byte
— Inputs, max.	244 byte
— Outputs, max.	244 byte
— Slots, max.	244
— per slot, max.	128 byte
DP slave	
Number of connections	16
• GSD file	http://support.automation.siemens.com/WW/view/en/113652
Transmission rate, max.	12 Mbit/s
automatic baud rate search	No
• Address area, max.	32; Virtual slots
• User data per address area, max.	32 byte
— of which consistent, max.	32 byte
Services	
— PG/OP communication	Yes; with interface active
— S7 routing	Yes; with interface active
 Global data communication 	No
 — S7 basic communication 	No
— S7 communication	Yes
 S7 communication, as client 	Yes
 S7 communication, as server 	Yes
 — Direct data exchange (slave-to-slave communication) 	No
— DPV1	No
Transfer memory	
— Inputs	244 byte
— Outputs	244 byte
2. Interface	
Interface type	PROFINET

Physics	Ethernet RJ45
Isolated	Yes
automatic detection of transmission rate	Yes; Autosensing
Autonegotiation	Yes
Autocrossing	Yes
Change of IP address at runtime, supported	Yes; Assignment by higher-level IO-Controller or by the user program with SFB104 "IP_CONF"
Number of connection resources	48
Interface types	
Number of ports	2
• integrated switch	Yes
Media redundancy	
• supported	Yes
 Switchover time on line break, typ. 	200 ms
 Number of stations in the ring, max. 	50
Functionality	
PROFINET IO Controller	Yes
PROFINET IO Device	Yes
PROFINET CBA	Yes
PROFIBUS DP master	No
PROFIBUS DP slave	No
Open IE communication	Yes
Web server	Yes
— Number of HTTP clients	5
Point-to-point connection	No
PROFINET IO Controller	
Transmission rate, max.	100 Mbit/s
Services	
— PG/OP communication	Yes
— S7 routing	Yes
— S7 communication	Yes
— Isochronous mode	Yes; Only with IRT and the High Performance option
— Open IE communication	Yes
— Shared device	Yes
Prioritized startup	Yes
Number of IO devices with prioritized startup, max.	32
Number of connectable IO Devices, max.	256
Of which IO devices with IRT, max.	64
of which in line, max.	64

- Number of connectable IO Devices for RT, max. - of which in line, max. - Activation/deactivation of IO Devices - Number of IO Devices that can be simultaneously activated/deactivated, max. - IO Devices changing during operation (partner ports), supported - Number of IO Devices per tool, max. - Device replacement without swap medium - Send cycles - Updating time - Send cycles - Inputs, max. - Outputs, max. - Outputs, max. - User data consistency, max. - PG/OP communication - S7 routing - S7 communication - IRT - Prioritized startup - Shared device - Number of IO Controllers with shared device - Number of IO Controllers with shared device - Number of IO Controllers with shared device - Number, max. - Outputs, max. - Outputs, max. - Outputs, max. - IRT - Prioritized startup - Shared device - Number of IO Controllers with shared device - Number, max. - Outputs, ma	— of which in line, max.	61
- of which in line, max Activation/deactivation of IO Devices - Number of IO Devices that can be simultaneously activated/deactivated, max IO Devices changing during operation (partner ports), supported - Number of IO Devices per tool, max. - IO Devices changing during operation (partner ports), supported - Number of IO Devices per tool, max. - Device replacement without swap medium - Send cycles - Updating time updating time time time time time time time time	 Number of connectable IO Devices for RT, 	256
- Activation/deactivation of IO Devices - Number of IO Devices that can be simultaneously activated/deactivated, max IO Devices changing during operation (partner ports), supported - Number of IO Devices per tool, max. - Number of IO Devices per tool, max. - Send cycles - Send cycles - Updating time - Send cycles - Updating time - Updating time - Send cycles - Updating time - Updating time - Send cycles and not be amount of configured user data, see - PROFINET IO, on the number of IO - Devices and on the amount of configured user data, see - PROFINET system description - Send cycles - PROFINET to Device - Services - PG/OP communication - Services - PG/OP communication - Services - PG/OP communication - Yes - Sommunication - Yes - IRT - Prioritized startup - Shared device - Number of IO Controllers with shared device, max. - Transfer memory - Inputs, max User data per submodule, max.	max.	
- Number of IO Devices that can be simultaneously activated/deactivated, max. - IO Devices changing during operation (partner ports), supported - Number of IO Devices per tool, max. - By Sarallel calls of the SFC 12 "D_ACT_DP" possible per line. Max. 32 IO Devices changing during operation (partner ports) are supported - Device replacement without swap medium - Send cycles - Device replacement without swap medium - Send cycles - Updating time - Updating time - Updating time - Updating time - So up to 512 ms; minimum value depends on preset communication share for PROFINET IO, on the number of IO Devices and on the amount of configured user data, see PROFINET system description - SPOSINET IO Device - Number of IO Controllers with shared device - Number of IO Controllers with shared device - Number, max User data per submodule, max. - User data per submodule, max. - User data per submodule, max. - User data per submodule, max.	— of which in line, max.	256
simultaneously activated/deactivated, max. — IO Devices changing during operation (partner ports), supported — Number of IO Devices per tool, max. — Device replacement without swap medium — Device replacement without swap medium — Send cycles — Updating time — Updating time time time time time time time time	 Activation/deactivation of IO Devices 	Yes
House changing during operation (partner ports), supported Number of IO Devices per tool, max. Number of IO Devices per tool, max. Number of IO Devices per tool, max. Send cycles Device replacement without swap medium Send cycles Updating time Updating time Devices and on the amount of configured user data, see PROFINET System description Address area Inputs, max. User data consistency, max. User data consistency, max. PST routing Services PC/IOP communication Yes Services PC/IOP communication Yes Services PC/IOP communication Yes Services PC/IOP communication Yes Services PC/IOP communication Services PC/IOP communication Yes Services PC/IOP communicatio	 Number of IO Devices that can be 	8
(partner ports), supported - Number of IO Devices per tool, max. 8; 8 parallel calls of the SFC 12 "D_ACT_DP" possible per line. Max. 32 IO Devices changing during operation (partner ports) are supported - Device replacement without swap medium - Send cycles - Updating time - Updating time time time time time time time time	simultaneously activated/deactivated, max.	
- Number of IO Devices per tool, max. - Number of IO Devices per tool, max. - By a parallel calls of the SFC 12 "D. ACT_DP" possible per line. - Max. 32 IO Devices changing during operation (partner ports) are supported - Device replacement without swap medium - Send cycles - Updating time - Updating time to serve the sum and the sum and the sum of IO Devices and on the amount of configured user data, see PROFINET IO Devices and on the amount of configured user data, see PROFINET IO Device services - PG/OP communication - Updating time - User data consistency, max. - User data consistency, max. - User data consistency, max. - User data per submodule, max.		Yes
Max. 32 IO Devices changing during operation (partner ports) are supported		
Send cycles Send cycles Updating time 250 μs, 500 μs, 1 ms, 2 ms, 4 ms additionally with IRT with high performance: 250 μs to 4 ms in 125 μs frame 250 μs to 512 ms; minimum value depends on preset communication share for PROFINET IO, on the number of IO Devices and on the amount of configured user data, see PROFINET system description Address area Inputs, max. User data consistency, max. Ves PROFINET IO Device Services PG/OP communication Yes Services 1 yes Services 1 yes Services 1 yes Services 1 yes 1 look promitized startup Yes Shared device Yes Number of IO Controllers with shared device No Ves Number of IO Controllers with shared device No Outputs, max. 1 440 byte; Per IO Controller with shared device Outputs, max. 1 440 byte; Per IO Controller with shared device Number, max. 1 440 byte; Per IO Controller with shared device Number, max. G4 User data per submodule, max.	— Number of IO Devices per tool, max.	Max. 32 IO Devices changing during operation (partner ports) are
performance: 250 µs to 4 ms in 125 µs frame 250 µs to 512 ms; minimum value depends on preset communication share for PROFINET IO, on the number of IO Devices and on the amount of configured user data, see PROFINET system description Address area Inputs, max. 4 kbyte Outputs, max. 4 kbyte User data consistency, max. 1 024 byte PROFINET IO Device Services PG/OP communication Yes Sory routing Yes Sory communication Yes Isochronous mode No Open IE communication Yes IRT Yes Prioritized startup Yes Shared device Yes Number of IO Controllers with shared device, max. Transfer memory Inputs, max. 1 440 byte; Per IO Controller with shared device Number, max. 1 440 byte; Per IO Controller with shared device Number, max. 64 User data per submodule, max. 1 024 byte	 Device replacement without swap medium 	Yes
communication share for PROFINET IO, on the number of IO Devices and on the amount of configured user data, see PROFINET system description Address area - Inputs, max.	— Send cycles	
- Inputs, max Outputs, max Outputs, max User data consistency, max. - User data consistency, max. PROFINET IO Device Services - PG/OP communication - S7 routing - S7 communication - S7 communication - Isochronous mode - Open IE communication - IRT - Prioritized startup - Shared device - Number of IO Controllers with shared device, max. Transfer memory - Inputs, max Outputs, max Outputs, max Outputs, max Outputs, max Number, max Number, max User data per submodule, max. PROFINET CBA	— Updating time	communication share for PROFINET IO, on the number of IO Devices and on the amount of configured user data, see
Outputs, max User data consistency, max. PROFINET IO Device Services PG/OP communication S7 routing S7 routing S7 communication Isochronous mode Open IE communication IRT Prioritized startup Shared device Number of IO Controllers with shared device, max. Transfer memory Inputs, max Outputs, max Outputs, max Outputs, max Number, max Number, max User data per submodule, max. PROFINET CBA 1 024 byte 1 024 byte	Address area	
- User data consistency, max. 1 024 byte PROFINET IO Device Services - PG/OP communication Yes - S7 routing Yes - S7 communication Yes - Isochronous mode No - Open IE communication Yes - IRT Yes - Prioritized startup Yes - Shared device Yes - Number of IO Controllers with shared device, max. Transfer memory - Inputs, max. 1 440 byte; Per IO Controller with shared device Submodules - Number, max. 64 - User data per submodule, max. 1 024 byte PROFINET CBA	— Inputs, max.	4 kbyte
PROFINET IO Device Services - PG/OP communication Yes - S7 routing Yes - S7 communication Yes - Isochronous mode No - Open IE communication Yes - IRT Yes - Prioritized startup Yes - Shared device Yes - Number of IO Controllers with shared device, max. Transfer memory - Inputs, max. 1 440 byte; Per IO Controller with shared device Submodules - Number, max. 64 - User data per submodule, max. 1 024 byte PROFINET CBA	— Outputs, max.	4 kbyte
Services	 User data consistency, max. 	1 024 byte
 — PG/OP communication — S7 routing — S7 communication — S7 communication — Isochronous mode — Open IE communication — IRT — Prioritized startup — Prioritized startup — Shared device — Number of IO Controllers with shared device, max. Transfer memory — Inputs, max. — 1 440 byte; Per IO Controller with shared device Submodules — Number, max. — Number, max. — User data per submodule, max. 1 024 byte 	PROFINET IO Device	
- S7 routing Yes - S7 communication Yes - Isochronous mode No - Open IE communication Yes - IRT Yes - Prioritized startup Yes - Shared device Yes - Number of IO Controllers with shared device, max. Transfer memory - Inputs, max. 1 440 byte; Per IO Controller with shared device Submodules - Number, max. 64 - User data per submodule, max. 1 024 byte	Services	
— S7 communication Yes — Isochronous mode No — Open IE communication Yes — IRT Yes — Prioritized startup Yes — Shared device Yes — Number of IO Controllers with shared device, max. Transfer memory — Inputs, max. 1 440 byte; Per IO Controller with shared device — Outputs, max. 1 440 byte; Per IO Controller with shared device Submodules — Number, max. 64 — User data per submodule, max. 1 024 byte	— PG/OP communication	Yes
- Isochronous mode No - Open IE communication Yes - IRT Yes - Prioritized startup Yes - Shared device Yes - Number of IO Controllers with shared device, max. Transfer memory - Inputs, max. 1 440 byte; Per IO Controller with shared device - Outputs, max. 1 440 byte; Per IO Controller with shared device Submodules - Number, max. 64 - User data per submodule, max. 1 024 byte	— S7 routing	Yes
— Open IE communication — IRT — Yes — Prioritized startup — Shared device — Number of IO Controllers with shared device, max. Transfer memory — Inputs, max. — Outputs, max. — Outputs, max. Submodules — Number, max. — User data per submodule, max. PROFINET CBA Yes Yes Yes 1 440 byte; Per IO Controller with shared device 1 440 byte; Per IO Controller with shared device	— S7 communication	Yes
 — IRT — Prioritized startup — Shared device — Number of IO Controllers with shared device, max. Transfer memory — Inputs, max. — Outputs, max. 1 440 byte; Per IO Controller with shared device — Outputs, max. 1 440 byte; Per IO Controller with shared device Submodules — Number, max. — User data per submodule, max. 1 024 byte 	— Isochronous mode	No
Prioritized startup — Shared device — Number of IO Controllers with shared device, max. Transfer memory — Inputs, max. — Outputs, max. 1 440 byte; Per IO Controller with shared device — Outputs, max. 1 440 byte; Per IO Controller with shared device Submodules — Number, max. — User data per submodule, max. 1 024 byte	— Open IE communication	Yes
— Shared device — Number of IO Controllers with shared device, max. Transfer memory — Inputs, max. — Outputs, max. Outputs, max. 1 440 byte; Per IO Controller with shared device 1 440 byte; Per IO Controller with shared device Submodules — Number, max. 64 — User data per submodule, max. 1 024 byte	— IRT	Yes
— Number of IO Controllers with shared device, max. Transfer memory — Inputs, max. — Outputs, max. 1 440 byte; Per IO Controller with shared device 1 440 byte; Per IO Controller with shared device Submodules — Number, max. — Number, max. — User data per submodule, max. PROFINET CBA	 Prioritized startup 	Yes
device, max. Transfer memory — Inputs, max. — Outputs, max. 1 440 byte; Per IO Controller with shared device 1 440 byte; Per IO Controller with shared device Submodules — Number, max. — User data per submodule, max. PROFINET CBA	— Shared device	Yes
 — Inputs, max. — Outputs, max. Submodules — Number, max. — User data per submodule, max. PROFINET CBA 1 440 byte; Per IO Controller with shared device 64 1 024 byte 		2
— Outputs, max. 1 440 byte; Per IO Controller with shared device Submodules — Number, max. — User data per submodule, max. PROFINET CBA 1 440 byte; Per IO Controller with shared device 64 1 024 byte	Transfer memory	
Submodules — Number, max. 64 — User data per submodule, max. 1 024 byte PROFINET CBA	— Inputs, max.	1 440 byte; Per IO Controller with shared device
 Number, max. User data per submodule, max. PROFINET CBA 	— Outputs, max.	1 440 byte; Per IO Controller with shared device
— User data per submodule, max. 1 024 byte PROFINET CBA	Submodules	
PROFINET CBA	— Number, max.	64
	— User data per submodule, max.	1 024 byte
• acyclic transmission Yes	PROFINET CBA	
	acyclic transmission	Yes

cyclic transmission	Yes
Open IE communication	
Number of connections, max.	46
 Local port numbers used at the system end 	0, 20, 21, 25, 80, 102, 135, 161, 34962, 34963, 34964, 65532, 65533, 65534, 65535
 Keep-alive function, supported 	Yes

Protocols	
Open IE communication	
• TCP/IP	
— Number of connections, max.	46
— Data length, max.	32 kbyte
 several passive connections per port, supported 	Yes
• ISO-on-TCP (RFC1006)	Yes; Via integrated PROFINET interface or CP 443-1 Adv. and loadable FBs
 Number of connections, max. 	46
— Data length, max.	32 kbyte; 1452 bytes via CP 443-1 Adv.
• UDP	
— Number of connections, max.	46
— Data length, max.	1 472 byte

Isochronous mode	
Isochronous operation (application synchronized up	Yes; Via PROFIBUS DP or PROFINET interface
to terminal)	
Equidistance	Yes
Number of DP masters with isochronous mode	1
User data per isochronous slave, max.	244 byte
shortest clock pulse	1.5 ms; 0.5 ms without use of SFC 126, 127
max. cycle	32 ms

Communication functions	
PG/OP communication	Yes
 Number of connectable OPs without message processing 	47
 Number of connectable OPs with message processing 	47; When using Alarm_S/SQ and Alarm_D/DQ
Data record routing	Yes
Global data communication	
• supported	Yes
 Number of GD loops, max. 	8
 Number of GD packets, transmitter, max. 	8
 Number of GD packets, receiver, max. 	16
 Size of GD packets, max. 	54 byte
• Size of GD packet (of which consistent), max.	1 variable

S7 basic communication	
• supported	Yes
User data per job, max.	76 byte
 User data per job (of which consistent), max. 	1 variable
S7 communication	
• supported	Yes
• as server	Yes
● as client	Yes
User data per job, max.	64 kbyte
 User data per job (of which consistent), max. 	462 byte; 1 variable
S5 compatible communication	
• supported	Yes; Via FC AG_SEND and AG_RECV, max. via 10 CP 443-1 or 443-5
• User data per job, max.	8 kbyte
• User data per job (of which consistent), max.	240 byte
 Number of simultaneous AG-SEND/AG-RECV orders per CPU, max. 	24/24
Standard communication (FMS)	
• supported	Yes; Via CP and loadable FB
Open IE communication	
• TCP/IP	Yes; via integrated PROFINET interface and loadable FBs
• UDP	Yes; via integrated PROFINET interface and loadable FBs
Web server	
• supported	Yes
 Number of HTTP clients 	5
User-defined websites	Yes
PROFINET CBA (at set setpoint communication load)	
 Setpoint for the CPU communication load 	20 %
 Number of remote interconnection partners 	32
 Number of functions, master/slave 	150
 Total of all master/slave connections 	4 500
 Data length of all incoming connections master/slave, max. 	45 000 byte
 Data length of all outgoing connections master/slave, max. 	45 000 byte
 Number of device-internal and PROFIBUS interconnections 	1 000
 Data length of device-internal und PROFIBUS interconnections, max. 	16 000 byte
Data length per connection, max.	2 000 byte
Remote interconnections with acyclic transmission	
— Sampling frequency: Sampling time, min.	200 ms; Depending on preset communication load, number of interconnections and data length used

 Number of incoming interconnections 	250
 Number of outgoing interconnections 	250
 Data length of all incoming 	8 000 byte
interconnections, max.	
— Data length of all outgoing	8 000 byte
interconnections, max.	2 000 byte
— Data length per connection, max.	2 000 byte
Remote interconnections with cyclic transmission	1 ms; Depending on preset communication load, number of
 Transmission frequency: Transmission interval, min. 	interconnections and data length used
Number of incoming interconnections	300
Number of outgoing interconnections	300
Data length of all incoming	4 800 byte
interconnections, max.	·
 Data length of all outgoing 	4 800 byte
interconnections, max.	
 Data length per connection, max. 	450 byte
HMI variables via PROFINET (acyclic)	
 Number of stations that can log on for HMI variables (PN OPC/iMap) 	2x PN OPC/1x iMap
HMI variable updating	500 ms
Number of HMI variables	1 000
 Data length of all HMI variables, max. 	32 000 byte
PROFIBUS proxy functionality	
— supported	Yes; 32 PROFIBUS slaves max. connectable
 Data length per connection, max. 	240 byte; Slave-dependent
Number of connections	
• overall	48
 usable for PG communication 	47
 reserved for PG communication 	1
 adjustable for PG communication, max. 	0
 usable for OP communication 	47
 reserved for OP communication 	1
 adjustable for OP communication, max. 	0
 usable for S7 basic communication 	46
 reserved for S7 basic communication 	0
 adjustable for S7 basic communication, 	0
max.	
 usable for S7 communication 	46
 reserved for S7 communication 	0
— adjustable for S7 communication, max.	0
 usable for routing 	23

— reserved for routing	0
— adjustable for routing, max.	0

S7 message functions	
Number of login stations for message functions, max.	47; Max. 47 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 8
	with Alarm, Alarm_8, Alarm_8P, Notify and Notify_8 (e.g. WinCC)
Symbol-related messages	Yes
SCAN procedure	Yes
Program alarms	Yes
Process diagnostic messages	Yes
simultaneously active Alarm-S blocks, max.	250; Simultaneously active alarm_S/SQ blocks or alarm_D/DQ blocks
Alarm 8-blocks	Yes
 Number of instances for alarm 8 and S7 	300
communication blocks, max.	
• preset, max.	150
Process control messages	Yes
Number of archives that can log on simultaneously	4
(SFB 37 AR_SEND)	
Number of messages	
• overall, max.	256
• in 100 ms grid, max.	0
● in 500 ms grid, max.	256
● in 1000 ms grid, max.	256
Number of additional values	
• with 100 ms grid, max.	0
• with 500, 1000 ms grid, max.	1
Test commissioning functions	
Status block	Yes; Up to 16 simultaneously
Single step	Yes
Number of breakpoints	16
Status/control	
Status/control variable	Yes; Up to 16 variable tables
 Variables 	Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters
Number of variables, max.	70; Status/control
Forcing	
• Forcing	Yes
Forcing, variables	Inputs/outputs, bit memories, distributed I/Os
Number of variables, max.	64
Diagnostic buffer	

• present

• Number of entries, max.

Yes

3 200

— adjustable	Yes
— preset	120
Service data	
• can be read out	Yes
Standards, approvals, certificates CE mark	West
	Yes Yes
CSA approval UL approval	Yes
cULus	Yes
FM approval	Yes
RCM (formerly C-TICK)	Yes
KC approval	Yes
EAC (formerly Gost-R)	Yes
Use in hazardous areas	100
• ATEX	ATEX II 3G Ex nA IIC T4 Gc
Ambient conditions	
Ambient temperature during operation	0.00
• min.	0 °C
• max.	60 °C
Configuration	
Configuration software	
Configuration Software	
• STEP 7	Yes
• STEP 7	see instruction list
• STEP 7 Programming	
• STEP 7 Programming • Command set	see instruction list
 STEP 7 Programming Command set Nesting levels 	see instruction list
 STEP 7 Programming Command set Nesting levels Access to consistent data in process image 	see instruction list 7 Yes
 STEP 7 Programming Command set Nesting levels Access to consistent data in process image System functions (SFC) 	see instruction list 7 Yes see instruction list
 STEP 7 Programming Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) 	see instruction list 7 Yes see instruction list
 STEP 7 Programming Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language 	see instruction list 7 Yes see instruction list see instruction list
 STEP 7 Programming Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD 	see instruction list 7 Yes see instruction list see instruction list
 STEP 7 Programming Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD 	see instruction list 7 Yes see instruction list see instruction list Yes Yes
 STEP 7 Programming Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL 	see instruction list 7 Yes see instruction list see instruction list Yes Yes Yes
 STEP 7 Programming Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL 	see instruction list 7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes
 STEP 7 Programming Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC 	see instruction list 7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes Yes Yes
 STEP 7 Programming Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH 	see instruction list 7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes
 STEP 7 Programming Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph® 	see instruction list 7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes
 STEP 7 Programming Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph® Number of simultaneously active SFCs 	see instruction list 7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
 STEP 7 Programming Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph® Number of simultaneously active SFCs DPSYC_FR 	see instruction list 7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
 STEP 7 Programming Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph® Number of simultaneously active SFCs DPSYC_FR D_ACT_DP 	see instruction list 7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye

— WR_PARM	8; SFC 55; per interface
— PARM_MOD	1; SFC 57; per interface
— WR_DPARM	2; SFC 56; per interface
— DPNRM_DG	8; SFC 13; per interface
— RDSYSST	8; SFC 51
— DP_TOPOL	1; SFC 103; per interface
Number of simultaneously active SFBs	
— RDREC	8; SFB 52; per interface, but not more than 32 across all external interfaces
— WRREC	8; SFB 53; per interface, but not more than 32 across all external interfaces
Know-how protection	
User program protection/password protection	Yes
Block encryption	Yes; With S7 block Privacy
Dimensions	
Width	25 mm
Height	290 mm
Depth	219 mm
Weights	
Weight, approx.	750 g
last modified:	08/25/2017