## SIEMENS

## Data sheet

## 6GK5204-0BA10-2BA3



SCALANCE X204IRT, managed IE IRT switch, 4x 10/100 Mbps RJ45 ports, error signaling contact with set button, redundant power supply, PROFINET IO device, network management, Redundancy Manager integrated, incl. electron. manual on CD-ROM, C-PLUG optional

product type designation	SCALANCE X204IRT	
transfer rate		
transfer rate	10 Mbit/s, 100 Mbit/s	
interfaces / for communication / maximum configuration for modular devices		
number of electrical ports / maximum	4	
interfaces / for communication / integrated		
number of electrical connections		
<ul> <li>for network components or terminal equipment</li> </ul>	4	
interfaces / other		
number of electrical connections		
<ul> <li>for signaling contact</li> </ul>	1	
<ul> <li>for power supply</li> </ul>	1	
type of electrical connection		
<ul> <li>for signaling contact</li> </ul>	2-pole terminal block	
<ul> <li>for power supply</li> </ul>	4-pole terminal block	
design of the removable storage		
• C-PLUG	Yes	
signal inputs/outputs		
operating voltage / of the signaling contacts		
<ul> <li>at DC / rated value</li> </ul>	24 V	
operational current / of the signaling contacts		
• at DC / maximum	0.1 A	
supply voltage, current consumption, power loss		
type of voltage / 1 / of the supply voltage	DC	
<ul> <li>supply voltage / 1 / rated value</li> </ul>	24 V	
<ul> <li>power loss [W] / 1 / rated value</li> </ul>	3.4 W	
<ul> <li>supply voltage / 1 / rated value</li> </ul>	18 32 V	
<ul> <li>consumed current / 1 / maximum</li> </ul>	0.14 A	
<ul> <li>type of electrical connection / 1 / for power supply</li> </ul>	4-pole terminal block	
<ul> <li>product component / 1 / fusing at power supply input</li> </ul>	Yes	
<ul> <li>fuse protection type / 1 / at input for supply voltage</li> </ul>	0.6 A / 60 V	
ambient conditions		
ambient temperature		
<ul> <li>during operation</li> </ul>	-40 +70 °C	
during storage	-40 +85 °C	
during transport	-40 +85 °C	
relative humidity		
<ul> <li>at 25 °C / without condensation / during operation / maximum</li> </ul>	95 %	
protection class IP	IP30	

design, dimensions and weights		
design	compact	
width	60 mm	
height	125 mm	
depth	125 mm	
	0.78 kg	
net weight fastening method	0.70 Kg	
-	Yes	
35 mm top hat DIN rail mounting	Yes	
wall mounting     S7 200 rail mounting	Yes	
<ul> <li>S7-300 rail mounting</li> <li>S7-1500 rail mounting</li> </ul>	No	
product features, product functions, product components		
	50	
cascading in the case of a redundant ring / at reconfiguration time of ~0.3/~s</td <td></td>		
cascading in cases of star topology	any (depending only on signal propagation time)	
product functions / management, configuration, engineeri	ng	
product function		
• CLI	Yes	
<ul> <li>web-based management</li> </ul>	Yes	
MIB support	Yes	
TRAPs via email	Yes	
<ul> <li>configuration with STEP 7</li> </ul>	Yes	
<ul> <li>port mirroring</li> </ul>	No	
multiport mirroring	No	
with IRT / PROFINET IO switch	Yes	
PROFINET IO diagnosis	Yes	
PROFINET conformity class	C	
network load class / according to PROFINET	2	
product function / switch-managed	Yes	
protocol / is supported		
• Telnet	Yes	
• HTTP	Yes	
• HTTPS	Yes	
• TFTP	Yes	
• FTP	Yes	
• BOOTP	No	
• DCP	Yes	
• LLDP	Yes	
• SNMP v1	Yes	
SNMP v2     SNMP v3	Yes	
SNMP V3 identification & maintenance function	Yes	
	Vac	
<ul> <li>I&amp;M0 - device-specific information</li> <li>I&amp;M1 - higher level designation/location designation</li> </ul>	Yes	
product functions / diagnostics		
product function		
port diagnostics	Yes	
statistics Packet Size	Yes	
statistics packet type	Yes	
error statistics	Yes	
product functions / DHCP		
product function		
DHCP client	Yes	
product functions / redundancy		
product function		
<ul> <li>ring redundancy</li> </ul>	Yes	
<ul> <li>High Speed Redundancy Protocol (HRP)</li> </ul>	Yes	
<ul> <li>high speed redundancy protocol (HRP) with redundancy manager</li> </ul>	Yes	
<ul> <li>high speed redundancy protocol (HRP) with standby redundancy</li> </ul>	Yes	
protocol / is supported / Media Redundancy Protocol (MRP)	Yes	

product function	
<ul> <li>media redundancy protocol (MRP) with redundancy manager</li> </ul>	Yes
<ul> <li>Parallel Redundancy Protocol (PRP)/operation in the PRP-network</li> </ul>	Yes
Parallel Redundancy Protocol (PRP)/Redundant	No
Network Access (RNA) <ul> <li>passive listening</li> </ul>	Yes
	165
product functions / security	
protocol / is supported	N .
• SSH	Yes
product functions / time	
product function	
SICLOCK support	Yes
protocol / is supported	N <sub>2</sub>
• NTP • SNTP	No Yes
	res
standards, specifications, approvals	
standard	
• for FM	FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4
<ul> <li>for safety / from CSA and UL</li> </ul>	UL 60950-1, CSA C22.2 No. 60950-1
for safety / from CSA and OL     for emitted interference	EN 61000-6-4:2001 (Class A)
for interference immunity	EN 61000-6-2
MTBF	80.58 a
reference code	00.00 u
according to IEC 81346-2	KF
• according to IEC 81346-2:2019	KFE
standards, specifications, approvals / CE	
certificate of suitability / CE marking	Yes
certificate of suitability / RoHS conformity	Yes; EN 50581
standards, specifications, approvals / hazardous environm	
standard / for hazardous zone	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07
	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A,
standard / for hazardous zone	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X
<ul><li>standard / for hazardous zone</li><li>from CSA and UL</li></ul>	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes; EN 60079-7; EN 60079-0; II 3 G Ex ec IIC T4 Gc DEKRA
standard / for hazardous zone • from CSA and UL certificate of suitability • ATEX	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes; EN 60079-7; EN 60079-0; II 3 G Ex ec IIC T4 Gc DEKRA 18ATEX0025 X
standard / for hazardous zone • from CSA and UL certificate of suitability • ATEX • IECEx	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes; EN 60079-7; EN 60079-0; II 3 G Ex ec IIC T4 Gc DEKRA 18ATEX0025 X Yes; IEC 60079-7; IEC 60079-0; Ex ec IIC T4 Gc DEK 18.0017X
standard / for hazardous zone • from CSA and UL certificate of suitability • ATEX • IECEx • CCC / for hazardous zone according to GB standard	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes; EN 60079-7; EN 60079-0; II 3 G Ex ec IIC T4 Gc DEKRA 18ATEX0025 X
standard / for hazardous zone • from CSA and UL certificate of suitability • ATEX • IECEx • CCC / for hazardous zone according to GB standard standards, specifications, approvals / other	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes; EN 60079-7; EN 60079-0; II 3 G Ex ec IIC T4 Gc DEKRA 18ATEX0025 X Yes; IEC 60079-7; IEC 60079-0; Ex ec IIC T4 Gc DEK 18.0017X Yes
standard / for hazardous zone • from CSA and UL certificate of suitability • ATEX • IECEx • CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes; EN 60079-7; EN 60079-0; II 3 G Ex ec IIC T4 Gc DEKRA 18ATEX0025 X Yes; IEC 60079-7; IEC 60079-0; Ex ec IIC T4 Gc DEK 18.0017X Yes EN 61000-6-4:2001
standard / for hazardous zone • from CSA and UL certificate of suitability • ATEX • IECEx • CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability • C-Tick	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes; EN 60079-7; EN 60079-0; II 3 G Ex ec IIC T4 Gc DEKRA 18ATEX0025 X Yes; IEC 60079-7; IEC 60079-0; Ex ec IIC T4 Gc DEK 18.0017X Yes EN 61000-6-4:2001 Yes
standard / for hazardous zone • from CSA and UL certificate of suitability • ATEX • IECEx • CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability • C-Tick • KC approval	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes; EN 60079-7; EN 60079-0; II 3 G Ex ec IIC T4 Gc DEKRA 18ATEX0025 X Yes; IEC 60079-7; IEC 60079-0; Ex ec IIC T4 Gc DEK 18.0017X Yes EN 61000-6-4:2001 Yes Yes
standard / for hazardous zone • from CSA and UL certificate of suitability • ATEX • IECEx • CCC / for hazardous zone according to GB standard <b>standards, specifications, approvals / other</b> certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes; EN 60079-7; EN 60079-0; II 3 G Ex ec IIC T4 Gc DEKRA 18ATEX0025 X Yes; IEC 60079-7; IEC 60079-0; Ex ec IIC T4 Gc DEK 18.0017X Yes EN 61000-6-4:2001 Yes Yes No
standard / for hazardous zone • from CSA and UL certificate of suitability • ATEX • IECEx • CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes; EN 60079-7; EN 60079-0; II 3 G Ex ec IIC T4 Gc DEKRA 18ATEX0025 X Yes; IEC 60079-7; IEC 60079-0; Ex ec IIC T4 Gc DEK 18.0017X Yes EN 61000-6-4:2001 Yes Yes No No
standard / for hazardous zone • from CSA and UL certificate of suitability • ATEX • IECEx • CCC / for hazardous zone according to GB standard <b>standards, specifications, approvals / other</b> certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes; EN 60079-7; EN 60079-0; II 3 G Ex ec IIC T4 Gc DEKRA 18ATEX0025 X Yes; IEC 60079-7; IEC 60079-0; Ex ec IIC T4 Gc DEK 18.0017X Yes EN 61000-6-4:2001 Yes Yes No No UL 61010-2-201; CAN/CSA-IEC 61010-2-201; Report-Nr. E85972; UL 62368-1; CSA C22.2 No. 62368-1; Report-Nr. E115352; ANSI/ISA 12.12.01; CSA C22.2 No. 213; Cl. 1, Div. 2, GP A,B, C, D T4; Cl. 1,
standard / for hazardous zone • from CSA and UL certificate of suitability • ATEX • IECEx • CCC / for hazardous zone according to GB standard <b>standards, specifications, approvals / other</b> certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1 • cULus approval	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes; EN 60079-7; EN 60079-0; II 3 G Ex ec IIC T4 Gc DEKRA 18ATEX0025 X Yes; IEC 60079-7; IEC 60079-0; Ex ec IIC T4 Gc DEK 18.0017X Yes EN 61000-6-4:2001 Yes Yes No No UL 61010-2-201; CAN/CSA-IEC 61010-2-201; Report-Nr. E85972; UL 62368-1; CSA C22.2 No. 62368-1; Report-Nr. E115352; ANSI/ISA 12.12.01; CSA C22.2 No. 213; Cl. 1, Div. 2, GP A,B, C, D T4; Cl. 1, Zone 2, GP IIC T4; Report-Nr. E240480
standard / for hazardous zone • from CSA and UL certificate of suitability • ATEX • IECEx • CCC / for hazardous zone according to GB standard <b>standards, specifications, approvals / other</b> certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1 • cULus approval <b>standards, specifications, approvals / marine classificatio</b>	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes; EN 60079-7; EN 60079-0; II 3 G Ex ec IIC T4 Gc DEKRA 18ATEX0025 X Yes; IEC 60079-7; IEC 60079-0; Ex ec IIC T4 Gc DEK 18.0017X Yes EN 61000-6-4:2001 Yes Yes No No UL 61010-2-201; CAN/CSA-IEC 61010-2-201; Report-Nr. E85972; UL 62368-1; CSA C22.2 No. 62368-1; Report-Nr. E115352; ANSI/ISA 12.12.01; CSA C22.2 No. 213; Cl. 1, Div. 2, GP A,B, C, D T4; Cl. 1, Zone 2, GP IIC T4; Report-Nr. E240480
standard / for hazardous zone • from CSA and UL certificate of suitability • ATEX • IECEx • CCC / for hazardous zone according to GB standard <b>standards, specifications, approvals / other</b> certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1 • cULus approval <b>standards, specifications, approvals / marine classification</b> Marine classification association	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes; EN 60079-7; EN 60079-0; II 3 G Ex ec IIC T4 Gc DEKRA 18ATEX0025 X Yes; IEC 60079-7; IEC 60079-0; Ex ec IIC T4 Gc DEK 18.0017X Yes EN 61000-6-4:2001 Yes Yes No No UL 61010-2-201; CAN/CSA-IEC 61010-2-201; Report-Nr. E85972; UL 62368-1; CSA C22.2 No. 62368-1; Report-Nr. E115352; ANSI/ISA 12.12.01; CSA C22.2 No. 213; Cl. 1, Div. 2, GP A,B, C, D T4; Cl. 1, Zone 2, GP IIC T4; Report-Nr. E240480
standard / for hazardous zone • from CSA and UL certificate of suitability • ATEX • IECEx • CCC / for hazardous zone according to GB standard <b>standards, specifications, approvals / other</b> certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1 • cULus approval <b>standards, specifications, approvals / marine classificatio</b> Marine classification association • American Bureau of Shipping Europe Ltd. (ABS)	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes; EN 60079-7; EN 60079-0; II 3 G Ex ec IIC T4 Gc DEKRA 18ATEX0025 X Yes; IEC 60079-7; IEC 60079-0; Ex ec IIC T4 Gc DEK 18.0017X Yes EN 61000-6-4:2001 Yes Yes No No UL 61010-2-201; CAN/CSA-IEC 61010-2-201; Report-Nr. E85972; UL 62368-1; CSA C22.2 No. 62368-1; Report-Nr. E115352; ANSI/ISA 12.12.01; CSA C22.2 No. 213; Cl. 1, Div. 2, GP A,B, C, D T4; Cl. 1, Zone 2, GP IIC T4; Report-Nr. E240480 n
standard / for hazardous zone • from CSA and UL certificate of suitability • ATEX • IECEx • CCC / for hazardous zone according to GB standard <b>standards, specifications, approvals / other</b> certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1 • cULus approval <b>standards, specifications, approvals / marine classificatio</b> Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV)	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes; EN 60079-7; EN 60079-0; II 3 G Ex ec IIC T4 Gc DEKRA 18ATEX0025 X Yes; IEC 60079-7; IEC 60079-0; Ex ec IIC T4 Gc DEK 18.0017X Yes EN 61000-6-4:2001 Yes Yes No No UL 61010-2-201; CAN/CSA-IEC 61010-2-201; Report-Nr. E85972; UL 62368-1; CSA C22.2 No. 62368-1; Report-Nr. E115352; ANSI/ISA 12.12.01; CSA C22.2 No. 213; Cl. 1, Div. 2, GP A,B, C, D T4; Cl. 1, Zone 2, GP IIC T4; Report-Nr. E240480 n Yes Yes
standard / for hazardous zone • from CSA and UL certificate of suitability • ATEX • IECEx • CCC / for hazardous zone according to GB standard <b>standards, specifications, approvals / other</b> certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1 • cULus approval <b>standards, specifications, approvals / marine classificatio</b> Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV) • Det Norske Veritas (DNV)	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes; EN 60079-7; EN 60079-0; II 3 G Ex ec IIC T4 Gc DEKRA 18ATEX0025 X Yes; IEC 60079-7; IEC 60079-0; Ex ec IIC T4 Gc DEK 18.0017X Yes EN 61000-6-4:2001 Yes Yes No No UL 61010-2-201; CAN/CSA-IEC 61010-2-201; Report-Nr. E85972; UL 62368-1; CSA C22.2 No. 62368-1; Report-Nr. E115352; ANSI/ISA 12.12.01; CSA C22.2 No. 213; Cl. 1, Div. 2, GP A,B, C, D T4; Cl. 1, Zone 2, GP IIC T4; Report-Nr. E240480 n Yes Yes No
standard / for hazardous zone • from CSA and UL certificate of suitability • ATEX • IECEx • CCC / for hazardous zone according to GB standard <b>standards, specifications, approvals / other</b> certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1 • cULus approval <b>standards, specifications, approvals / marine classificatio</b> Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV) • Det Norske Veritas (DNV) • Germanische Lloyd (GL)	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes; EN 60079-7; EN 60079-0; II 3 G Ex ec IIC T4 Gc DEKRA 18ATEX0025 X Yes; IEC 60079-7; IEC 60079-0; Ex ec IIC T4 Gc DEK 18.0017X Yes EN 61000-6-4:2001 Yes Yes No No UL 61010-2-201; CAN/CSA-IEC 61010-2-201; Report-Nr. E85972; UL 62368-1; CSA C22.2 No. 62368-1; Report-Nr. E115352; ANSI/ISA 12.12.01; CSA C22.2 No. 213; Cl. 1, Div. 2, GP A,B, C, D T4; Cl. 1, Zone 2, GP IIC T4; Report-Nr. E240480 <b>n</b> Yes Yes No No
standard / for hazardous zone • from CSA and UL certificate of suitability • ATEX • IECEx • CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1 • cULus approval Standards, specifications, approvals / marine classification Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV) • Det Norske Veritas (DNV) • Germanische Lloyd (GL) • DNV GL	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes; EN 60079-7; EN 60079-0; II 3 G Ex ec IIC T4 Gc DEKRA 18ATEX0025 X Yes; IEC 60079-7; IEC 60079-0; Ex ec IIC T4 Gc DEK 18.0017X Yes EN 61000-6-4:2001 Yes Yes No No UL 61010-2-201; CAN/CSA-IEC 61010-2-201; Report-Nr. E85972; UL 62368-1; CSA C22.2 No. 62368-1; Report-Nr. E115352; ANSI/ISA 12.12.01; CSA C22.2 No. 213; Cl. 1, Div. 2, GP A,B, C, D T4; Cl. 1, Zone 2, GP IIC T4; Report-Nr. E240480 n Yes Yes No No No Yes
standard / for hazardous zone • from CSA and UL certificate of suitability • ATEX • IECEx • CCC / for hazardous zone according to GB standard <b>standards, specifications, approvals / other</b> certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1 • cULus approval <b>standards, specifications, approvals / marine classification</b> Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV) • Det Norske Veritas (DNV) • Germanische Lloyd (GL) • DNV GL • Lloyds Register of Shipping (LRS)	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes; EN 60079-7; EN 60079-0; II 3 G Ex ec IIC T4 Gc DEKRA 18ATEX0025 X Yes; IEC 60079-7; IEC 60079-0; Ex ec IIC T4 Gc DEK 18.0017X Yes EN 61000-6-4:2001 Yes Yes No No UL 61010-2-201; CAN/CSA-IEC 61010-2-201; Report-Nr. E85972; UL 62368-1; CSA C22.2 No. 62368-1; Report-Nr. E115352; ANSI/ISA 12.12.01; CSA C22.2 No. 213; Cl. 1, Div. 2, GP A,B, C, D T4; Cl. 1, Zone 2, GP IIC T4; Report-Nr. E240480 n Yes Yes No No
standard / for hazardous zone • from CSA and UL certificate of suitability • ATEX • IECEx • CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1 • cULus approval Standards, specifications, approvals / marine classification Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV) • Det Norske Veritas (DNV) • Germanische Lloyd (GL) • DNV GL • Lloyds Register of Shipping (LRS) • Nippon Kaiji Kyokai (NK)	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes; EN 60079-7; EN 60079-0; II 3 G Ex ec IIC T4 Gc DEKRA 18ATEX0025 X Yes; IEC 60079-7; IEC 60079-0; Ex ec IIC T4 Gc DEK 18.0017X Yes EN 61000-6-4:2001 Yes No No UL 61010-2-201; CAN/CSA-IEC 61010-2-201; Report-Nr. E85972; UL 62368-1; CSA C22.2 No. 62368-1; Report-Nr. E115352; ANSI/ISA 12.12.01; CSA C22.2 No. 213; Cl. 1, Div. 2, GP A,B, C, D T4; Cl. 1, Zone 2, GP IIC T4; Report-Nr. E240480 No No Yes Yes No No No Yes Yes
standard / for hazardous zone • from CSA and UL certificate of suitability • ATEX • IECEx • CCC / for hazardous zone according to GB standard <b>standards, specifications, approvals / other</b> certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1 • cULus approval <b>standards, specifications, approvals / marine classification</b> Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV) • Det Norske Veritas (DNV) • Germanische Lloyd (GL) • DNV GL • Lloyds Register of Shipping (LRS)	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes; EN 60079-7; EN 60079-0; II 3 G Ex ec IIC T4 Gc DEKRA 18ATEX0025 X Yes; IEC 60079-7; IEC 60079-0; Ex ec IIC T4 Gc DEK 18.0017X Yes EN 61000-6-4:2001 Yes Yes No No UL 61010-2-201; CAN/CSA-IEC 61010-2-201; Report-Nr. E85972; UL 62368-1; CSA C22.2 No. 62368-1; Report-Nr. E115352; ANSI/ISA 12.12.01; CSA C22.2 No. 213; Cl. 1, Div. 2, GP A,B, C, D T4; Cl. 1, Zone 2, GP IIC T4; Report-Nr. E240480 n Yes Yes No No No Yes Yes Yes
standard / for hazardous zone • from CSA and UL certificate of suitability • ATEX • IECEx • CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1 • cULus approval <b>standards, specifications, approvals / marine classification</b> Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV) • Det Norske Veritas (DNV) • Germanische Lloyd (GL) • DNV GL • Lloyds Register of Shipping (LRS) • Nippon Kaiji Kyokai (NK) • Polski Rejestr Statkow (PRS) • Royal Institution of Naval Architects (RINA)	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes; EN 60079-7; EN 60079-0; II 3 G Ex ec IIC T4 Gc DEKRA 18ATEX0025 X Yes; IEC 60079-7; IEC 60079-0; Ex ec IIC T4 Gc DEK 18.0017X Yes EN 61000-6-4:2001 Yes Yes No No UL 61010-2-201; CAN/CSA-IEC 61010-2-201; Report-Nr. E85972; UL 62368-1; CSA C22.2 No. 62368-1; Report-Nr. E115352; ANSI/ISA 12.12.01; CSA C22.2 No. 213; Cl. 1, Div. 2, GP A,B, C, D T4; Cl. 1, Zone 2, GP IIC T4; Report-Nr. E240480 n Yes Yes No No No Yes Yes Yes Yes Yes Yes
standard / for hazardous zone • from CSA and UL certificate of suitability • ATEX • IECEx • CCC / for hazardous zone according to GB standard <b>standards, specifications, approvals / other</b> certificate of suitability • C-Tick • KC approval • railway application in accordance with EN 50155 • railway application in accordance with EN 50124-1 • cULus approval <b>standards, specifications, approvals / marine classification</b> Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV) • Det Norske Veritas (DNV) • Germanische Lloyd (GL) • DNV GL • Lloyds Register of Shipping (LRS) • Nippon Kaiji Kyokai (NK) • Polski Rejestr Statkow (PRS)	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07 ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T4 Yes; EN 60079-7; EN 60079-0; II 3 G Ex ec IIC T4 Gc DEKRA 18ATEX0025 X Yes; IEC 60079-7; IEC 60079-0; Ex ec IIC T4 Gc DEK 18.0017X Yes EN 61000-6-4:2001 Yes Yes No No UL 61010-2-201; CAN/CSA-IEC 61010-2-201; Report-Nr. E85972; UL 62368-1; CSA C22.2 No. 62368-1; Report-Nr. E115352; ANSI/ISA 12.12.01; CSA C22.2 No. 213; Cl. 1, Div. 2, GP A,B, C, D T4; Cl. 1, Zone 2, GP IIC T4; Report-Nr. E240480 n Yes Yes No No No Yes Yes Yes Yes Yes Yes

further information / internet-Links	
Internet-Link	
<ul> <li>to web page: selection aid TIA Selection Tool</li> </ul>	http://www.siemens.com/tia-selection-tool
<ul> <li>to website: Industrial communication</li> </ul>	http://www.siemens.com/simatic-net
<ul> <li>to website: Industry Mall</li> </ul>	https://mall.industry.siemens.com
<ul> <li>to website: Information and Download Center</li> </ul>	http://www.siemens.com/industry/infocenter
<ul> <li>to website: Image database</li> </ul>	http://automation.siemens.com/bilddb
<ul> <li>to website: CAx-Download-Manager</li> </ul>	http://www.siemens.com/cax
<ul> <li>to website: Industry Online Support</li> </ul>	https://support.industry.siemens.com
security information	
security information	Siemens provides products and solutions with industrial security functions that support the secure operation of plants, solutions, machines, equipment and/or networks. They are important components in a holistic industrial security concept. With this in mind, Siemens' products and solutions undergo continuous development. Siemens recommends strongly that you regularly check for product updates. For the secure operation of Siemens products and solutions, it is necessary to take suitable preventive action(e.g. cell protection concept) and integrate each component into a holistic, state-of-the-art industrial security concept. Third-party products that may be in use should also be considered. For more information about industrial security, visit http://www.siemens.com/industrialsecurity. To stay informed about product updates as they occur, sign up for a product-specific newsletter. For more information, visit http://support.automation.siemens.com. (V3.4)

2/22/2023 🖸